

CITY OF PORTLAND
Fire Department
380 Congress Street
Portland, Maine 04101

Fire Inspection Violations

Business		Location	Number	Inspection Type	
OCEANSIDE AUTO CLINIC		1041 OCEAN AVE	65397-0-0	FP Routine Inspection	
Owner/Manager		CBL	Inspector		
JAMES COMPANY LLC		415 B002001	CHRISTOPHER CHAMPAGNE	Shift: 003	Unit: E11
Code	Type	Location	Inspection Date	Target Compliance	Actual Compliance
1	Fire extinguishers required		6/11/08	7/15/08	
2	Means of egress per 7.5	EXITS MUST COMPLY	6/11/08	7/15/08	
3	Utilities shall comply with 9.1	HEATING SYSTEM INSTALLATION MUST COMPLY	6/11/08	7/15/08	
4	Debris inside building	GENERAL CLUTTER IN BUILDING, BLOCKING EXITS	6/11/08	7/15/08	
5	Unnecessary debris outside of struc	CARS, TIRES, MISC. STORED ALL AROUND BLDG.	6/11/08	7/15/08	
6	Open electrical junction box	OPEN ELECTRICAL BOXES THROUGHOUT	6/11/08	7/15/08	
7	Improper wiring, not code	PROVIDE LETTER OF COMPLIANCE FROM LICENSED ELECTRICIAN	6/11/08	7/15/08	
8	Gas cylinder not properly secured	LOOSE GAS CYLINDER IN BUILDING	6/11/08	7/15/08	
9	spray area not protected	SPRAY BOOTH REQUIRES AUTOMATIC FIRE PROTECTION SYSTEM.	6/11/08	7/15/08	
10	Approved safety can required	DISPOSAL OF HAZ-MAT LIQUID	6/11/08	7/15/08	
11	boiler protection required	FURNACE NOT IN PROTECTED ENCLOSURE	6/11/08	7/15/08	
12	Hole in ceiling needs repair	HOLES IN CEILING	6/11/08	7/15/08	
13	Structure needs repair	SUPPORT FOR REAR STAIRS BROKEN	6/11/08	7/15/08	
14	obstructed egress	FRONT DOOR.	6/11/08	7/15/ 08	
15	Exits clearly visible or conspicuou	FRONT DOOR.	6/11/08	7/15/08	
16	Approved safety can required	IMPROPER DISPOSAL OF FLAMIBLE LIQUIDS	6/11/08	7/15/08	

CITY OF PORTLAND
Fire Department
380 Congress Street
Portland, Maine 04101

Fire Inspection Violations

Business	Location	Number	Inspection Type
OCEANSIDE AUTO CLINIC	1041 OCEAN AVE	65397-0-0	FP Routine Inspection
Owner/Manager	CBL	Inspector	
JAMES COMPANY LLC	415 B002001	CHRISTOPHER CHAMPAGNE	Shift: 003 Unit: E11

Code	Type	Location	Inspection Date	Target Compliance	Actual Compliance
1	Fire extinguishers required		6/11/08	7/15/08	
2	Means of egress per 7.5	EXITS MUST COMPLY	6/11/08	7/15/08	
3	Utilities shall comply with 9.1	HEATING SYSTEM INSTALLATION MUST COMPLY	6/11/08	7/15/08	
4	Debris inside building	GENERAL CLUTTER IN BUILDING, BLOCKING EXITS	6/11/08	7/15/08	
5	Unnecessary debris outside of struc	CARS, TIRES, MISC. STORED ALL AROUND BLDG.	6/11/08	7/15/08	
6	Open electrical junction box	OPEN ELECTRICAL BOXES THROUGHOUT	6/11/08	7/15/08	
7	Improper wiring, not code	PROVIDE LETTER OF COMPLIANCE FROM LICENSED ELECTRICIAN	6/11/08	7/15/08	
8	Gas cylinder not properly secured	LOOSE GAS CYLINDER IN BUILDING	6/11/08	7/15/08	
9	spray area not protected	SPRAY BOOTH REQUIRES AUTOMATIC FIRE PROTECTION SYSTEM.	6/11/08	7/15/08	
10	Approved safety can required	DISPOSAL OF HAZ-MAT LIQUID	6/11/08	7/15/08	
11	boiler protection required	FURNACE NOT IN PROTECTED ENCLOSURE	6/11/08	7/15/08	
12	Hole in ceiling needs repair	HOLES IN CEILING	6/11/08	7/15/08	
13	Structure needs repair	SUPPORT FOR REAR STAIRS BROKEN	6/11/08	7/15/08	
14	obstructed egress	FRONT DOOR.	6/11/08	7/15/08	
15	Exits clearly visible or conspicuou	FRONT DOOR.	6/11/08	7/15/08	
16	Approved safety can required	IMPROPER DISPOSAL OF FLAMIBLE LIQUIDS	6/11/08	7/15/08	