



FIRE PROTECTION
FRONTLINE DEFENSE

November 6, 2018

Craig Lewis,

Colson & Colson General Contractors,
830 Ocean Ave, Portland, ME

RE: Portland Retirement Residence,
830 Ocean Ave.,
Portland, ME 04103

Dear Sir,

This letter is to confirm that Edge Fire Protection, Inc has completed the sprinkler fire protection system and standpipe system at the above noted address. The systems have been installed and tested in accordance with NFPA 13, 2016 and NFPA 14, 2013 and the approved drawings.

Yours Truly,

A handwritten signature in black ink, appearing to read "Dave Manners".

Dave Manners, C.E.T. , Nicet Level IV
Senior Estimating/Design Manager,
Edge Fire Protection, Inc