

### NFPA 13R sprinkler check list

- Is this check list applicable? no
- What edition of NFPA 13R is the designed to? \_\_\_\_\_
- Building construction type: \_\_\_\_\_
- Will the sprinkler system provide complete or partial coverage of the building? \_\_\_\_\_
- Will covered exterior balconies, decks and ground floor patios be sprinklered? \_\_\_\_\_
- Size of riser assembly: \_\_\_\_\_
- Fire department connection- number of 2 ½" inlets: \_\_\_\_\_
- Electrical supervision will be provided via the fire alarm system per NFPA 101:9.7.2: \_\_\_\_\_
- Is the nearest fire hydrant within 100 ft. of the FDC? \_\_\_\_\_
- The completed *Contractor's Material and Test Certificate for Aboveground Piping* shall be provided at the completion of the job? \_\_\_\_\_

### NFPA 13 sprinkler check list

- Is this check list applicable? yes
- What edition of NFPA 13 is the designed to? 2007
- Building construction type: metal
- Will the sprinkler system provide complete or partial coverage of the building? complete
- System type (See NFPA 13:3.4): wet
- NFPA 13 Occupancy Classification (Hazard): light
- Is the structure high-rise (see NFPA 101:3.3.32.7)? no
- Size of riser assembly: 8" existing
- Fire department connection- number of 2 ½" inlets: existing
- Electrical supervision will be provided via the fire alarm system per NFPA 101:9.7.2: existing
- Is the nearest fire hydrant within 100 ft. of the FDC? yes
- The completed *Contractor's Material and Test Certificate for Aboveground Piping* shall be provided at the completion of the job? yes

### NFPA 14 standpipe check list

- Is this check list applicable? no
- What edition of NFPA 14 is the designed to? \_\_\_\_\_