DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

NAPPI DISTRIBUTORS

Located at

235 PRESUMPSCOT ST

PERMIT ID: 2016-00069

ISSUE DATE: 02/25/2016

CBL: 421 A005001

has permission to

Create new unit and change of use to wine storage warehouse. Demise 4,000 SF of space, create a new ADA bathroom, new HVAC, and electrical to space for the "Cellardoor Winery".

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part the reof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Laurie Leader /s/ Craig Messinger

Fire Official **Building Official**

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Type:

Approved Property Use - Zoning

Building Inspections

Fire Department

warehouse

Use Group: S-2

Wine Storage

Occupant load = 8 Building is sprinkled

ENTIRE

MUBEC/IBC 2009

Located at: 235 PRESUMPSCOT ST **PERMIT ID:** 2016-00069 CBL: 421 A005001

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing w/Fire & Draft Stopping Electrical Close-in w/Fire & Draftstopping Certificate of Occupancy/Final

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 2016-00069

Date Applied For: 01/12/2016

CBL:

421 A005001

Proposed Use:

Front bldg, left unit: Warehouse for Wine Storage ("Cellardoor

Winery")

Proposed Project Description:

Create new unit and change of use to wine storage warehouse. Demise 4,000 SF of space, create a new ADA bathroom, new HVAC, and electrical to space for the "Cellardoor Winery".

Dept: Zoning Status: Approved w/Conditions Reviewer: Christina Stacey Approval Date: 02/05/2016

Note: I-M zone Ok to Issue: ✓

1 off-street parking space for each 1,000 sf over 3,000 sf warehouse floor area - proposed 4,000 sf warehouse = 1 space required. Lot has 50+ parking spaces - OK

Warehouse <5,000 sf no loading bay required.

Conditions:

- 1) This unit shall remain a warehouse. Any change of use shall require a separate permit application for review and approval.
- 2) Separate permits shall be required for any new signage.
- 3) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.

Dept: Building Inspecti **Status:** Approved w/Conditions **Reviewer:** Laurie Leader **Approval Date:** 02/25/2016 **Note:** Ok to Issue: ✓

Conditions:

- 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.
- 2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.

 Dept:
 Engineering DPS Status:
 Not Applicable
 Reviewer:
 Approval Date:
 01/19/2016

 Note:
 Ok to Issue:
 ✓

Conditions:

1) This approval is non-applicable to Engineering DPS as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Services for any other reason than FOG, please contact David Margolis-Pineo at 207-874-8850 or dmp@portlandmaine.gov

Dept: Fire **Status:** Approved w/Conditions **Reviewer:** Craig Messinger **Approval Date:** 02/22/2016 **Note:** Ok to Issue: ✓

Conditions:

- 1) All outstanding code violations shall be corrected prior to final inspection.
- 2) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve.
- 3) Shall meet the requirements of 2009 NFPA 1 Fire Code.
- 4) Shall comply with NFPA 101, Chapter 42, Storage Occupancies.
- 5) All construction shall comply with City Code Chapter 10.