

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that
NAPPI DISTRIBUTORS

Located at
235 PRESUMPCOT ST

PERMIT ID: 2016-02489 **ISSUE DATE:** 11/02/2016 **CBL:** 421 A005001

has permission to **Installing 3 bldg wall signs (54.5 sq ft each), one freestanding monument sign (32 sq ft), and a metal awning.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Jeanie Bourke

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

warehouse & distribution with ancillary retail

Building Inspections

Use Group: M/B/S **Type:** Signs
Mercantile, Business & Storage - NAPA
Exterior
MUBEC/IBC 2009

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases 6 months.**
- **If the inspection requirements are not followed as stated below, additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

REQUIRED INSPECTIONS:

Setbacks and Footings Prior to Pouring

Electrical - Commercial

Final - Commercial

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2016-02489	Date Applied For: 09/22/2016	CBL: 421 A005001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: warehouse/distribution & ancillary retail space (NAPA Auto Parts)		Proposed Project Description: Installing 3 bldg wall signs (54.5 sq ft each), one freestanding monument sign (32 sq ft), and a metal awning.		
Dept: Zoning Status: Approved w/Conditions Reviewer: Christina Stacey Approval Date: 11/01/2016 Note: I-M zone, multitenant Ok to Issue: <input checked="" type="checkbox"/> Freestanding sign - allowed one with max size 70 sf and max height 15', proposed 32 sf and height 7' - OK Setback 5' min, proposed 7' - OK Building signs - allowed 1 per building face, proposing one on each of 3 faces. Principal façade @ Presumpscot St - façade approx 3020 sf, 8% = 241 sf max size, 55 sf proposed - OK Side facades approx 2,125 sf, 2% = 42.5 sf max size, 42.5 sf proposed - OK Conditions: 1) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspecti Status: Approved w/Conditions Reviewer: Jeanie Bourke Approval Date: 10/27/2016 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) Signage and Awning Installation to comply with Chapters 16 (Structural Loads), 31 (Materials) & 32 (ROW Height & Encroachments) of the IBC 2009 building code. 2) A separate permit is required for electrical installations				