



CUNNINGHAM
SECURITY SYSTEMS

October 26, 2016

Fire Prevention Bureau
Portland Fire Department
380 Congress Street
Portland, ME 04101
Fax#: (207) 874-8410

To Whom It May Concern:

This letter is to inform you that on October 19, 2016, we completed the installation, programming and testing of two new pull stations and a heat detector above the fire alarm control panel located in the building at 235 Presumpscot Street in Portland, ME. These new fire alarm devices were tied into the existing building fire alarm control panel and were installed, programmed and tested to NFPA 72 standards. All devices that are part of this fire alarm system were tested and signals were sent to and received at our central monitoring station. All the fire alarm devices were found to be fully functional at that time.

Should you have any questions or comments regarding this matter, please feel free to contact me at (207) 846-3350.

Sincerely,

Ronald S. Snider, Manager

cc: Acct. File