



Permitting and Inspections Department
Michael A. Russell, MS, Director

Water-Based Fire Suppression System Permit Application

A permit is required for water-based fire suppression systems. Full-sized plans and details in PDF format and this application form shall be submitted to permitting@portlandmaine.gov. Prior to acceptance of any fire protection system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided.

Construction Address: 235 Presumpscot Street

Tax Assessor's CBL:

421

A005

001

Chart #

Block #

Lot #

Sprinkler installation cost: \$47,496.00

State Sprinkler License No.: 511

State Sprinkler Permit/Log No.: FSP13438

Life Safety Code Occupancy Classification: FSP13438

Applicant Name: Residential Fire Protection, LLC

Address: 64 Daggett Hill Rd

City, State & Zip: Greene, Maine 04236

Phone: 207-946-3473

Email: scamic@rfpllc.net

Lessee/Owner Name (if different from applicant): Hardypond Construction

Address: 7 Tee Drive

City, State & Zip: Portland, Maine 04103

Phone: 207-797-6066

Email:

Contractor Name (if different from applicant):

Address:

City, State & Zip:

Phone:

Email:

The suppression work to be done will be: New Renovation Addition to existing system

Will the system be a combination sprinkler and standpipe system?

The water supply is: Municipal Pump and tank Other

Name of person to contact when permit is ready: Stan Camic

Address: 64 Daggett Hill Rd

City, State & Zip: Greene, Maine 04236

Phone: 207-946-3473

Email: scamic@rfpllc.net

Permits for water-based fire suppression systems are subject to the following:

- A copy of the state sprinkler permit with RMS sign-off is required prior to the final inspection.
- The design shall comply with City Code Chapter 10 and Fire Department Regulations Chapter 6.
- All installations must comply with NFPA and the Fire Department Technical Standards.



Permitting and Inspections Department
 Michael A. Russell, MS, Director

The following checklists are to be completed, as applicable:

NFPA 13D sprinkler (Rooming and Lodging and Small Residential Board and Care only)

What edition of NFPA 13D is system designed to? _____

Is the building part of a mixed occupancy? _____

Will all the habitable areas and closets be sprinklered? _____

Will the entrance foyers be sprinklered? _____

Is there a multipurpose room? _____

Does the system use pex piping? _____

Will the water supply meet the requirements for a two-family dwelling? _____

Will water flow activate the fire alarm system? _____

Will the valves be electrically supervised? _____

Has a city plumbing permit been issued? _____ Permit No.: _____

NFPA 13R sprinkler

What edition of NFPA 13R is the system designed to? _____

Building construction type: _____

Will the sprinkler system provide complete or partial coverage of the building? _____

Will covered exterior balconies, decks and ground floor patios be sprinklered? _____

Size of riser assembly: _____

Fire department connection – number of 2 ½” inlets: _____

Electrical supervision will be provided via the fire alarm system per NFPA 101:9.7.2: _____

Is the nearest fire hydrant within 100 feet of the FDC? _____

The completed *Contractor's Material and Test Certificate for Aboveground Piping* shall be provided at the completion of the job: _____

NFPA 13 sprinkler

What edition of NFPA 13 is the system designed to? 2016

Building construction type: metal & concrete

Will the sprinkler system provide complete or partial coverage of the building? complete

System type (see NFPA 13:3.4): Wet

NFPA 13 Occupancy Classification (Hazard): Ordinary Group II

Is the structure high-rise (see NFPA 101:3.3.32.7): no

Size or rise assembly: Existing

Fire department connection – number of 2 ½” inlets: Existing

Electrical supervision will be provided via the fire alarm system per NFPA 101:9.7.2: Existing

Is the nearest fire hydrant within 100 feet of the FDC? _____

The completed *Contractor's Material and Test Certificate for Aboveground Piping* shall be provided at the completion of the job: yes



Permitting and Inspections Department
Michael A. Russell, MS, Director

NFPA 14 standpipe

What edition of NFPA 14 is the system designed to?

Class of standpipe:

Is the system automatic or manual?

Is the system wet or dry (see NFPA 14:5.4.1.4)?

Is the structure high-rise (see NFPA 101:3.3.32.7)?

Minimum residual pressure for the most remote hose connection (see NFPA 14:7.8.1 and 7.8.1):

Maximum static pressure at hose connections (see NFPA 14:7.8.3):

Are floor control valve assemblies provided (see NFPA 14:6.3.5)?

Number of standpipes (see NFPA 14:3.3.11):

Minimum required flow rate (see NFPA 14:7.10):

Fire department connection – number of 2 1/2" inlets (see NFPA 14:7.12.3):

Pressure required at the FDC inlets to deliver the system demand (see NFPA 14:6.4.5.2.2):

Is the nearest fire hydrant within 100 feet of the FDC (see NFPA 14:6.4.5.4)?

The completed *Contractor's Material and Test Certificate for Aboveground Piping* shall be provided at the completion of the job:

NFPA 20 fire pump (not required for NFPA 13D systems)

What edition of NFPA 20 is the system design to?

What is the water source?

Is the pump and associated equipment listed for fire service?

What is the minimum flow rate?

What is the pump driver type?

Is the pump design less than 7 hp?

If less than 7 hp, does the pump have a general listing and has its use been approved by the State Fire Marshal's Office?

Will the equipment be protected in accordance with NFPA 14:5.12?

Is the pump installed at least 50 feet from the protected premises?

If not, what is the fire resistance separation provided (see NFPA 14:5.12.1.1)?

NFPA 24 private fire mains and hydrants

All information shall be provided per NFPA 24:4.1.3 prior to construction:

Design/installation shall comply with City Code Ch. 10 and Fire Department Regulations Ch. 2:

What is the minimum fire main size serving a fire hydrant?

What is the minimum fire flow available from the water supply?

The completed *Contractor's Material and Test Certificate for Underground Piping* shall be provided at the completion of the job:

The completed *City of Portland Test and Maintenance Report* and *Hydrant Flow Test Report* shall be provided at the completion of the job:

Separate permits are required for internal and external plumbing and electrical installations. For questions on Fire Department requirements, call the Fire Prevention Officer at (207) 874-8405.



Permitting and Inspections Department
Michael A. Russell, MS, Director

Electronic Signature and Fee Payment Confirmation

This is a legal document and your electronic signature is considered a legal signature per Maine state law. You will receive an e-mailed invoice from our office which signifies that your electronic permit application has been received and is ready for payment. Please pay by one of the following:

- Electronic check or credit card: portlandmaine.gov/payyourpermit
- Over the phone at (207) 874-8703
- Drop off to Room 315, City Hall
- Mail to:

**City of Portland
Permitting and Inspections Department
389 Congress Street, Room 315
Portland, Maine 04101**

By signing below, I understand the review process starts once my payment has been received. After all approvals have been completed, my permit will be issued via e-mail. Work may not commence until permit is issued.

Applicant Signature: _____

Date: 10-17-17

I have provided electronic copies and sent them on:

Date: 10-17-17

NOTE: All electronic paperwork must be delivered to permitting@portlandmaine.gov or with a thumb drive to the office.

If you or the property owner owes taxes or user charges on property within the City, payment arrangements must be made before a permit application is accepted.