

# ELECTRICAL PERMIT

## City of Portland, Me.



To the Chief Electrical Inspector, Portland Maine:  
 The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the City of Portland Electrical Ordinance, National Electrical Code and the following specifications:

Date 12-28-10  
 Permit # 2010-12-153  
 CBL# 422-B-12

LOCATION: 390 Presumpscot METER MAKE & # \_\_\_\_\_  
 CMP ACCOUNT # \_\_\_\_\_ OWNER \_\_\_\_\_  
 TENANT \_\_\_\_\_ PHONE # \_\_\_\_\_

**TOTAL EACH FEE**

OUTLETS	15	Receptacles	6	Switches		Smoke Detector	.20
FIXTURES		Incandescent	12	Fluorescent		Strips	.20
SERVICES		Overhead		Underground		TTL AMPS <800	15.00
		Overhead		Underground		>800	25.00
Temporary Service		Overhead		Underground		TTL AMPS	25.00
							25.00
METERS		(number of)					1.00
MOTORS		(number of)					2.00
RESID/COM		Electric units					1.00
HEATING		oil/gas units		Interior		Exterior	5.00
APPLIANCES		Ranges		Cook Tops		Wall Ovens	2.00
		Insta-Hot		Water heaters		Fans	2.00
		Dryers		Disposals		Dishwasher	2.00
		Compactors		Spa		Washing Machine	2.00
		Others (denote)					2.00
MISC. (number of)		Air Cond/win					3.00
		Air Cond/cent				Pools	10.00
		HVAC		EMS		Thermostat	5.00
		Signs					10.00
		Alarms/res					5.00
		Alarms/com					15.00
		Heavy Duty(CRKT)					2.00
		Circus/Carnv					25.00
		Alterations					5.00
		Fire Repairs					15.00
		E Lights					1.00
		E Generators					20.00
PANELS		Service		Remote		Main	4.00
TRANSFORMER		0-25 Kva					5.00
		25-200 Kva					8.00
		Over 200 Kva					10.00
						TOTAL AMOUNT DUE	
						MINIMUM FEE/COMMERCIAL	55.00
						MINIMUM FEE	45.00

RECEIVED  
 DEC 28 2010  
 Dept. of Building Inspections  
 City of Portland, Maine

CONTRACTORS NAME MacDonald Bros MASTER LIC. # 08498  
 ADDRESS 71 Rocky Hill Rd Saco LIMITED LIC. # \_\_\_\_\_  
 TELEPHONE 450 83013

SIGNATURE OF CONTRACTOR [Signature]

White Copy - Office • Yellow Copy - Applicant

**ELECTRICAL INSTALLATIONS—**

Permit Number \_\_\_\_\_

Location \_\_\_\_\_

Owner \_\_\_\_\_

Date of Permit \_\_\_\_\_

Final Inspection \_\_\_\_\_

By Inspector \_\_\_\_\_

INSPECTION: Service \_\_\_\_\_ by \_\_\_\_\_  
 Service called in \_\_\_\_\_  
 Closing-in \_\_\_\_\_ by \_\_\_\_\_

PROGRESS INSPECTIONS: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

DATE:	REMARKS:
1/6/2011	Electrical clos. In OK (Fix Panel Door, Add Plastic Label, Data Room Ground) BKL
2/22/2011	Need Data Room Ground, GFCI Protect The Fans, Panel cover, Add Plastic, Schedule, LPS cover
	New Access BKL