M-SERIES

SUBMITTAL DATA: MSZ-GL09NA-U1

9,000 BTU/H WALL-MOUNTED INDOOR UNIT FOR MXZ-C MULTI-ZONE HEAT-PUMP SYSTEMS

Job Name:

System Reference: | Date:

Inspections Division
Date: 12/16/16

Indoor Unit: MSZ-GL09NA-U1

Wireless Remote Controller

SPECIFICATIONS:

Rated Capacity*		
Cooling[1]	Btu/h / W	9,000
Heating at 47° F[2]	Btu/h / W	10,900

Rating Conditions per AHRI Standard:
[1] Cooling | Indoor: 80° F(27° C)DB / 67° F(19° C)WB; Outdoor: 95° F(35° C)DB / 75° F(24° C)WB
[2] Heating at 47°F | Indoor: 70° F (21° C)DB / 60° F (16° C)WB; Outdoor: 47° F (8° C)DB / 43° F (6° C)WB

For data on specific indoor units (all ducted, all non-ducted, and both ducted and non-ducted) combinations, see the MXZ Technical and Service Manual.

Applications should be restricted to comfort cooling only; equipment cooling applications are not recommended for low ambient temperature conditions.

Electrical Power Requirements		208 / 230V, 1-Phase, 60 Hz
Minimum Circuit Ampacity (MCA)	A	1.0
Blower Motor (ECM)	F.L.A.	0.76
Blower Motor Output	W	30
Field Drainpipe Size O.D.	In.(mm)	5/8 (15)

Airflow Rate (Quiet - Lo - Med - Hi - Super Hi)			
Cooling	DRY	CFM	145-170-237-321-399
	WET		109-134-201-286-364
Heating	DRY		145-170-237-321-406

Sound Pressure Level (Quiet - Lo - Med - Hi - Super Hi)		
Cooling	dB(A)	19-22-30-37-43
Heating		19-22-30-37-43

External Dimensions (H x W x D)	In.(mm)	11-5/8 x 31-7/16 x 9-1/8 (295 x 798 x 232)
Net Weight	Lbs.(kg)	29 (12)
External Finish		Munsell 1.0Y 9.2 / 0.2

Refrigerant Piping (Flared)		
Liquid (High Pressure)	In.(mm)	1/4 (6.35)
Gas (Low Pressure)		3/8 (9.52)

ACCESSORIES:

Indoor Unit

- ☐ Condensate Pump (BlueDiamond X87-711/721; 115/230V)
- ☐ Condensate Pump (Sauermann SI30-115/230; 115/230V)
- ☐ Anti-Allergy Enzyme Filter (MAC-408FT-E)
- ☐ Platinum Catalyst Deodorizing Filter (MAC-308FT-E)
- ☐ Drain Pan Level Sensor (DPLS2)

Controls

- ☐ Wireless Controller (MHK1)
- ☐ Wired Remote Controller PAR-31MAA (Requires MAC-333IF-E)
- ☐ Wireless Interface for kumo cloud™ (PAC-WHS01WF-E)
- ☐ Thermostat Interface (PAC-US444CN-1)

Specifications are subject to change without notice.

© 2016 Mitsubishi Electric US, Inc.

DIMENSIONS: MSZ-GL09NA-U1

Inspections Division
Date: 12/16/16

MSZ-GL09NA-U1

Unit: in. (mm)

Piping	Insulation	ø1 - 3/8 O.D
	Liquid line	ø1/4 19 - 11/16 (Flared connection ø1/4)
	Gas line	ø3/8 16 - 15/16 (Flared connection: ø3/8 (**GL06/09/12NA**), ø1/2 (**GL15NA**))
Drain hose	Insulation ø1-1/8 O.D Connected part ø5/8 O.D	

MITSUBISHI ELECTRIC
COOLING & HEATING

1340 Satellite Boulevard. Suwanee, GA 30024
Toll Free: 800-433-4822 www.mehvac.com

AHRI CERTIFIED www.ahridirectory.org Unitary Small HP AHRI Standard 210/240

Intertek

Specifications are subject to change without notice.

© 2016 Mitsubishi Electric US, Inc.