

... Fire Protection by Computer Design

High Tech Fire Protection
84 Hackett Mills Road Poland
P.O. Box 154 Minot, ME
Poland, ME 04274
207-998-2551

Job Name : Health Info Net 1st floor office space
Building : FP-01
Location : 1st Floor Office Space
System : #1
Contract :
Data File : 1st floor.WXF

HYDRAULIC CALCULATIONS
for

Project name: Health Info Net 1st floor office space
Location: 1st Floor Office Space
Drawing no: FP-01
Date: 9-03-13

Design

Remote area number: #1
Remote area location: 1st Floor Office Space 111
Occupancy classification: Light Hazard
Density: .1 - Gpm/SqFt
Area of application: 1950 - SqFt
Coverage per sprinkler: 196 - SqFt
Type of sprinklers calculated: Quick Response Pendent Heads
No. of sprinklers calculated: 21
In-rack demand: N/A - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 521 - GPM @ 71 - Psi
Type of system: Dry system
Volume of dry or preaction system: 153 - Gal

Water supply information

Date: 5-17-13
Location: 2" Main drain tag on riser
Source: Main tag on existing dry riser

Name of contractor: High Tech Fire Protection
Address: 84 Hackett Mills Road Poland / P.O. Box 154 Minot, ME / Pola
Phone number: 207-998-2551
Name of designer: Ed Poulin
Authority having jurisdiction: State of Maine/ City of Portland
Notes: (Include peaking information or gridded systems here.)


Water Supply Curve (C)

High Tech Fire Protection
Health Info Net 1st floor office space

Page 2
Date

City Water Supply:
C1 - Static Pressure : 99
C2 - Residual Pressure: 92
C2 - Residual Flow : 485

Demand:
D1 - Elevation : 2.599
D2 - System Flow : 420.395
D2 - System Pressure : 68.851
Hose (Demand) : 100
D3 - System Demand : 520.395
Safety Margin : 22.175



Fittings Used Summary

High Tech Fire Protection
Health Info Net 1st floor office space

Page 3
Date

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
D	Dry Rel D										28		47								
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	0	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

High Tech Fire Protection
Health Info Net 1st floor office space

Page 4
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DP1	-1.0	5.6	12.25	na	19.6	0.1	196	7.0
DP2	-1.0	5.6	12.25	na	19.6	0.1	196	7.0
DP3	-1.0	5.6	12.25	na	19.6	0.1	196	7.0
10	10.0	K = K @ EQ02	13.58	na	19.6			
11	10.0	K = K @ EQ02	13.66	na	19.65			
12	10.0	K = K @ EQ02	13.78	na	19.74			
13	10.0	K = K @ EQ02	14.02	na	19.91			
14	10.0	K = K @ EQ02	14.85	na	20.49			
15	10.0	K = K @ EQ02	15.67	na	21.05			
16	10.0	K = K @ EQ02	17.07	na	21.97			
20	10.0	K = K @ EQ01	15.21	na	21.03			
21	10.0	K = K @ EQ01	15.29	na	21.09			
22	10.0	K = K @ EQ01	15.59	na	21.3			
23	10.0	K = K @ EQ01	16.14	na	21.67			
24	10.0	K = K @ EQ01	16.52	na	21.92			
25	10.0	K = K @ EQ03	16.53	na	21.44			
26	10.0	K = K @ EQ01	16.76	na	22.08			
30	10.0	K = K @ EQ01	14.83	na	20.77			
31	10.0	K = K @ EQ01	14.9	na	20.82			
32	10.0	K = K @ EQ01	15.11	na	20.97			
33	10.0	K = K @ EQ01	15.57	na	21.28			
34	10.0	K = K @ EQ01	16.3	na	21.78			
35	10.0	K = K @ EQ01	16.43	na	21.86			
A	10.0		17.19	na				
B	10.0		17.4	na				
C	10.0		18.05	na				
D	10.0		20.22	na				
E	10.0		32.01	na				
F	7.5		37.87	na				
G	7.5		38.4	na				
H	7.5		39.14	na				
I	7.5		44.75	na				
TOR	7.5		64.52	na	100.0			
BOR	4.0		68.85	na				

The maximum velocity is 16.16 and it occurs in the pipe between nodes C and D

Final Calculations - Hazen-Williams

High Tech Fire Protection
Health Info Net 1st floor office space

Page 5
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftn'g's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DP1 to EQ01	19.60 19.6	1.049 100.0 0.1756	2E 1T	2.855 3.568 0.0	1.500 6.423 7.923	12.250 -0.433 1.391			K Factor = 5.60 Vel = 7.28	
	0.0 19.60						13.208		K Factor = 5.39	
DP2 to EQ02	19.60 19.6	1.049 100.0 0.1757	1E 2T	1.427 7.137 0.0	1.500 8.564 10.064	12.250 -0.433 1.768			K Factor = 5.60 Vel = 7.28	
	0.0 19.60						13.585		K Factor = 5.32	
DP3 to EQ03	19.60 19.6	1.049 100.0 0.1756	2E 1T	2.855 3.568 0.0	5.000 6.423 11.423	12.250 -0.433 2.006			K Factor = 5.60 Vel = 7.28	
	0.0 19.60						13.823		K Factor = 5.27	
10 to 11	19.60 19.6	2.157 100.0 0.0052		0.0 0.0 0.0	13.750 0.0 13.750	13.585 0.0 0.072			K Factor @ node EQ02 Vel = 1.72	
11 to 12	19.65 39.25	2.157 100.0 0.0189		0.0 0.0 0.0	6.500 0.0 6.500	13.657 0.0 0.123			K Factor @ node EQ02 Vel = 3.45	
12 to 13	19.74 58.99	2.157 100.0 0.0403		0.0 0.0 0.0	6.000 0.0 6.000	13.780 0.0 0.242			K Factor @ node EQ02 Vel = 5.18	
13 to 14	19.92 78.91	2.157 100.0 0.0690		0.0 0.0 0.0	12.000 0.0 12.000	14.022 0.0 0.828			K Factor @ node EQ02 Vel = 6.93	
14 to 15	20.49 99.4	2.157 100.0 0.1058		0.0 0.0 0.0	7.750 0.0 7.750	14.850 0.0 0.820			K Factor @ node EQ02 Vel = 8.73	
15 to A	21.05 120.45	2.157 100.0 0.1509	1T	8.783 0.0 0.0	1.300 8.783 10.083	15.670 0.0 1.522			K Factor @ node EQ02 Vel = 10.58	
	0.0 120.45						17.192		K Factor = 29.05	
16 to A	21.97 21.97	2.157 100.0 0.0065	1T	8.783 0.0 0.0	10.000 8.783 18.783	17.070 0.0 0.122			K Factor @ node EQ02 Vel = 1.93	
	0.0 21.97						17.192		K Factor = 5.30	
20 to 21	21.03 21.03	2.157 100.0 0.0060		0.0 0.0 0.0	14.000 0.0 14.000	15.206 0.0 0.084			K Factor @ node EQ01 Vel = 1.85	
21 to 22	21.09 42.12	2.157 100.0 0.0216		0.0 0.0 0.0	14.000 0.0 14.000	15.290 0.0 0.302			K Factor @ node EQ01 Vel = 3.70	
22 to 23	21.29 63.41	2.157 100.0 0.0461		0.0 0.0 0.0	12.000 0.0 12.000	15.592 0.0 0.553			K Factor @ node EQ01 Vel = 5.57	

Final Calculations - Hazen-Williams

High Tech Fire Protection
Health Info Net 1st floor office space

Page 6
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
23 to B	21.67 85.08	2.157 100.0 0.0793	1T	8.783 0.0 0.0	7.100 8.783 15.883	16.145 0.0 1.260			K Factor @ node EQ01 Vel = 7.47	
	0.0 85.08						17.405		K Factor = 20.39	
24 to 25	21.92 21.92	2.157 100.0 0.0061		0.0 0.0 0.0	2.300 0.0 2.300	16.520 0.0 0.014			K Factor @ node EQ01 Vel = 1.92	
25 to 26	21.44 43.36	2.157 100.0 0.0229		0.0 0.0 0.0	9.750 0.0 9.750	16.534 0.0 0.223			K Factor @ node EQ03 Vel = 3.81	
26 to B	22.07 65.43	2.157 100.0 0.0488	1T	8.783 0.0 0.0	4.500 8.783 13.283	16.757 0.0 0.648			K Factor @ node EQ01 Vel = 5.74	
	0.0 65.43						17.405		K Factor = 15.68	
30 to 31	20.77 20.77	2.157 100.0 0.0058		0.0 0.0 0.0	11.600 0.0 11.600	14.830 0.0 0.067			K Factor @ node EQ01 Vel = 1.82	
31 to 32	20.81 41.58	2.157 100.0 0.0211		0.0 0.0 0.0	10.200 0.0 10.200	14.897 0.0 0.215			K Factor @ node EQ01 Vel = 3.65	
32 to 33	20.97 62.55	2.157 100.0 0.0450		0.0 0.0 0.0	10.200 0.0 10.200	15.112 0.0 0.459			K Factor @ node EQ01 Vel = 5.49	
33 to 34	21.28 83.83	2.157 100.0 0.0772		0.0 0.0 0.0	9.500 0.0 9.500	15.571 0.0 0.733			K Factor @ node EQ01 Vel = 7.36	
34 to C	21.77 105.6	2.157 100.0 0.1183	1T	8.783 0.0 0.0	6.000 8.783 14.783	16.304 0.0 1.749			K Factor @ node EQ01 Vel = 9.27	
	0.0 105.60						18.053		K Factor = 24.85	
35 to C	21.86 21.86	1.049 100.0 0.2149	1T	3.568 0.0 0.0	4.000 3.568 7.568	16.427 0.0 1.626			K Factor @ node EQ01 Vel = 8.12	
	0.0 21.86						18.053		K Factor = 5.14	
A to B	142.42 142.42	3.26 100.0 0.0275		0.0 0.0 0.0	7.750 0.0 7.750	17.192 0.0 0.213			Vel = 5.47	
B to C	150.51 292.93	3.26 100.0 0.1045		0.0 0.0 0.0	6.200 0.0 6.200	17.405 0.0 0.648			Vel = 11.26	
C to D	127.47 420.4	3.26 100.0 0.2040	1E	6.714 0.0 0.0	3.900 6.714 10.614	18.053 0.0 2.165			Vel = 16.16	

Final Calculations - Hazen-Williams

High Tech Fire Protection
Health Info Net 1st floor office space

Page 7
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
D to E	0.0 420.4	3.26 100.0 0.2040	1V	4.796 0.0 0.0	53.000 4.795 57.795	20.218 0.0 11.788		Vel = 16.16	
E to F	0.0 420.4	3.26 100.0 0.2039	1X	12.469 0.0 0.0	11.000 12.469 23.469	32.006 1.083 4.786		Vel = 16.16	
F to G	0.0 420.4	4.26 100.0 0.0554	1V	6.39 0.0 0.0	3.000 6.390 9.390	37.875 0.0 0.520		Vel = 9.46	
G to H	0.0 420.4	4.26 100.0 0.0555	1E	9.397 0.0 0.0	4.000 9.397 13.397	38.395 0.0 0.743		Vel = 9.46	
H to I	0.0 420.4	4.26 100.0 0.0554	1F 4V	3.759 25.561 0.0	72.000 29.320 101.320	39.138 0.0 5.615		Vel = 9.46	
I to TOR	0.0 420.4	4.26 100.0 0.0554	12V	76.682 0.0 0.0	280.000 76.682 356.682	44.753 0.0 19.768		Vel = 9.46	
TOR to BOR	100.00 520.4	4.026 100.0 0.1083	1D	19.984 0.0 0.0	6.000 19.984 25.984	64.521 1.516 2.814		Qa = 100 Vel = 13.12	
	0.0 520.40					68.851		K Factor = 62.72	