

**... Fire Protection by Computer Design**

High Tech Fire Protection  
84 Hackett Mills Road Poland  
P.O. Box 154 Minot, ME  
Poland, ME 04274  
207-998-2551

Job Name : Health Info Net basement office space  
Building : FP-01  
Location : Basement Office 141  
System : #2  
Contract :  
Data File : Basement.WXF

---

**HYDRAULIC CALCULATIONS**  
**for**

**Project name:** Health Info Net basement office space  
**Location:** Basement Office 141  
**Drawing no:** FP-01  
**Date:** 9-4-13

**Design**

**Remote area number:** #2  
**Remote area location:** Basement office 141  
**Occupancy classification:** Light Hazard  
**Density:** .1 - Gpm/SqFt  
**Area of application:** 1950 - SqFt  
**Coverage per sprinkler:** 196 - SqFt  
**Type of sprinklers calculated:** Quick Response Pendent Heads  
**No. of sprinklers calculated:** 17  
**In-rack demand:** n/a - GPM  
**Hose streams:** 100 - GPM  
**Total water required (including hose streams):** 486 - GPM @ 74 - Psi  
**Type of system:** Dry System  
**Volume of dry or preaction system:** 153 - Gal

**Water supply information**

**Date:** 5-17-13  
**Location:** 2" Main drain tag on riser  
**Source:** Main Tag on existing dry riser

**Name of contractor:** High Tech Fire Protection  
**Address:** 84 Hackett Mills Road Poland / P.O. Box 154 Minot, ME / Pola  
**Phone number:** 207-998-2551  
**Name of designer:** Ed Poulin  
**Authority having jurisdiction:** State of Maine/ City of Portland  
**Notes: (Include peaking information or gridded systems here.)**


# Water Supply Curve (C)

High Tech Fire Protection  
Health Info Net basement office space

Page 2  
Date

City Water Supply:  
C1 - Static Pressure : 99  
C2 - Residual Pressure: 92  
C2 - Residual Flow : 485

Demand:  
D1 - Elevation : 1.516  
D2 - System Flow : 386.186  
D2 - System Pressure : 73.509  
Hose ( Demand ) : 100  
D3 - System Demand : 486.186  
Safety Margin : 18.459



# Fittings Used Summary

High Tech Fire Protection  
Health Info Net basement office space

Page 3  
Date

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
D	Dry Rel D												28		47							
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28	
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	
V	90' EII Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0	

## Units Summary

Diameter Units                   Inches  
Length Units                       Feet  
Flow Units                         US Gallons per Minute  
Pressure Units                   Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Pressure / Flow Summary - STANDARD

High Tech Fire Protection  
Health Info Net basement office space

Page 4  
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DP1	-1.0	5.6	12.25	na	19.6	0.1	196	7.0
DP2	-1.0	5.6	12.25	na	19.6	0.1	196	7.0
DP3	-1.0	5.6	12.25	na	19.6	0.1	196	7.0
50	7.5	K = K @ EQ01	14.46	na	20.18			
51	7.5	K = K @ EQ01	14.52	na	20.22			
52	7.5	K = K @ EQ01	14.68	na	20.33			
53	7.5	K = K @ EQ01	15.19	na	20.68			
54	7.5	K = K @ EQ01	16.07	na	21.27			
55	7.5	K = K @ EQ02	16.84	na	21.62			
56	7.5	K = K @ EQ03	12.62	na	19.6			
57	7.5	K = K @ EQ03	13.55	na	20.31			
58	7.5		17.8	na				
59	7.5	K = K @ EQ03	14.56	na	21.06			
60	7.5	K = K @ EQ03	15.63	na	21.81			
61	7.5		20.48	na				
70	7.5	K = K @ EQ02	21.87	na	24.63			
71	7.5	K = K @ EQ02	21.96	na	24.68			
72	7.5	K = K @ EQ02	22.34	na	24.89			
73	7.5	K = K @ EQ02	23.02	na	25.27			
74	7.5	K = K @ EQ03	21.74	na	25.73			
75	7.5	K = K @ EQ03	22.93	na	26.42			
76	7.5		24.45	na				
77	7.5	K = K @ EQ02	27.27	na	27.5			
AA	7.5		38.73	na				
BB	7.5		41.23	na				
F	7.5		46.74	na				
G	7.5		47.18	na				
H	8.0		47.6	na				
I	8.0		52.4	na				
TOR	8.0		69.3	na	100.0			
BOR	4.0		73.51	na				

The maximum velocity is 22.72 and it occurs in the pipe between nodes BB and F

# Final Calculations - Hazen-Williams

High Tech Fire Protection  
Health Info Net basement office space

Page 5  
Date

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DP1 to EQ01	19.60 19.6	1.049 100.0 0.1757	2E 1T	2.855 3.568 0.0	4.000 6.423 10.423	12.250 -0.433 1.831			K Factor = 5.60	
	0.0 19.60						13.648		K Factor = 5.31	
DP2 to EQ02	19.60 19.6	1.049 100.0 0.1756	1E 2T	1.427 7.137 0.0	3.000 8.564 11.564	12.250 -0.433 2.031			K Factor = 5.60	
	0.0 19.60						13.848		K Factor = 5.27	
DP3 to EQ03	19.60 19.6	1.049 100.0 0.1756	1T	3.568 0.0 0.0	1.000 3.568 4.568	12.250 -0.433 0.802			K Factor = 5.60	
	0.0 19.60						12.619		K Factor = 5.52	
50 to 51	20.18 20.18	2.157 100.0 0.0055		0.0 0.0 0.0	10.000 0.0 10.000	14.463 0.0 0.055			K Factor @ node EQ01	
									Vel = 1.77	
51 to 52	20.21 40.39	2.157 100.0 0.0200		0.0 0.0 0.0	8.100 0.0 8.100	14.518 0.0 0.162			K Factor @ node EQ01	
									Vel = 3.55	
52 to 53	20.33 60.72	2.157 100.0 0.0425		0.0 0.0 0.0	12.000 0.0 12.000	14.680 0.0 0.510			K Factor @ node EQ01	
									Vel = 5.33	
53 to 54	20.68 81.4	2.157 100.0 0.0731		0.0 0.0 0.0	12.000 0.0 12.000	15.190 0.0 0.877			K Factor @ node EQ01	
									Vel = 7.15	
54 to 55	21.26 102.66	2.157 100.0 0.1123		0.0 0.0 0.0	6.900 0.0 6.900	16.067 0.0 0.775			K Factor @ node EQ01	
									Vel = 9.01	
55 to 58	21.62 124.28	2.157 100.0 0.1600		0.0 0.0 0.0	6.000 0.0 6.000	16.842 0.0 0.960			K Factor @ node EQ02	
	0.0 124.28						17.802		K Factor = 29.46	
56 to 57	19.60 19.6	1.049 100.0 0.1757		0.0 0.0 0.0	5.300 0.0 5.300	12.619 0.0 0.931			K Factor @ node EQ03	
									Vel = 7.28	
57 to 58	20.31 39.91	1.049 100.0 0.6547	1E 1T	1.427 3.568 0.0	1.500 4.995 6.495	13.550 0.0 4.252			K Factor @ node EQ03	
									Vel = 14.82	
58 to 61	124.28 164.19	2.157 100.0 0.2677		0.0 0.0 0.0	10.000 0.0 10.000	17.802 0.0 2.677				
	0.0 164.19						20.479		K Factor = 36.28	
59 to 60	21.06 21.06	1.049 100.0 0.2004		0.0 0.0 0.0	5.300 0.0 5.300	14.564 0.0 1.062			K Factor @ node EQ03	
									Vel = 7.82	

# Final Calculations - Hazen-Williams

High Tech Fire Protection  
Health Info Net basement office space

Page 6  
Date

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
60 to 61	21.81 42.87	1.049 100.0 0.7472	1E 1T	1.427 3.568 0.0	1.500 4.995 6.495	15.626 0.0 4.853			K Factor @ node EQ03 Vel = 15.91	
61 to AA	164.19 207.06	2.157 100.0 0.4112	1T	8.783 0.0 0.0	35.600 8.783 44.383	20.479 0.0 18.250			Vel = 18.18	
	0.0 207.06					38.729			K Factor = 33.27	
70 to 71	24.63 24.63	2.157 100.0 0.0080		0.0 0.0 0.0	12.000 0.0 12.000	21.868 0.0 0.096			K Factor @ node EQ02 Vel = 2.16	
71 to 72	24.68 49.31	2.157 100.0 0.0289		0.0 0.0 0.0	13.000 0.0 13.000	21.964 0.0 0.376			K Factor @ node EQ02 Vel = 4.33	
72 to 73	24.90 74.21	2.157 100.0 0.0616		0.0 0.0 0.0	11.000 0.0 11.000	22.340 0.0 0.678			K Factor @ node EQ02 Vel = 6.52	
73 to 76	25.27 99.48	2.157 100.0 0.1059		0.0 0.0 0.0	13.500 0.0 13.500	23.018 0.0 1.430			K Factor @ node EQ02 Vel = 8.73	
	0.0 99.48					24.448			K Factor = 20.12	
74 to 76	25.73 25.73	1.049 100.0 0.2905	1T	3.568 0.0 0.0	5.750 3.568 9.318	21.741 0.0 2.707			K Factor @ node EQ03 Vel = 9.55	
	0.0 25.73					24.448			K Factor = 5.20	
75 to 76	26.42 26.42	1.049 100.0 0.3052	1T	3.568 0.0 0.0	1.400 3.568 4.968	22.932 0.0 1.516			K Factor @ node EQ03 Vel = 9.81	
76 to 77	125.21 151.63	2.157 100.0 0.2311		0.0 0.0 0.0	12.200 0.0 12.200	24.448 0.0 2.819			Vel = 13.31	
77 to BB	27.50 179.13	2.157 100.0 0.3145	1T	8.783 0.0 0.0	35.600 8.783 44.383	27.267 0.0 13.960			K Factor @ node EQ02 Vel = 15.73	
	0.0 179.13					41.227			K Factor = 27.90	
AA to BB	207.06 207.06	2.635 100.0 0.1552		0.0 0.0 0.0	16.100 0.0 16.100	38.729 0.0 2.498			Vel = 12.18	
BB to F	179.13 386.19	2.635 100.0 0.4915	1V	4.213 0.0 0.0	7.000 4.213 11.213	41.227 0.0 5.511			Vel = 22.72	
F to G	0.0 386.19	4.26 100.0 0.0473	1V	6.39 0.0 0.0	3.000 6.390 9.390	46.738 0.0 0.444			Vel = 8.69	

# Final Calculations - Hazen-Williams

High Tech Fire Protection  
Health Info Net basement office space

Page 7  
Date

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
G to H	0.0 386.19	4.26 100.0 0.0474	1E	9.397 0.0 0.0	4.000 9.397 13.397	47.182 -0.217 0.635		Vel = 8.69	
H to I	0.0 386.19	4.26 100.0 0.0474	1F 4V	3.759 25.561 0.0	72.000 29.320 101.320	47.600 0.0 4.800		Vel = 8.69	
I to TOR	0.0 386.19	4.26 100.0 0.0474	12V	76.682 0.0 0.0	280.000 76.682 356.682	52.400 0.0 16.895		Vel = 8.69	
TOR to BOR	100.00 486.19	4.026 100.0 0.0955	1D	19.984 0.0 0.0	6.000 19.984 25.984	69.295 1.732 2.482		Qa = 100 Vel = 12.25	
	0.0 486.19					73.509		K Factor = 56.71	