

## MEMORANDUM



**TO:** Shukria Wiar  
**FROM:** Dan Goyette, PE  
**DATE:** June 30, 2008  
**RE:** Roundhouse Property Expansion

---

Woodard & Curran has reviewed the proposed improvements at 125 Presumpscot Street. The proposed project involves the connection of the building roof drains to the City's storm drain system.

### Documents Reviewed

- Grading and Drainage Plan prepared by Deluca-Hoffman Associates, Inc., dated April 2005, revised June 2, 2008.
- Memo prepared by Deluca-Hoffman Associates, Inc., dated June 4, 2008.

### Comments

- Any piping within the City Right of Way shall be either concrete or PVC.
- The connection to the City system should be made to the pipe leaving the catch basin not the catch basin structure.

Please contact our office if you have any questions.

DRG  
203943