



CUNNINGHAM
SECURITY SYSTEMS

January 21, 2020

Fire Prevention Bureau
Portland Fire Department
380 Congress Street
Portland, ME 04101
Fax#: (207) 874-8410

To Whom It May Concern:

This letter is to inform you that on January 20, 2020, we completed the programming and testing of the newly installed fire alarm devices in the Northeast Dermatology Associates space (unit #18) in the building at 125 Presumpscot Street in Portland, ME. We tied these new fire alarm devices into the building's existing fire alarm control panel and programmed and tested these new devices to NFPA 72 Standards with signals sent from these devices to the fire alarm control panel with the signals received at our central monitoring station. These new fire alarm devices were found to be fully functional at that time.

Should you have any questions or comments regarding this matter, please feel free to contact me at (207) 846-3350.

Sincerely,

Ronald S. Sneider, Manager