



January 22, 2020

Portland Fire Department
380 Congress Street
Portland, ME 04101

Re: NEDA Portland – 125 Presumpscot St. (Unit 18) – Fire Sprinkler System Modifications

Fire Prevention:

Life Safety Fire Protection, Inc. has completed the fire sprinkler system modifications at the NEDA Portland project on 125 Presumpscot Street in Portland, ME. The system was tested, inspected and was left in service with all control valves left in the “open” position. The installation was found to meet the minimum design requirements for NFPA 13 and was installed as per the approved plans. Please note that the owner is responsible for yearly inspection and testing as required by NFPA 25.

Sincerely,

A handwritten signature in black ink that reads "Jeffrey Denis". The signature is written in a cursive style.

Jeffrey Denis, CET
Maine RMS #RMS326
CTO / Owner
Life Safety Fire Protection, Inc.

S p r i n k l e r S y s t e m D e s i g n & I n s t a l l a t i o n

97 Lower Jaffrey Road • Dublin • N.H. 03444 • Tel: (603) 563-7700 • Fax: (603) 563-7070
Toll Free: 877-433-3300 • email: sales@lifesafetyfire.com • www.lifesafetyfire.com