

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

PERMIT ISSUED

Permit No: 05-1640	Issue Date: NOV 17 2005	CEL: 425 1004001
-----------------------	----------------------------	---------------------

Location of Construction: 142 PRESUMPCOT ST	Owner Name: 142 PRESUMPCOT LIMITED LI	Owner Address: 142 PRESUMPCOT ST	Phone:
Business Name:	Contractor Name: Down East Energy	Contractor Address: 172 Main Street South Portland	Phone: 2077995585
Lessee/Buyer's Name	(Phone:	Permit Type: Tanks - Commercial	Zone:

Past Use: Commercial	Proposed Use: Commercial/ install a 1000gallon tank	Permit Fee: \$30.00	Cost of Work: \$30.00	CEO District: 4
-------------------------	--	------------------------	--------------------------	--------------------

FIRE DEPT: TO NFA 58	<input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied	INSPECTION: Use Group J Type: Tank
Signature: Greg Cass		Signature: [Signature]

Proposed Project Description:
install a 1000 gallon tank

PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)

Action: Approved Approved w/Conditions Denied

Signature: _____ Date: _____

Permit Taken By: Idobson	Date Applied For: 11/02/2005	Zoning Approval
-----------------------------	---------------------------------	------------------------

<ol style="list-style-type: none"> This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules. Building permits do not include plumbing, septic or electrical work. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.. 	<p>Special Zone or Reviews</p> <p><input type="checkbox"/> Shoreland</p> <p><input type="checkbox"/> Wetland</p> <p><input type="checkbox"/> Flood Zone</p> <p><input type="checkbox"/> Subdivision</p> <p><input type="checkbox"/> Site Plan</p> <p>Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/></p> <p>late: _____</p>	<p>Zoning Appeal</p> <p><input type="checkbox"/> Variance</p> <p><input type="checkbox"/> Miscellaneous</p> <p><input type="checkbox"/> Conditional Use</p> <p><input type="checkbox"/> Interpretation</p> <p><input type="checkbox"/> Approved</p> <p><input type="checkbox"/> Denied</p> <p>late: _____</p>	<p>Historic Preservation</p> <p><input type="checkbox"/> Not in District or Landmark</p> <p><input type="checkbox"/> Does Not Require Review</p> <p><input type="checkbox"/> Requires Review</p> <p><input type="checkbox"/> Approved</p> <p><input type="checkbox"/> Approved w/Conditions</p> <p><input type="checkbox"/> Denied</p> <p>Date: _____</p>
--	--	--	--

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 05-1640	Date Applied For: 11/02/2005	CBL: 425 I004001
------------------------------	--	----------------------------

Location of Construction: 142 PRESUMPCOT ST	Owner Name: 142 PRESUMPCOT LIMITED LI	Owner Address: 142 PRESUMPCOT ST	Phone:
Business Name:	Contractor Name: Down East Energy	Contractor Address: 172 Main Street South Portland	Phone (207) 799-5585
Lessee/Buyer's Name	Phone:	Permit Type: Tanks - Commercial	

Proposed Use: Commercial/ install a 1000 gallon tank	Proposed Project Description: install a 1000 gallon tank
--	--

Dept: Zoning **Status:** Not Applicable **Reviewer:** Tammy Munson **Approval Date:** 11/16/2005
Note: **OktoIssue:**

Dept: Building **Status:** Approved with Conditions **Reviewer:** Tammy Munson **Approval Date:** 11/16/2005
Note: **OktoIssue:**

- 1) The tank must not be subject to vehicular traffic.
- 2) The tank must be installed per NFPA 58.

Dept: Fire **Status:** Approved with Conditions **Reviewer:** Cptn Greg Cass **Approval Date:** 11/08/2005
Note: **OktoIssue:**

- 1) Installation to comply with NFPA 58