

Inspection Services
P. Samuel Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

September 27, 1995

PIKE BRUCE A M
120 PROVIDENCE ST
PORTLAND ME 04102

Re: 118 Providence St
CBL: 425- - I-010-001-01
DU: 3

Dear Mr. Pike:

The Housing Inspections Division of the Department of Planning and Urban Development has recently completed an overall inspection of the above-referred property.


Congratulations are extended to you for the general condition of your property which was found to meet the standards established by the City's Housing Code. We did, however, note the following items that could cause future problems:


1. INT - OVERALL - 113.50
HARD-WIRED BATTERY-BACK/UP SMOKE DETECTORS ARE REQUIRED IN EACH UNIT

Good maintenance is the best way to protect the value of your property and neighborhood.

Please feel free to call on us if we can be of assistance to you.

Sincerely,


Arthur Rowe
Code Enforcement Officer


Tammy Menon
Code Enfc. Offr./ Field Supv.