Director of Planning and Urban Development Penny St. Louis Littell

> Inspection Services, Director Jeanie Bourke

January 27, 2009

PELLETIER MICHELINE E 44 HODGINS ST PORTLAND, ME 04103

CBL: 427 G004001 Located at 44 HODGINS ST

Hand Delivery

Dear PELLETIER MICHELINE E,

A re-inspection at the above-referenced property was made on

01/27/2009

This is to certify that you have complied with our request to correct the violation(s) of the Municipal Code relating to housing conditions noted on the attached report.

This notice is intended to document that you have corrected the specific violations as previously noted. It is not intended to indicate compliance with other City regulations, it also does not imply that the structure or premises is violation free.

Thank you for your cooperation. If you have any questions, feel free to contact me at this office.

Sincerely,

Mike Menario @ (207) 874-8789

Building Inspector

CITY OF PORTLAND DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street Portland, Maine 04101

Inspection Violations

Owner/Manager		Inspector	Inspection Date
PELLETIER MICHELINE E		Mike Menario	1/27/2009
Locatation	CBL	Status	Inspection Type
44 HODGINS ST	427 G004001		Complaint-Inspection

Biology Co.	Code	Int/Ext	Floor	Unit No.	Area Co	ompliance Date
1)	6-116.(c) Violation: Notes:	Interior Egress Obstructions Maintain the hallway , front entrance and i	1 rear entran	2 ce	Various locations	01/27/2009
2)	6-109.(b) Violation: Notes:	Interior Maintenance of shared areas. Keep area around furnaces clear and free	1	2	Basement .	01/27/2009
3)	6-116.(e) Violation: Notes:	Interior Fire Protection Install smoke detector outside bedrooms	1	2	Various locations	01/27/2009

Comments: 1-27-09 Exits are clear, furnace is clear on all sides, smoke detector outside bedrooms NOTE: still has thousands of dolls in unit!