

# FAX



To: *Michelle Tibbitts*

Fax Number: *822-2146*

From: *Mike Menario*

Fax Number:

Date: *2-4-09*

Regarding: *44 Hodgins St.*

Total Number Of Pages Including Cover: *3*

Phone Number For Follow-Up: *874-8789*

**Comments:**

City Of Portland, Maine  
Inspections Division Services  
389 Congress St Room 315 Portland Me 04101-3509  
Phone: (207) 874-8703 or (207) 874-8693  
Fax: (207) 874-8716  
<http://www.portlandmaine.gov/>

Add		Edit		Delete		Carry Over		Compliance Date: <input type="text"/>		Close	
Code		Int/Ext		Status/Date		Notes:		Unit No.		Floor	
								Area		Compliant/Compliance Date	
ScheduleID:		<input type="text" value="59683"/>		ViolationID:		<input type="text" value="43783"/>		<input type="text" value="427 G004001"/>			
6-116.(c)		Interior		2		1		Various locations		<input checked="" type="checkbox"/>	
Open		Maintain the hallway , front entrance and rear entrance						01/27/2009		Violation Date	
										01/27/2009	
6-109.(b)		Interior		2		1		Basement		<input checked="" type="checkbox"/>	
Open		Keep area around furnaces clear and free from obstructions at all times						01/27/2009		Violation Date	
										01/27/2009	
6-116.(e)		Interior		2		1		Various locations		<input checked="" type="checkbox"/>	
Open		Install smoke detector outside bedrooms						01/27/2009		Violation Date	
										01/27/2009	
Create By:		<input type="text" value="mme"/>		Create Date:		<input type="text" value="01/28/2009"/>					











