



RECEIVED

JUL 31 2013

Dept. of Building Inspections
City of Portland Maine

CITY OF PORTLAND

NFPA LIFE SAFETY CODE - FIRE PREVENTION CODE
DWELLING UNIT COMPLIANCE

Section 14-391 of the Land Use Ordinance allows illegal nonconforming dwelling units to become legalized thru a given process. Part of this process is that the dwelling unit(s) that are requested to be legalized must comply or be able to comply with the NFPA Life Safety Code - Fire Prevention Code PRIOR to issuing the requested permit.

Please return this form to the Zoning Administrator (Marge Schmuckal) as to compliance or the ability to comply with these codes.

Location: 125 Sherwood St 428-A-003

Owner: Lucas Theriault

Address of Owner: 125 Sherwood St, Portland ME 04103 Telephone: 314-8979

Applicant information if different than above: —

Current number of legal units: two (2)

Number of units to be legalized: one (1)

total: ~~two~~ (3)
three

Comments of approval or disapproval (list any and all conditions):

- 1) 1. Fire Doors need each unit; AND BASEMENT. (3) 3rd floor 2nd means of egress
- 2) SMOKE & CO ALARMS ALL UNITS AND BASEMENT.
- 3) STORAGE in HALLWAYS.

Signature: Robert P...

Date: 7/29/2013