Request for Clarification of Information

Address: 126 Sherwood Street

Permit #: 2016-02738

Date: 1/5/2017

Reviewer: Greg Gilbert

- 1. (page 1) Clarify whether the steps will have backers
- 2. (page 2) Provide connection detail for landing connections (must be positive connections)
- a. Stringer to landing
- b. Stringer to Deck
- c. Rim joists to posts
- d. Deck joists to rim Joists
- 3. (page 2) Provide dimensions for height of graspable handrail (minimum one side of stair, offset from Guard Rail)
- 4. (page 2) Provide callout for method of anchoring Posts to "Sono tube" as called out on page 3
- 5. (page 3) Provide call outs for sizes and types of each lumber member
- 6. (page 3) Call out spacing between support posts
- 7. (page 3) Provide diameter for "Sono Tube"
- 8. (page 3) provide the height of the landing
- 9. (page 5) provide framing plan for Deck
- 10. (page 5) Provide detail showing whether the Deck will be self-supported or supported by the existing house? (if supported by the house, inspectors must be able to the connection from the inside of the house)
- 11. (Page 5) Show any other beams required for the support of the deck
- 12. (Page 5) Show cross bracing / lateral Support as required between deck joists
- 13. (page 5) Will shed be removed / relocated during construction / Demolition







