CITY OF PORTLAND, MAINE
RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 09/06/17

Complete railings on all sides and stairs (open space < 4")