Paul Jones 126 Sherwood 04103

CITY OF PORTLAND, MAINE
RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 09/06/17

all Railings 42" and less than 4" apart.

width of stairs: 36"

footings: 48" Sonotubes concrete

decking: PT 5/4" decking