

**... Fire Protection by Computer Design**

EASTERN FIRE PROTECTION  
170 KITTY HAWK AVE  
LEW/AUB IND PARK  
AUBURN, MAINE 04210  
207-784-1508

Job Name : 593 WASHINGTON AVE  
Drawing : 3RD FLOOR  
Location : PORTLAND, MAINE  
Remote Area : WET  
Contract : 1-05652-SPN  
Data File : WASH AVE CALC.WXF


# Water Supply Curve C

EASTERN FIRE PROTECTION  
593 WASHINGTON AVE

Page 1  
Date 8/28/2017

City Water Supply:  
C1 - Static Pressure : 105  
C2 - Residual Pressure: 100  
C2 - Residual Flow : 1524

Demand:  
D1 - Elevation : 14.220  
D2 - System Flow : 64.701  
D2 - System Pressure : 76.988  
Hose ( Demand ) : \_\_\_\_\_  
D3 - System Demand : 64.701  
Safety Margin : 27.997



# Fittings Used Summary

EASTERN FIRE PROTECTION  
593 WASHINGTON AVE

Page 2  
Date 8/28/2017

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

## Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

**SUPPLY ANALYSIS**

<b>Node at Source</b>	<b>Static Pressure</b>	<b>Residual Pressure</b>	<b>Flow</b>	<b>Available Pressure</b>	<b>Total Demand</b>	<b>Required Pressure</b>
TEST	105.0	100	1524.0	104.986	64.7	76.988

**NODE ANALYSIS**

<b>Node Tag</b>	<b>Elevation</b>	<b>Node Type</b>	<b>Pressure at Node</b>	<b>Discharge at Node</b>	<b>Notes</b>
1A	0.0	4.9	8.2	14.03	
2A	0.0	4.9	8.2	14.03	
1	127.0	4.4	16.61	17.93	
2	127.0	4.78	8.61	14.03	K=K @ 1B
3	127.0	4.78	9.69	14.89	K=K @ 1B
4	127.0	4.78	13.93	17.85	K=K @ 2B
5	127.0		14.92		
1C	117.0		22.11		
6	117.0		28.02		
7	117.0		31.58		
8	108.0		39.98		
9	98.666		47.73		
TOR	98.666		66.99		
BFP	97.166		68.09		
UDG	94.166		74.29		
TEST	94.166		76.99		

# Final Calculations - Hazen-Williams - 2007

EASTERN FIRE PROTECTION  
593 WASHINGTON AVE

Page 4  
Date 8/28/2017

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
1A to 1B	0 0	4.90	14.03 14.03	1 1.049	T 0.0	5.0 0.0 6.000	120 0.0675	8.200 0.0 0.405		Vel = 5.21	
1B			0.0 14.03					8.605		K Factor = 4.78	
2A to 2B	0 0	4.90	14.03 14.03	1 1.049	T 0.0	5.0 0.0 6.000	120 0.0675	8.200 0.0 0.405		Vel = 5.21	
2B			0.0 14.03					8.605		K Factor = 4.78	
1 to 1C	127 117	4.40	17.93 17.93	1 1.049	E 0.0	2.0 0.0 11.000	120 0.1064	16.610 4.331 1.170		Vel = 6.66	
1C			0.0 17.93					22.111		K Factor = 3.81	
2 to 3	127 127	4.78	14.03 14.03	1 1.049		0.0 0.0 16.000	120 0.0676	8.605 0.0 1.081		K = K @ 1B Vel = 5.21	
3 to 5	127 127	4.78	14.89 28.92	1 1.049	E T 0.0	2.0 5.0 20.333	120 0.2574	9.686 0.0 5.234		K = K @ 1B Vel = 10.74	
5			0.0 28.92					14.920		K Factor = 7.49	
4 to 5	127 127	4.78	17.85 17.85	1 1.049	T 0.0	5.0 0.0 9.416	120 0.1055	13.927 0.0 0.993		K = K @ 2B Vel = 6.63	
5 to 6	127 117		28.92 46.77	1 1.049	T 0.0	5.0 0.0 14.000	120 0.6265	14.920 4.331 8.771		Vel = 17.36	
6			0.0 46.77					28.022		K Factor = 8.84	
1C to 6	117 117		17.93 17.93	1 1.049	E T 0.0	2.0 5.0 55.583	120 0.1063	22.111 0.0 5.911		Vel = 6.66	
6 to 7	117 117		46.77 64.7	1.25 1.38	T 0.0	6.0 0.0 11.833	120 0.3003	28.022 0.0 3.554		Vel = 13.88	
7 to 8	117 108		0.0 64.7	1.25 1.38	T 0.0	6.0 0.0 15.000	120 0.3003	31.576 3.898 4.505		Vel = 13.88	
8 to 9	108 98.666		0.0 64.7	1.25 1.38	E 0.0	3.0 0.0 12.333	120 0.3003	39.979 4.043 3.704		Vel = 13.88	
9 to TOR	98.666 98.666		0.0 64.7	1.25 1.38	3E T 0.0	9.0 6.0 64.125	120 0.3003	47.726 0.0 19.259		Vel = 13.88	
TOR to BFP	98.666 97.166		0.0 64.7	1.25 1.38		0.0 0.0 1.500	120 0.3007	66.985 0.650 0.451		Vel = 13.88	

# Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION  
593 WASHINGTON AVE

Page 5  
Date 8/28/2017

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
BFP to UDG	97.166 94.166		0.0 64.7	1.25 1.38		0.0 0.0 3.000	120 0.3003	68.086 5.299 0.901		** Fixed Loss = 4 Vel = 13.88	
UDG to TEST	94.166 94.166		0.0 64.7	2 1.985	E T G	6.204 12.407 1.241 60.000 19.851 79.851	150 0.0338	74.286 0.0 2.702		Vel = 6.71	
TEST			0.0 64.70					76.988		K Factor = 7.37	