

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 10-0487		Issue Date:		CBL: 428 B022001	
Location of Construction: 14 CHURCHILL ST		Owner Name: PORTLAND HOUSING AUTHOR		Owner Address: 14 BAXTER BLVD	
Business Name:		Contractor Name: Simplex / Grinnell		Contractor Address: 20 Thomas Drive Westbrook	
Lessee/Buyer's Name		Phone:		Phone: 2078426440	
Past Use: Portland Housing - Community Center (Washington Gardens)		Proposed Use: Portland Housing - Community Center (Washington Gardens) - install a non - water based fire suppression system in kitchen hood		Permit Type: Fire Suppression System	
Proposed Project Description: install a non - water based fire suppression system in kitchen hood		Permit Fee: \$40.00		Cost of Work: \$1,266.50	
		FIRE DEPT: <input type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group: Type:	
		Signature:		Signature:	
		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)			
		Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied			
		Signature: Date:			
Permit Taken By: ldobson		Date Applied For: 05/07/2010		Zoning Approval	
1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules. 2. Building permits do not include plumbing, septic or electrical work. 3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..		Special Zone or Reviews		Zoning Appeal	
		<input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/> Date:		<input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date:	
		Historic Preservation			
		<input type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date:			

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT

ADDRESS

DATE

PHONE

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE

DATE

PHONE

Location of Construction: 14 CHURCHILL ST	Owner Name: PORTLAND HOUSING AUTHOR	Owner Address: 14 BAXTER BLVD	Phone:
Business Name:	Contractor Name: Simplex / Grinnell	Contractor Address: 20 Thomas Drive Westbrook	Phone 2078426440
Lessee/Buyer's Name	Phone:	Permit Type: Fire Suppression System	Zone:

Dept: Zoning **Status:** Approved **Reviewer:** Marge Schmuckal **Approval Date:** 05/10/2010
Note: **Ok to Issue:** ☒

Dept: Building **Status:** Approved **Reviewer:** Tammy Munson **Approval Date:** 05/20/2010
Note: **Ok to Issue:** ☒

Dept: Fire **Status:** Approved with Conditions **Reviewer:** Ben Wallace Jr. **Approval Date:** 05/11/2010
Note: **Ok to Issue:** ☒

- 1) As-built documents shall be submitted in pdf to the Building Inspections Office upon completion of job.
- 2) System acceptance and commissioning must be co-ordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.
- 3) Hood suppression system shall comply with NFPA 17A, 96, and UL 300. Activation of the suppression system shall activate the fire alarm system if available. A puff test is required. The Class K fire extinguisher and proper signage should be located at the suppression system pull station.

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT

ADDRESS

DATE

PHONE

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE

DATE

PHONE