



February 18, 2016

I-IV-V LLC

225 BRADLEY ST

PORTLAND, ME 04102

CBL: 428 K006001

Located at 226 SHERWOOD ST

NOTICE OF INTENT TO PROSECUTE

Dear Owner/Manager/Occupant,

An inspection of the property located at the address referenced above revealed that the structure and premises fail to comply with NFPA 2009 Fire Code and/or NFPA Life Safety Codes. Attached is a list of those violations.

The above-referenced property is in violation of the Chapter 10, Fire Prevention and Protection, Article 1 of the Portland City Code (the "Code") and National Fire Protection Association (NFPA) 101 Life Safety Code. Please note that the Code is available online at [www.portlandmaine.gov](http://www.portlandmaine.gov).

This is a notice of intent to prosecute. As such, the matter is being referred to the City of Portland Corporation Council for legal action and possible civil penalties as provided for in Chapter 10, Fire Prevention and Protection, 10-25 of the Code and in Title 30- A.M.R.S.A. 4452.

Please be advised that you will need to contact the Fire Prevention Bureau at 207-874-8400 before the court date on the attached Reference to Court letter to either schedule a re-inspection or to submit a plan of action to correct these violations.

Sincerely,

A handwritten signature in cursive script that reads "Capt. Retruccelli".

Portland Fire Department

Fire Prevention Bureau

**CITY OF PORTLAND  
PORTLAND FIRE DEPARTMENT**

380 Congress Street  
Portland, Maine 04101

**Inspection Violations**

<b>Owner/Manager</b> I-IV-V LLC		<b>Inspector</b> Steven Hall	<b>Inspection Date</b> 2/17/2016
<b>Location</b> 226 SHERWOOD ST	<b>CBL</b> 428 K006001	<b>Status</b> Failed	<b>Inspection Type</b> Fire Company-FP Routine Inspec

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
------	---------	-------	----------	------	-----------------

1) 80.80

**Violation:** NFPA 101- 7.5.1.1.1 SECOND EXIT REQUIRED; Where exits are not immediately accessible from an open floor area, continuous passageways, aisles, or corridors leading directly to every exit shall be maintained and shall be arranged to provide access for each occupant to no less than two exits by separate ways of travel, unless otherwise provided in 7.5.1.1.3 and 7.5.1.1.4.

**Notes:** NO SECOND MEANS OF EXIT ON THE 228 SIDE

2) 55.30

**Violation:** NFPA 101- 31.2.4.1 TWO EXITS REQUIRED ABOVE FIRST FLOOR; EVERY DWELLING UNIT SHALL HAVE ACCESS TO NOT LESS THAN TWO SEPARATE EXITS REMOTELY LOCATED FROM EACH OTHER AS REQUIRED BY 7.5.1.

**Notes:** NO SECOND MEANS OF EXITS ON 228 SHERWOOD

3) 89.05

**Violation:** NFPA 1 EXCESSIVE/DISORDERLY STORAGE; REFERENCE NFPA 1 FOR EXCESSIVE FUEL-LOAD.

**Notes:** STORAGE IN THE STAIRWELLS

4) 3.011

**Violation:** NFPA 101- 31.3.2.1.1 BOILER PROTECTION REQUIRED; THE AREAS DESCRIBED IN TABLE 31.3.2.1.1 SHALL BE PROTECTED AS INDICATED:  
BOILER AND FUEL-FIRED HEATER ROOMS SERVING MORE THAN A SINGLE DWELLING UNIT (MINIMUM SEPARATION/PROTECTION IS 1 HOUR OR SPRINKLERS)

**Notes:** NO SPRINKLER HEADS OVER THE WASHER DRYERS IN BASEMENT

5) 55.20

**Violation:** NFPA 101- 31.3.3.2 INTERIOR FINISH; INTERIOR WALL AND CEILING FINISH MATERIALS COMPLYING WITH 10.2 SHALL BE PERMITTED AS FOLLOWS:

- (1) EXIT ENCLOSURES- CLASS A OR B
- (2) LOBBIES AND CORRIDORS- CLASS A OR B
- (3) OTHER SPACES- CLASS A, B, OR C.

**Notes:** PANELING IN STAIRWELL OF 226

**Comments:**

STATE OF MAINE

DISTRICT COURT

Location: Portland

Docket No.

CITY OF PORTLAND and body politic and  
Corporate, located in the County of  
Cumberland and State of Maine,

Plaintiff,

**FIRE PREVENTION AND PROTECTION  
CODE VIOLATION**

**(M.R. CIV. P. 80H AND 80k)**

v.


I-IV-V LLC  
Defendant

SUMMONS NUMBER: 353673

This matter has been referred to the Corporation Counsel's Office for immediate legal action with respect to the code violations detailed in the attached letter. It has been assigned the above summons number and will be filed with the Portland District Court and will be assigned for an initial appearance at the Portland District Court 205 Newbury Street Portland, Maine 04101 at 8:30 A.M. on 04/11/2016. Please contact Tori Ross in Fire Prevention at (207)-874-8400 or via e-mail at [meservev@portlandmaine.gov](mailto:meservev@portlandmaine.gov) to set up an in-person meeting to meet with somebody in the Fire Prevention Bureau to resolve these issues or make alternative arrangements to relieve you of the requirement to appear in Court on 04/11/2016.

Dated:

2/25/16



---

Adam R. Lee, Esq. Bar No. 4143  
Associate Corporation Counsel  
City of Portland  
389 Congress St  
Portland, ME 04101  
207-874-8480