DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

OTTOMAN PROPERTIES LLC

Located at

46 VERANDA ST

PERMIT ID: 2017-00121

ISSUE DATE: 07/17/2017

CBL: 429 A004001

has permission to

Interior alterations including resurface concrete floors-replace electrical service panel-new counters-install emergency lighting and exit signs-plumbing for new equipment (Union Bagel)

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Jason Grant /s/ Brian Stephens

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

retail food establishment

Building Inspections

Use Group: M

Type: 5B

Mercantile (bagel shop, take-out only)

Occupant Load = 20

First Floor

MUBEC/IBC-2009

Fire Department

Classification:

Class C Mercantile

ENTIRE

NFPA 101 CH 37

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703

or email: buildinginspections@portlandmaine.gov

Check the Status of Permit or Schedule an Inspection at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that are attached to this permit.
- Permits expire in 6 months if the project is not started or ceases for 6 months.
- If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing

Electrical Close-in

Final - Electric

Final Inspection

Food Service Inspection

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No:	Date Applied For:	CBL:
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 87-	4-8716	2017-00121	01/27/2017	429 A004001
Proposed Use:	Proposed Project Description: Interior alterations including resurface concrete floors-replace electrical service panel-new counters-install emergency lighting an exit signs-plumbing for new equipment (Union Bagel)			
Retail food establishment (bagels)				
Dept: Zoning Status: Approved w/Conditions Re	viewer:	Jennifer Thomps	on Approval Da	ate: 01/30/2017
Note: B-1				Ok to Issue: 🗹
Conditions:				
1) As a retail establishment in the B-1 zone, the hours of operation at pm and 6am	re from 6	5 am to 11 pm and	there can be no deliv	reries betweeen 10
2) Separate permits shall be required for any new signage.				
3) This permit is being approved on the basis of plans submitted. Ar work.	ıy deviat	ions shall require a	a separate approval b	efore starting that
Dept: Building Inspecti Status: Approved w/Conditions Re	viewer:	Brian Stephens	Approval Da	ate: 07/17/2017
Note:				Ok to Issue: 🗹
Conditions:				
1) Separate permits are required for any electrical, plumbing, sprinkl pellet/wood stoves, commercial hood exhaust systems, fire suppre approval as a part of this process.				
2) This permit is approved based upon information provided by the a approved plans requires separate review and approval prior to work		or design professi	onal. Any deviation	from the final
Dept: Engineering DPS Status: Approved w/Conditions Re Note:	viewer:	Rachel Smith	Approval Da	ate: 06/19/2017 Ok to Issue: ✓
Conditions:				
1) Applicant must install an APPROVED grease control unit. Contact requirements.	t rms@p	oortlandmaine.gov	to ensure the unit me	eets City
Dept: Fire Status: Approved w/Conditions Re	viewer:	Jason Grant	Approval Da	ate: 03/22/2017
Note:				Ok to Issue: 🗹
Conditions:				
1) The means of egress shall be illuminated in accordance with 2009	NPFA 1	101, sections 7.8.		
2) Fire extinguishers are required per NFPA 1 (2009 Edition) Table with NFPA 1, 13.6.8.	13.6.2.	quantity, size, type	and location shall be	in accordance

3) All construction shall comply with City Code, Chapter 10.

All construction shall comply with 2009 NFPA 101, Chapter # 43

All construction shall comply with 2009 NFPA 1, Fire Code. Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code (Chapter 1.14.4).

All means of egress to remain accessible at all times.

PERMIT ID: 2017-00121 **Located at:** 46 VERANDA ST **CBL:** 429 A004001