CITY OF PORTLAND, MAINE
RESURGAM

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/19/13

Scale 2" = 1'

Ledger Detail

5" LedgerLoks
Esr # 1078
16" O¢
Staggered
patter
2" From edge

A Layer of 15¢
and water sheild
Between 2"x12" and
1" Board sheathing

All LedgerLok 5" Bolt Lag 16" O¢ Staggered patter 2" From edge
of 2"x12" Board

scale 1/2" = 1'