

City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 12 Veranda Street 04103		Owner: VJD Enterprises		Phone: 874-2809		Permit No: 99 066 1	
Owner Address: 201 Harvard St.		Lessee/Buyer's Name: **Rickman Sheley/Davanti Inc 12 Veranda St.		Phone:		BusinessName: 04103 Portland, ME	
Contractor Name:		Address:		Phone:		Permit Issued: JUN 24 1999 CITY OF PORTLAND	
Past Use: Vacant		Proposed Use: Hair Salon		COST OF WORK: \$ 0		PERMIT FEE: \$ 25.00	
				FIRE DEPT. <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group: Type:	
				Signature: <i>[Signature]</i>		Signature: <i>[Signature]</i>	
Proposed Project Description: Change of use from vacant to hair salon.				PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)			
				Action: Approved <input type="checkbox"/> Approved with Conditions: <input type="checkbox"/> Denied <input type="checkbox"/>			
Permit Taken By: UB				Date Applied For: 12-14-99			

Zone: CBL: 429-C-006

Zoning Approval: *[Signature]*

Special Zone or Reviews:

Shoreland *423/99*

Wetland

Flood Zone

Subdivision

Site Plan maj minor mm

Zoning Appeal

Variance

Miscellaneous

Conditional Use

Interpretation

Approved

Denied

Historic Preservation

Not in District or Landmark

Does Not Require Review

Requires Review

Action:

Approved

Approved with Conditions

Denied

Date: *[Signature]*

PERMIT ISSUED
WITH REQUIREMENTS

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

6-14-99

SIGNATURE OF APPLICANT ADDRESS: DATE: PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE:

CEO DISTRICT *[Signature]*
ub

COMMENTS

7/15 33 1/2 inch opening (door) - left railing of stairs does not meet code -
bathroom needs covered trash can & self closing door Sum w/ John Reed

8/4/99 - Work done - appears per plans -
OK to occupy TM

Inspection Record

Type	Date
Foundation: _____	_____
Framing: _____	_____
Plumbing: _____	_____
Final: _____	_____
Other: _____	_____



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 14 Veranda Street CBL#429-C-006

Issued to VJD Enterprises

Date of Issue 8-4-99

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 990661, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

1st Floor →

APPROVED OCCUPANCY

Hair Salon
Boca 1996
Use Group B Type 5-B

Limiting Conditions:

This certificate supersedes
certificate issued

Approved:

8-4-99 *Tammy Morrison*

(Date)

Tammy Morrison
Inspector

.....
Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

MA
8/4/99 *1999*

BUILDING PERMIT REPORT

DATE: 17 June 99 ADDRESS: 12 Veranda ST. CBL: 429-C-006

REASON FOR PERMIT: Change of Use From Vacant To Hair Salon

BUILDING OWNER: V.J.D. Enterprises

PERMIT APPLICANT: _____

USE GROUP B BOCA 1996 CONSTRUCTION TYPE 5B

CONDITION(S) OF APPROVAL

This permit is being issued with the understanding that the following conditions are met:

Approved with the following conditions: *1, *11, *13, *27, *30, *31, *33

1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
2. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection)
3. Foundation drain shall be placed around the perimeter of a foundation that consists of gravel or crushed stone containing not more than 10 percent material that passes through a No. 4 sieve. The drain shall extend a minimum of 12 inches beyond the outside edge of the footing. The thickness shall be such that the bottom of the drain is not higher than the bottom of the base under the floor, and that the top of the drain is not less than 6 inches above the top of the footing. The top of the drain shall be covered with an approved filter membrane material. Where a drain tile or perforated pipe is used, the invert of the pipe or tile shall not be higher than the floor elevation. The top of joints or top of perforations shall be protected with an approved filter membrane material. The pipe or tile shall be placed on not less than 2" of gravel or crushed stone, and shall be covered with not less than 6" of the same material. Section 1813.5.2
4. Foundations anchors shall be a minimum of 1/2" in diameter, 7" into the foundation wall, minimum of 12" from corners of foundation and a maximum 6' o.c. between bolts. (Section 2305.17)
5. Waterproofing and dampproofing shall be done in accordance with Section 1813.0 of the building code.
6. Precaution must be taken to protect concrete from freezing. Section 1908.0
7. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
8. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of 1/2 inch gypsum board or the equivalent applied to the garage means of 1/2 inch gypsum board or the equivalent applied to the garage side. (Chapter 4, Section 407.0 of the BOCA/1996)
9. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993). Chapter 12 & NFPA 211
10. Sound transmission control in residential building shall be done in accordance with Chapter 12, Section 1214.0 of the City's Building Code.
11. Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2, M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect. (Handrails shall be a minimum of 3e4" but not more than 38". Use Group R-3 shall not be less than 30", but not more than 38".) Handrail grip size shall have a circular cross section with an outside diameter of at least 1 1/4" and not greater than 2". (Sections 1021 & 1022.0) - Handrails shall be on both sides of stairway. (Section 1014.7)
12. Headroom in habitable space is a minimum of 7'6". (Section 1204.0)
13. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 1/4" maximum rise. All other Use Group minimum 11" tread, 7" maximum rise. (Section 1014.0)
14. The minimum headroom in all parts of a stairway shall not be less than 80 inches. (6'8") 1014.4
15. Every sleeping room below the fourth story in buildings of Use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft. (Section 1018.6)
16. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units. (Section 1010.1)
17. All vertical openings shall be enclosed with construction having a fire rating of at least one (1) hour, including fire doors with self closer's. (Over 3 stories in height requirements for fire rating is two (2) hours.) (Section 710.0)
18. The boiler shall be protected by enclosing with (1)hour fire rated construction including fire doors and ceiling, or by providing automatic extinguishment. (Table 302.1.1)
19. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be

installed and maintained at the following locations):

- In the immediate vicinity of bedrooms
- In all bedrooms
- In each story within a dwelling unit, including basements

In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required) Section 920.3.2.

A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type. (Section 921.0)

21. The Fire Alarm System shall maintained to NFPA #72 Standard.

22. The Sprinkler System shall maintained to NFPA #13 Standard.

23. All exit signs, lights and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023.0 & 1024.0 of the City's Building Code. (The BOCA National Building Code/1996)

24. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".

25. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification the Division of Inspection Services.

26. Ventilation shall meet the requirements of Chapter 12 Sections 1210.0 of the City's Building Code. (Crawl spaces & attics).

* 27. All electrical, plumbing and HVAC permits must be obtained by a Master Licensed holders of their trade. No closing in of walls until all electrical (min. 72 hours notice) and plumbing inspections have been done.

28. All requirements must be met before a final Certificate of Occupancy is issued.

29. All building elements shall meet the fastening schedule as per Table 2305.2 of the City's Building Code (the BOCA National Building Code/1996).

* 30. Ventilation of spaces within a building shall be done in accordance with the City's Mechanical Code (The BOCA National Mechanical Code/1993). (Chapter M-16)

31. Please read and implement the attached Land Use Zoning report requirements.


32. Boring, cutting and notching shall be done in accordance with Sections 2305.4.4, 2305.5.1 and 2305.5.3 of the City's Building Code.

* 33. Glass and glazing shall meet the requirements of Chapter 24 of the building code.

34. _____

35. _____

36. _____

 Samuel Hoffses, Building Inspector

cc: Lt. McDougall, PFD

Marge Schmuckal, Zoning Administrator

PSH 12-14-98 

**On the basis of plans submitted and conditions placed on these plans any deviations shall require a separate approval.

THIS IS NOT A PERMIT/CONSTRUCTION CANNOT COMMENCE UNTIL THE PERMIT IS ISSUED

**Building or Use Permit Pre-Application
Attached Single Family Dwellings/Two-Family Dwelling
Multi-Family or Commercial Structures and Additions Thereto**

In the interest of processing your application in the quickest possible manner, please complete the Information below for a Building or Use Permit.

NOTEIf you or the property owner owes real estate or personal property taxes or user charges on ANY PROPERTY within the City, payment arrangements must be made before permits of any kind are accepted.**

Location/Address of Construction (include Portion of Building): <i># 12 VERANDA ST, 04103 1ST FL</i>		
Total Square Footage of Proposed Structure: <i>600 sq feet</i>	Square Footage of Lot	
Tax Assessor's Chart, Block & Lot Number Chart# <i>429</i> Block# <i>C</i> Lot# <i>006</i>	Owner: <i>UJD ENTERPRISES</i>	Telephone#: <i>207 874-2909</i>
Owner's Address: <i>201 HARVARD ST, PORTLAND, ME, 04103</i>	Lessee/Buyer's Name (If Applicable): <i>*RICKMAN SHELLEY DAVANTI INC</i>	Cost Of Work: \$ Fee: \$ <i>25-</i>
Proposed Project Description: (Please be as specific as possible) <i>Put in Hair Salon SPACE change of use from vacant SPACE to HAIR SALON (salon already in at 12 Veranda) ST</i>		
Contractor's Name, Address & Telephone: <i>N/A</i>		Rec'd By: <i>UB</i>
Current Use: <i>vacant</i>	Proposed Use: <i>HAIR SALON</i>	

Separate permits are required for Internal & External Plumbing, HVAC and Electrical installation.

- All construction must be conducted in compliance with the 1996 B.O.C.A. Building Code as amended by Section 6-Art II.
- All plumbing must be conducted in compliance with the State of Maine Plumbing Code.
- All Electrical Installation must comply with the 1996 National Electrical Code as amended by Section 6-Art III.
- HVAC (Heating, Ventilation and Air Conditioning) installation must comply with the 1993 BOCA Mechanical Code.

You must Include the following with you application:

- 1) A Copy of Your Deed or Purchase and Sale Agreement
- 2) A Copy of your Construction Contract, if available
- 3) A Plot Plan/Site Plan

Minor or Major site plan review will be required for the above proposed projects. The attached checklist outlines the minimum standards for a site plan.

4) Building Plans

Unless exempted by State Law, construction documents must be designed by a registered design professional.

A complete set of construction drawings showing all of the following elements of construction:


- Cross Sections w/Framing details (including porches, decks w/ railings, and accessory structures)
- Floor Plans & Elevations
- Window and door schedules
- Foundation plans with required drainage and dampproofing
- Electrical and plumbing layout. Mechanical drawings for any specialized equipment such as furnaces, chimneys, gas equipment, HVAC equipment (air handling) or other types of work that may require special review must be included.


Certification

I hereby certify that I am the Owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this permit.

Signature of applicant: <i>[Signature]</i>	Date: <i>6-14-99</i>
--	----------------------

Building Permit Fee: \$25.00 for the 1st \$1000. cost plus \$5.00 per \$1,000.00 construction cost thereafter.
Additional Site review and related fees are attached on a separate addendum





FIRST FLOOR PLAN

WASHINGTON AVENUE

N/F BDK TRUST PARTNERS
BK. 8019 PG. 147

POWER POLE

SPACES 1 & 2
FOR DAVANTI
ONLY

M/F SPARKOWICK

STOCKADE FENCE

N50°09'20"E FOUND 1" IRON PIPE 0.09

71.04'

SET 5/8" IRON ROD W/CAP 9-17-98

(SMALL'S LANE)

SEE NOTE

0.18' FOUND 3/4" IRON PIPE 0.09

EASEMENT - CMP. BK. 3321 PG. 271

N51°02'50"E - 114.00'

N51°02'50"E

N38°37'10"W

19.39'

SET 5/8" IRON ROD W/CAP 9-17-98

EHT

FOUND POWER POLE #60411R

(86± DEED) N 37°54'10"W

73.00'

8979.5 SQ. FT.

103.00'

S51°02'50"W

114.00'

EXISTING BUILDING

POWER POLE
5/8" IRON ROD W/CAP TO BE SET

6610' CHAIN LINK FENCE

31±

N/F LEOLA BLACK BK. 2473 PG. 26 (PARCEL 1)

BK. 2473 PG. 26 (PARCEL 2)

EXISTING BUILDING

S37°54'10"E (86± DEED) SEE NOTE

45.5' 79.00'

FOUND 3/4" IRON PIPE

137.64'

COUNTY COMMISSIONER'S OCT. 2, 1928 ROAD LINE CO. PG 5 PG 12

2773'0/S MONUMENT

VERANDA STREET

14 Veranda St

25 SQ. FT. ± LAYOUT AND TAKEN BY S.H.C. SEPT. 4, 1979 BK. 4494 PG. 60

TO CITY OF PORTLAND NOV. 29, 1929 BK. 1333 PG. 478

CO. COMM. JUNE 4, 1887 LINE

LOCUS DEED REFERENCE:

LOUCAS DEMETRIOS GOULATIS TO EMBASSY CONVENIENCE STORES INC. BOOK 7438 PAGE 292 OCTOBER 21, 1986.

NOTE:

- LINE AS SURVEYED BY H.I. JORDAN C.E. 1936 FOR HERMAN BRUNSTEIN
- LINE AS SURVEYED BY C.H. BARRON C.E. 1950 FOR WM. + MARGARET TURNER

Handwritten signature: Daniel J. DalFonso

Handwritten signature: Daniel J. DalFonso 3-15-93

REVISED 9-23-98 TO SHOW SURVEY OF NORTHERLY LINE OF BLACK BY DANIEL J. DALFONSO - LAND SURVEYOR 111 BAHMAN ST. SO. PORTLAND, ME. 04116 (PHONE: 797-5131)		
PLAN SHOWING A STANDARD BOUNDARY SURVEY MADE FOR VINCENZO DE PAOLO "EXHIBIT A" PORTLAND, MAINE		
SCALE: 1"=20'	APPROVED BY:	DRAWN BY DJP
DATE: 3-15-93	DANIEL J. DALFONSO LAND SURVEYOR P.O. BOX 984 SCARBOROUGH, MAINE 04070-0984	REVISED
THIS SURVEY CONFORMS TO THE MAINE BOARD OF REGISTRATION FOR LAND SURVEYORS STANDARDS FOR CATEGORY I CONDITION III		RECEIVED 6/23/99
		DRAWING NUMBER 298