



Department of Permitting and Inspections

Ann Machado
Zoning Administrator

NFPA LIFE SAFETY CODE – FIRE PREVENTION CODE DWELLING UNIT COMPLIANCE

Section 14-391 of the Land Use Ordinance allows illegal non-conforming dwelling units to become legalized through a given process. Part of this process is that the dwelling units that are requested to be legalized **MUST** comply, or be able to comply, with the NFPA Life Safety Code – Fire Prevention Code, **PRIOR** to issuing the requested permit.

Please return this form to the Zoning Administrator as to compliance or the ability to comply with these codes.

Location: 57 Veranda Street – 429 D-009

Owner: Denise & Kevin Kaserman (D) 615-5608, (K) 337-7873


Address of owner: 4 Country Lane, Falmouth, ME 04105
(If different)

Applicant Information: _____
(If different):

Current number of legal units: two

Number of units to be legalized: one total of three units

Comments of approval or disapproval (List any and all conditions):
3rd floor shall require 2nd egress or construction to meet
single means requirements:
Hardwire Smoke/CO alarms required in 3rd fl. unit

Signature:  capt. FPB Date: _____