



PO Box 2551
2257 West Broadway
South Portland, ME 04106

1.800.370.3473
fax 207.879.0540

www.norrisinc.com

11/5/14

Scope of Work: 505 Washington Ave

The existing fire alarm panel is a very old conventional style panel that does not have a digital communicator for central station reporting. Norris Inc. is replacing the panel with an addressable panel and replacing all the initiating field devices with addressable type. We are also installing a cellular dialer for 24-hour central station reporting. There is currently no smoke detector above the fire alarm panel, however we will add one as part of this installation.

In an effort to replace the panel and install the communicator right away per fire dept. request, we are proposing to replace initiating devices in their existing locations only. Any additional devices required to meet code and/or city ordinance will be dealt with separately as "phase 2" of this project.

The main panel is located in the hallway just inside the main entrance of the building. There is an existing knock box at this door.

Norris Inc. will provide and install the fire alarm equipment, provide the required documentation for permits, final connections and testing according to City of Portland requirements.