



CUNNINGHAM
SECURITY SYSTEMS

May 1, 2018

Fire Prevention Bureau
Portland Fire Department
380 Congress Street
Portland, ME 04101
(207) 756-8096
Fax#: (207) 874-8410

To Whom It May Concern:

This letter is to inform you that on April 27, 2018, we completed the installation, programming and testing of the new fire alarm system in the apartment building located at 476 Washington Avenue in Portland, ME. This new fire alarm system was installed, programmed and tested per the manufacturer's recommendations and to NFPA 72 standards with test signals sent from all devices and received at our Central Monitoring Station. This fire alarm system was found to be fully functional at that time.

Should you have any questions or comments regarding this matter, please feel free to contact me at (207) 846-3350.

Sincerely,

Ronald S. Snieder, Manager

cc: Acct. File