		NOTIFICA	ATION APPL	IANCE CIRC	UIT VOLTAG	E DROPS		
				Float Harde	r			
			Po	ortland, Mai	ne			
		WIRE		CURRENT	VOLTAGE	VOLTAGE	END	CIRCUIT
PANEL	CIRCUIT	GAUGE	LENGTH	DRAW	DROP	LOSS	VOLTAGE	LOAD
FCPS	NAC 1	14	125 FT	.852A	.54VDC	2.25%	23.46VDC	28%
		FCF	S: 0.852A/	BA Spare	Capacity: 8	9%		
		Cal	culated @ N	/laximum Di	stance/Curr	ent		