Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 03/29/16

3/4/16

Scope of work: Float Harder

Norris Inc. will remove/relocate existing and install new fire alarm devices as needed for tenant fit up. There is an existing 10 zone fire alarm panel that is located in the rear of the building in the hallway leading to the second floor office space. The existing panel is monitored by a 24 hour central station.

The space will be fully sprinkled.

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 03/29/16