DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

WASHINGTON AVE PROPERTIES LLC

Located at

522 WASHINGTON AVE

PERMIT ID: 2015-03069

ISSUE DATE: 07/08/2016

CBL: 429 J003001

has permission to Construct an addition and attached landings/stairs to the existing, two- story office

building.

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Laurie Leader

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Building Inspections

Fire Department

office

Use Group: B/S-1

Type: 5B

Occupant load of addition = 33 Building is not sprinkled

ADDITION

MUBEC/IBC 2009

Located at: 522 WASHINGTON AVE **PERMIT ID:** 2015-03069 CBL: 429 J003001

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Site VISIT

Final - DRC

Setbacks and Footings Prior to Pouring

Foundation/Backfill

Close-in Plumbing/Framing w/Fire & Draft Stopping

Above Ceiling Inspection

Electrical Close-in w/Fire & Draftstopping

Final - Fire

Final - Electric

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit			Permit No:	Date Applied For:	CBL:
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-87			2015-03069	12/22/2015	429 J003001
	sed Use:		Project Description:		
Office		Construct an addition and attached landings/stairs to the existing, two- story office building.			
Dep	pt: Zoning Status: Approved w/Conditions Re	eviewer:	Christina Stacey	Approval Da	ite: 05/02/2016
	te: B-2 zone Total office floor area, existing & proposed = 3,112 sf			,	Ok to Issue: 🗹
	nditions:				
1) .	Separate permits shall be required for any new signage.				
	Γhis permit is being approved on the basis of plans submitted. A work.	ny deviati	ons shall require a	separate approval be	efore starting that
4) [This property shall remain an office. Any change of use shall requ	uire a sepa	arate permit applic	ation for review and	approval.
Dep Not		eviewer:	Laurie Leader	Approval Da	te: 07/07/2016 Ok to Issue: ✓
Cor	nditions:				
I	Separate permits are required for any electrical, plumbing, sprink pellet/wood stoves, commercial hood exhaust systems, fire supprapproval as a part of this process.				
-	This permit is approved based upon information provided by the approved plans requires separate review and approval prior to wo		or design profession	onal. Any deviation f	rom the final
Dep	ot: Engineering DPS Status: Not Applicable Re	eviewer:		Approval Da	ite: 12/24/2015
Not	te:			1	Ok to Issue: 🗹
	nditions:				
(Γhis approval is non-applicable to Engineering DPS as it relates to Grease Program. If approval is needed for this project by the EngFOG, please contact David Margolis-Pineo at 207-874-8850 or d	gineering ?	Department of Pub		
Dep	ot: Fire Status: Approved w/Conditions Re	eviewer:	Craig Messinger	Approval Da	nte: 02/10/2016
Not	te:				Ok to Issue: 🗹
	nditions:				
	Emergency lights and exit signs are required. Emergency lights a circuit and on the same circuit as the lighting for the area they ser		gns are required to	be labeled in relation	n to the panel and
2) \$	Shall comply with NFPA 101, Chapter 38, New Business Occupa	ancies.			
3) 1	All outstanding code violations shall be corrected prior to final in	spection.			
4) 1	All construction shall comply with City Code Chapter 10.				
5) \$	Shall meet the requirements of 2009 NFPA 1 Fire Code.				
Der	ot: DRC Status: Approved w/Conditions Re	eviewer:	Philip DiPierro	Approval Da	nte: 05/26/2016
Not	·		r = 10110		Ok to Issue:
	nditions:				
1) 5	See site plan approval letter dated April 28, 2016 (site plan appro	ved on A	oril 28, 2016) for c	conditions of approva	a1.