

CITY OF PORTLAND  
 FIRE PREVENTION BUREAU  
 380 Congress Street, Portland, Maine 04101  
 fireprevention@portlandmaine.gov  
 (207) 874-8400

**NOTICE OF VIOLATION AND ORDER TO CORRECT**

August 7, 2017

<b>Responsible Party 1:</b> BEAULIEU LORI A 140 WOODLANDS DR FALMOUTH, ME 04105		
<b>Location</b> 41 BATES ST	<b>CBL</b> 429 J010001	<b>Inspection Date</b> 7/13/2017
<b>Inspector</b> Mark Stewart	<b>Inspection Type</b> FP Routine Inspection Commerci	<b>Status</b> Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

**You must send this form to the Fire Prevention Bureau no later than 8/30/2017.**

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
<b>1-14.14 ILLUMINATION OF EXIT SIGNS;</b> EXIT SIGNS SHALL BE CONTINUOUSLY ILLUMINATED AND USE AN EMERGENCY LIGHTING SOURCE. Multiple illuminated Exit Signs were not functioning throughtout building.	
<b>1-4.5.8 MAINTENANCE, INSPECTION, AND TESTING;</b> WHENEVER OR WHEREVER ANY DEVICE, EQUIPMENT, SYSTEM, CONDITION, ARRANGEMENT, LEVEL OF PROTECTION, FIRE-RESISTIVE CONSTRUCTION, OR ANY OTHER FEATURE IS REQUIRED FOR COMPLIANCE WITH THE PROVISIONS OF THIS CODE, SUCH DEVICE, EQUIPMENT, SYSTEM, CONDITION, ARRANGEMENT, LEVEL OF PROTECTION, FIRE-RESISTIVE CONSTRUCTION, OR OTHER FEATURE SHALL THEREAFTER BE CONTINUOUSLY MAINTAINED. Horn/Strobe fixture pulled out of wall second floor, left side office.	
<b>NFPA 101- 7.10.1.1 EXITS CLEARLY VISIBLE OR CONSPICUOUSLY INDICATED;</b> Where Required: Means of egress shall be marked in accordance with section 7.10 where required in Chapters 11 through 43. Exit to rear stairs from right side second floor offices needs signage.	
<b>NFPA 1- 18.2.2.1 FIRE DEPARTMENT KNOX BOX REQ;</b> The AHJ shall have the authority to require an access box(es) to be installed in an accessible location where access to or within a structure or area is difficult because of security. The access box(es) shall be of an approved type listed in accordance with UL 1037. Properties with fire alarm systems and fire supression systems require Knox access. Knox Box needed.	

Violation	Proposed Date of Completion
<b>NFPA 10- 7.1.1 FIRE EXTINGUISHERS NEED ANNUAL SERVICE;</b> The owner or designated agent or occupant of a property in which fire extinguishers are located shall be responsible for inspection, maintenance, and recharging. Extinguisher in left side basement office needs inspection.	
<b>NFPA 101-7.9 EMERGENCY LIGHTING</b> Emergency light in basemnet rear hallway not working.	
<b>NFPA 1- 19.1.2 INSIDE STORAGE NOT ORDERLY;</b> Persons owning or having control of any property shall not allow any combustible waste material to accumulate in any area or in any manner that creates a fire hazard to life or property. Storage in boiler room needs to be cleaned up.	
<b>NFPA 54- 9.6.4 UTILITY DISCONNECTS BLOCKED;</b> Each appliance connected to a piping system shall have an accessible, approved manual shutoff valve with a nondisplaceable valve member, or a listed gas convenience outlet. Appliance shutoff valves and convenience outlets shall serve a single appliance only and shall be installed in accordance with 9.6.4.1. Electrical panel in boiler room obstructed.	
<b>FINAL DATE OF COMPLETED VIOLATION(S)</b>	___ / ___ / ___
<b>FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)</b>	___ / ___ / ___

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

**VIOLATOR CERTIFICATION**

*I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.*

*I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.*

*If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.*

\_\_\_\_\_  
Date

\_\_\_\_\_  
Responsible Party

\_\_\_\_\_  
Date

\_\_\_\_\_  
Responsible Party

**SEEN AND AGREED**

\_\_\_\_\_  
Date

\_\_\_\_\_  
Fire Prevention Bureau