

CITY OF PORTLAND  
 FIRE PREVENTION BUREAU  
 380 Congress Street, Portland, Maine 04101  
 fireprevention@portlandmaine.gov  
 (207) 874-8400

**NOTICE OF VIOLATION AND ORDER TO CORRECT**

January 4, 2017

<b>Responsible Party 1:</b> HJCJ INC 501 WASHINGTON AVE PORTLAND , ME 04103		
<b>Location</b> 501 WASHINGTON AVE	<b>CBL</b> 429 H047001	<b>Inspection Date</b> 12/22/2016
<b>Inspector</b> David Petruccelli	<b>Inspection Type</b> FP Routine Inspection	<b>Status</b> Follow up Required

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must complete the proposed date of completion column by proposing a reasonable timeframe to remedy each violation. This form must be received by the Fire Prevention Bureau no later than 1/30/2017. The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

**YOUR FAILURE TO SUBMIT A PLAN OF ACTION BY THE DATE PROVIDED, OR TO CORRECT ANY VIOLATION WITHIN THE APPLICABLE TIME FRAME, MAY RESULT IN LEGAL ACTION AGAINST YOU, THE IMPOSITION OF CIVIL PENALTIES, AND THE PURSUIT OF OTHER LEGAL REMEDIES.**

<b>Violation</b>	<b>Proposed Date of Completion</b>
<b>NFPA 101- 37.3.2.1 PROTECTION OF HAZARDS (COMBINED MERCANTILE AND PARKING STRUCTURES);</b> Hazardous areas shall be protected in accordance with 37.3.2.1.1 or 37.3.2.1.2. Section noted applies to Mercantile occupancies. Door rating shall be minimum 3/4 of an hour.	

**VIOLATOR CERTIFICATION**

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau’s discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

\_\_\_\_\_ Date

\_\_\_\_\_ Responsible Party

\_\_\_\_\_ Date

\_\_\_\_\_ Responsible Party

**SEEN AND AGREED**

\_\_\_\_\_ Date

\_\_\_\_\_ Fire Prevention Bureau