



Department of Permitting and Inspections

Ann Machado
Zoning Administrator

NFPA LIFE SAFETY CODE – FIRE PREVENTION CODE DWELLING UNIT COMPLIANCE

Section 14-391 of the Land Use Ordinance allows illegal non-conforming dwelling units to become legalized through a given process. Part of this process is that the dwelling units that are requested to be legalized MUST comply, or be able to comply, with the NFPA Life Safety Code – Fire Prevention Code, PRIOR to issuing the requested permit.

Please return this form to the Zoning Administrator as to compliance or the ability to comply with these codes.

Location: 144 Veranda St - CBL 432 A002

Owner: Aymen Korika

Address of owner: same

(If different)

Applicant Information: _____

(If different):

Current number of legal units: 2

Number of units to be legalized: 1, for a total of 3 DU's in the building

Comments of approval or disapproval (List any and all conditions):

fire doors required from units to shared egress (6 req);
CO alarms req each unit & basement, blanks req in elec. panels;
wires shall terminate in a box, discontinued to be removed;
boiler protection required for fuel fired devices

Signature: [Handwritten Signature]

Date: October 17, 2016