


COMMENTS

5/10/02 - Deck finished - need handrails - owner putting them on while there. (Thought Guard was handrail. OK. Tom M)

Close out

permit # 000475
ABL # 432-J-3



Inspection Record

Type	Date
Foundation: _____	_____
Framing: _____	_____
Plumbing: _____	_____
Final: _____	_____
Other: _____	_____

ELECTRICAL PERMIT

City of Portland, Me.



To the Chief Electrical Inspector, Portland Maine:
 The undersigned hereby applies for a permit to make electrical installations
 in accordance with the laws of Maine, the City of Portland Electrical Ordinance,
 National Electrical Code and the following specifications:

Date 5/25/01
 Permit # 1537
 CBL# 431-J-003

LOCATION: 12 Dalton St. METER MAKE & # _____
 CMP ACCOUNT # 441-0055091-015 OWNER Gary Creamer
 TENANT Vacant PHONE # 774-6903

							TOTAL EACH FEE		
OUTLETS		Receptacles		Switches		Smoke Detector		.20	
FIXTURES		Incandescent		Fluorescent		Strips		.20	
SERVICES	X	Overhead		Underground		TTL AMPS <800		15.00	
		Overhead		Underground		>800		25.00	
Temporary Service		Overhead		Underground		TTL AMPS		25.00	
								25.00	
METERS		(number of)	<u>3</u>					1.00	<u>3.00</u>
MOTORS		(number of)						2.00	
RESID/COM		Electric units						1.00	
HEATING		oil/gas units		Interior		Exterior		5.00	
APPLIANCES		Ranges		Cook Tops		Wall Ovens		2.00	
		Insta-Hot		Water heaters		Fans		2.00	
		Dryers		Disposals		Dishwasher		2.00	
		Compactors		Spa		Washing Machine		2.00	
MISC. (number of)		Others (denote)						2.00	
		Air Cond/win						3.00	
		Air Cond/cent				Pools		10.00	
		HVAC		EMS		Thermostat		5.00	
		Signs						10.00	
		Alarms/res						5.00	
		Alarms/com						15.00	
		Heavy Duty(CRKT)						2.00	
		Circus/Carnv						25.00	
		Alterations						5.00	
		Fire Repairs						15.00	
		E Lights						1.00	
		E Generators						20.00	
PANELS		Service	<u>2</u>	Remote	<u>1</u>	Main		4.00	<u>12.00</u>
TRANSFORMER		0-25 Kva						5.00	
		25-200 Kva						8.00	
		Over 200 Kva						10.00	
							TOTAL AMOUNT DUE		
							MINIMUM FEE/COMMERCIAL 45.00		
							MINIMUM FEE	<u>35.00</u>	<u>35.00</u>

INSPECTION: Will be ready _____ or will call _____

CONTRACTORS NAME Richard Rodney MASTER LIC. # 16723
 ADDRESS 103 Kennebunk Pond Rd. LIMITED LIC. # _____
 TELEPHONE 499-7164

SIGNATURE OF CONTRACTOR Richard Rodney

ELECTRICAL INSTALLATIONS—

Permit Number _____
 Location _____
 Owner _____
 Date of Permit _____
 Final Inspection _____
 By Inspector _____

INSPECTION: Service _____ by _____
 Service called in _____
 Closing-in _____ by _____

PROGRESS INSPECTIONS: _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____

DATE:	REMARKS:
1-9-01	12' rule for 2 nd fl. outlets, 1 1/4" rule 9-10
2-22-01	left message to call when corrected SKW
	Still 1 1/4" rule adjustments needed SKW

3-12: ~~called & left message on Ans. Mach. asking for~~
~~verification of connections @ all boxes~~
~~between Garage & kitchen~~
 Called & left message asking for Return
 Call. SKW