

CLOJED
KIT - REMOVED - VC

COMPLAINT PROCESSING

Complaint Information:

Address: 54 Olympia
CBL: 433 B021
Case #: 2012-05-3916 332-1168 | Kevin
Reporting Party/# Tenant 712-7175 | Michael
Landlord/Contact/# Michael D D'Amboise 799-1834
Complaint(s): Kevin D'Amboise

Electrical: All units / Fed Pacific,
 + faulty wiring

Smokes: All Bedrooms

Fire Separation: Rear Door 3rd unit ✓

Staircase: 3rd unit

W. Gas Inop: 1st fl. (R) ✓

2 unit: 2 allowed. w/o appeal

Property Information:

Owner/LLC
Address

Michael D D'Amboise
5 Adelbert St.
South Portland, ME
04106

Inspection Information:

Inspection Date
Inspector
Assisting
Units in Bldg
Units Allowed

5/4/12
GF
BL / CPP
3
2

PC. from Kevin D'Amboise

wants to legalize non-conforming
unit

When did this first occur? On Going
How many times? " "
Have you notified LL Yes

Remsp Zoning 6/8/12

650
6763