

. . . Fire Protection by Computer Design

FREEDOM FIRE PROTECTION INC.
209 QUAKER RIDGE ROAD
CASCO, MAINE 04015
207-627-4109

Job Name : NADEAU STOVER RESIDENCE
Building : 23 OREGON STREET
Location : PORTLAND, MAINE 04103
System : #1 AREA #1
Contract :
Data File : Nadeau Stover Residence HC1.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - NADEAU STOVER RESIDENCE Date - 9/24/12
Location - PORTLAND, MAINE 04103
Building - 23 OREGON STREET System No. - #1 AREA #1
Contractor - FREEDOM FIRE PROTECTION Contract No. -
Calculated By - MICHAEL NOBLIT Drawing No. - FP-2
Construction: (X) Combustible () Non-Combustible Ceiling Height VARIES
OCCUPANCY - HOUSE

S Type of Calculation: (X)NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
Y Number of Sprinklers Flowing: ()1 (X)2 ()4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 13 Gpm System Type
Listed Pres. at Start Point - 7 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16' x 16' () Deluge () PreAction
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
S Additional Flow Added - 0 Gpm Make TYCO Model LFII
I Elevation at Highest Outlet - 25'-3"Feet Size 1/2" K-Factor 4.9
G Note: Temperature Rating 155
N

Calculation Gpm Required 26.156 Psi Required 72.520 At Test
Summary C-Factor Used: Overhead 150 Underground 140

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 3/9/2012 Rated Cap. Cap.
T Time of Test - @ Psi Elev.
E Static (Psi) - 101 Elev.
R Residual (Psi) - 0 Other Well
Flow (Gpm) - 1321 Proof Flow Gpm
S Elevation -

P Location:
P
L Source of Information: PORTLAND WATER DISTRICT
Y


Water Supply Curve (C)

FREEDOM FIRE PROTECTION INC.
NADEAU STOVER RESIDENCE

Page 2
Date 9/24/12

City Water Supply:
C1 - Static Pressure : 101
C2 - Residual Pressure: 0
C2 - Residual Flow : 1321

Demand:
D1 - Elevation : 10.936
D2 - System Flow : 26.1561
D2 - System Pressure : 72.520
Hose (Adj City) : _____
Hose (Demand) : _____
D3 - System Demand : 26.1561
Safety Margin : 28.409



Fittings Used Summary

FREEDOM FIRE PROTECTION INC.
NADEAU STOVER RESIDENCE

Page 3
Date 9/24/12

Fitting Legend

| Abbrev. | Name | 1/2 | 3/4 | 1 | 1 1/4 | 1 1/2 | 2 | 2 1/2 | 3 | 3 1/2 | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 |
|---------|--------------------|--|-----|---|-------|-------|----|-------|----|-------|----|----|----|----|----|----|----|----|----|-----|-----|
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 |
| T | 90' Flow Thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 |
| Zaa | Ames 2000B | Fitting generates a Fixed Loss Based on Flow | | | | | | | | | | | | | | | | | | | |

Pressure / Flow Summary - STANDARD

FREEDOM FIRE PROTECTION INC.
 NADEAU STOVER RESIDENCE

Page 4
 Date 9/24/12

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| 101 | 25.25 | 4.9 | 7.0 | na | 12.96 | 0.05 | 256 | 7.0 |
| 18 | 27.25 | | 6.33 | na | | | | |
| 102 | 25.25 | 4.9 | 7.25 | na | 13.19 | 0.05 | 256 | 7.0 |
| 17 | 27.25 | | 6.58 | na | | | | |
| 16 | 27.75 | | 6.58 | na | | | | |
| 15 | 27.75 | | 8.77 | na | | | | |
| 14 | 27.75 | | 10.44 | na | | | | |
| 13 | 22.75 | | 13.78 | na | | | | |
| 12 | 22.75 | | 15.39 | na | | | | |
| 11 | 14.083 | | 21.18 | na | | | | |
| 10 | 14.083 | | 22.61 | na | | | | |
| 9 | 14.083 | | 24.38 | na | | | | |
| 8 | 14.083 | | 27.62 | na | | | | |
| 7 | 4.66 | | 33.19 | na | | | | |
| 6 | 4.66 | | 34.68 | na | | | | |
| 5 | 4.66 | | 38.53 | na | | | | |
| 4 | 4.66 | | 40.13 | na | | | | |
| 3 | 4.66 | | 41.38 | na | | | | |
| 2 | 0.0 | | 48.4 | na | | | | |
| 1 | 0.0 | | 54.41 | na | | | | |
| 0 | 0.0 | | 72.51 | na | | | | |
| TEST | 0.0 | | 72.52 | na | | | | |

The maximum velocity is 19.25 and it occurs in the pipe between nodes 1 and 0

Final Calculations - Hazen-Williams

FREEDOM FIRE PROTECTION INC.
NADEAU STOVER RESIDENCE

Page 5
Date 9/24/12

| Hyd. Ref. Point | Qa Qt | Dia. "C" Pf/Ft | Fitting or Eqv. Ln. | Pipe Ftnng's Total | Pt Pe Pf | Pt Pv Pn | ***** | Notes | ***** |
|-----------------|-------|----------------|---------------------|--------------------|--------------|----------|-------|-----------------|-------|
| 101 to 18 | 12.96 | 1.101 150 | 1E 3.825 | 2.500 3.825 | 7.000 -0.866 | | | K Factor = 4.90 | |
| 18 to 16 | 12.96 | 0.0305 | 0.0 | 6.325 | 0.193 | | | Vel = 4.37 | |
| 18 to 16 | 0.0 | 1.101 150 | 1E 3.825 | 2.000 9.563 | 6.327 -0.217 | | | | |
| | 12.96 | 0.0305 | 0.0 | 15.387 | 0.470 | | | Vel = 4.37 | |
| | 0.0 | | | | | | | | |
| | 12.96 | | | | 6.580 | | | K Factor = 5.05 | |
| 102 to 17 | 13.19 | 1.101 150 | 1E 3.825 | 2.500 3.825 | 7.248 -0.866 | | | K Factor = 4.90 | |
| 17 to 16 | 13.19 | 0.0315 | 0.0 | 6.325 | 0.199 | | | Vel = 4.44 | |
| 17 to 16 | 0.0 | 1.101 150 | 1E 3.825 | 3.000 3.825 | 6.581 -0.217 | | | | |
| | 13.19 | 0.0316 | 0.0 | 6.825 | 0.216 | | | Vel = 4.44 | |
| 16 to 15 | 12.97 | 1.101 150 | 1T 9.563 | 10.000 9.562 | 6.580 0.0 | | | | |
| | 26.16 | 0.1117 | 0.0 | 19.562 | 2.186 | | | Vel = 8.82 | |
| 15 to 14 | 0.0 | 1.101 150 | 3E 11.475 | 3.500 11.475 | 8.766 0.0 | | | | |
| | 26.16 | 0.1118 | 0.0 | 14.975 | 1.674 | | | Vel = 8.82 | |
| 14 to 13 | 0.0 | 1.101 150 | 1E 3.825 | 6.660 3.825 | 10.440 2.166 | | | | |
| | 26.16 | 0.1118 | 0.0 | 10.485 | 1.172 | | | Vel = 8.82 | |
| 13 to 12 | 0.0 | 1.101 150 | 1E 3.825 | 1.000 9.563 | 13.778 0.0 | | | | |
| | 26.16 | 0.1118 | 0.0 | 14.387 | 1.608 | | | Vel = 8.82 | |
| 12 to 11 | 0.0 | 1.101 150 | 1T 9.563 | 8.660 9.562 | 15.386 3.754 | | | | |
| | 26.16 | 0.1118 | 0.0 | 18.222 | 2.037 | | | Vel = 8.82 | |
| 11 to 10 | 0.0 | 1.101 150 | 1T 9.563 | 3.250 9.562 | 21.177 0.0 | | | | |
| | 26.16 | 0.1118 | 0.0 | 12.812 | 1.432 | | | Vel = 8.82 | |
| 10 to 9 | 0.0 | 1.101 150 | 1T 9.563 | 6.250 9.562 | 22.609 0.0 | | | | |
| | 26.16 | 0.1118 | 0.0 | 15.812 | 1.767 | | | Vel = 8.82 | |
| 9 to 8 | 0.0 | 1.101 150 | 1E 3.825 | 15.660 9.563 | 24.376 0.0 | | | | |
| | 26.16 | 0.1118 | 0.0 | 29.047 | 3.247 | | | Vel = 8.82 | |
| 8 to 7 | 0.0 | 1.101 150 | 1E 3.825 | 9.500 3.825 | 27.623 4.081 | | | | |
| | 26.16 | 0.1118 | 0.0 | 13.325 | 1.490 | | | Vel = 8.82 | |
| 7 to 6 | 0.0 | 1.049 150 | 1E 3.022 | 7.500 3.022 | 33.194 0.0 | | | | |
| | 26.16 | 0.1415 | 0.0 | 10.522 | 1.489 | | | Vel = 9.71 | |

| Hyd. Ref. Point | Qa Qt | Dia. "C" Pf/Ft | Fitting or Eqv. Ln. | Pipe Ftng's Total | Pt Pe Pf | Pt Pv Pn | ***** | Notes | ***** |
|-----------------------|----------|----------------------|---------------------------|-------------------------|----------------|----------------|------------------|-------|-------|
| 6 | 0.0 | 1.049 | 3E 6.0 | 12.000 | 34.683 | | | | |
| to | | 120 | 0.0 | 6.000 | 0.0 | | | | |
| 5 | 26.16 | 0.2138 | 0.0 | 18.000 | 3.848 | | Vel = 9.71 | | |
| 5 | 0.0 | 1.049 | 1E 2.0 | 5.500 | 38.531 | | | | |
| to | | 120 | 0.0 | 2.000 | 0.0 | | | | |
| 4 | 26.16 | 0.2137 | 0.0 | 7.500 | 1.603 | | Vel = 9.71 | | |
| 4 | 0.0 | 1.049 | 1T 5.0 | 0.830 | 40.134 | | | | |
| to | | 120 | 0.0 | 5.000 | 0.0 | | | | |
| 3 | 26.16 | 0.2139 | 0.0 | 5.830 | 1.247 | | Vel = 9.71 | | |
| 3 | 0.0 | 1.049 | 1Zaa 0.0 | 4.660 | 41.381 | | | | |
| to | | 120 | 0.0 | 0.0 | 6.018 | | * Fixed loss = 4 | | |
| 2 | 26.16 | 0.2137 | 0.0 | 4.660 | 0.996 | | Vel = 9.71 | | |
| 2 | 0.0 | 1.125 | 0.0 | 20.000 | 48.395 | | | | |
| to | | 150 | 0.0 | 0.0 | 4.000 | | * Fixed loss = 4 | | |
| 1 | 26.16 | 0.1006 | 0.0 | 20.000 | 2.013 | | Vel = 8.44 | | |
| 1 | 0.0 | 0.745 | 0.0 | 17.750 | 54.408 | | | | |
| to | | 140 | 0.0 | 0.0 | 3.000 | | * Fixed loss = 3 | | |
| 0 | 26.16 | 0.8509 | 0.0 | 17.750 | 15.104 | | Vel = 19.25 | | |
| 0 | 0.0 | 6.16 | 0.0 | 250.000 | 72.512 | | | | |
| to | | 140 | 0.0 | 0.0 | 0.0 | | | | |
| TEST | 26.16 | 0.0 | 0.0 | 250.000 | 0.008 | | Vel = 0.28 | | |
| | 0.0 | | | | | | | | |
| | 26.16 | | | | 72.520 | | K Factor = 3.07 | | |