



D1

THIRD LEVEL FLOOR PLAN

1/8" = 1'-0"

1441 Ford Street, P.O. Box 618
Portland, Maine 04106
Tel: (207) 775-0000
www.smart-inc.com

ARCHITECTURE
ENGINEERING
PLANNING
INTERIOR DESIGN
COMMISSIONING

SMART

MARTIN'S POINT HEALTH CARE
MEDICAL OFFICE BUILDING
PORTLAND, MAINE

THIRD LEVEL: MEDICAL OFFICES
FIRE PROTECTION PLAN

AS NOTED
DATE: 07/13/2009
PROJECT NUMBER: 101005
DESIGNER: S.M.A.R.T. INC.
SCALE: 1/8" = 1'-0"
SHEET NO.: FP103 OF 103

DATE: 07/13/2009
PROJECT NUMBER: 101005
DESIGNER: S.M.A.R.T. INC.
SCALE: 1/8" = 1'-0"
SHEET NO.: FP103 OF 103

ISSUED FOR G.M.P. & PERMITTING
4-3-09

PROJECT ISSUE STATUS:
CURRENT ISSUE STATUS:
PROJECT NUMBER: 101005
PROJECT NAME: MARTIN'S POINT HEALTH CARE
PROJECT LOCATION: PORTLAND, MAINE

NOTES:

1. SEE SHEET D001 FOR PROJECT GENERAL NOTES.
2. SEE SHEET D001 FOR FIRE PROTECTION LEGEND AND ABBREVIATIONS.
3. TAKE NOTE OF SPILLAGE LOCATIONS ON ARCHITECTURAL DRAWINGS. PROVIDE SEVERAL COVERAGE WITHIN CEILING ACCESSIBLE AREAS AND 3' CLEARANCE FROM WALLS AND PARTITIONS.
4. PROVIDE SEVERAL COVERAGE WITHIN CEILING ACCESSIBLE AREAS AND 3' CLEARANCE FROM WALLS AND PARTITIONS.
5. PROVIDE SEVERAL COVERAGE WITHIN CEILING ACCESSIBLE AREAS AND 3' CLEARANCE FROM WALLS AND PARTITIONS.
6. PROVIDE SEVERAL COVERAGE WITHIN CEILING ACCESSIBLE AREAS AND 3' CLEARANCE FROM WALLS AND PARTITIONS.

KEYED NOTES:

1. 1" FIRE DEPARTMENT CONNECTION FOR MANUAL DRY STAND PIPE SYSTEM. PROVIDE CHECK VALVE BETWEEN DRY AND STANDPIPE.
2. 1" FIRE DEPARTMENT CONNECTION FOR SPRINKLER SYSTEM.
3. 1" FIRE DEPARTMENT VALVE. TURN DRY 116 AWAY FROM WALL TO ALLOW GREATER ACCESS TO THREATS TO FIRE DEPARTMENT.
4. CLEAN AGENT FIRE SUPPRESSION SYSTEM.

SPRINKLER HEAD TYPES: REFER TO 1900 SERIES SPECIFICATIONS FOR SPRINKLER HEAD TYPES FOR EACH SPECIFIC LOCATION.
PROVIDE SHAW-WALSH OR ENGINEER APPROVED FLEXIBLE CONNECTOR WHERE PIPES PASS EXPANSION JOINT.

PROGRESS PRINT