



D1 THIRD LEVEL ENLARGED PARTIAL FLOOR PLAN - AREA A
1/4" = 1'-0"

ARCHITECTURE
ENGINEERING
PLANNING
INTERIOR DESIGN
COMMISSIONING

SMRI
MEDICAL OFFICE BUILDING
PORTLAND, MAINE

THIRD LEVEL: MEDICAL OFFICES
ENLARGED PARTIAL POWER FLOOR PLAN - AREA A

ISSUED FOR G.M.P. & PERMITTING
4-3-09

PROJECT MONTH: []
CURRENT ISSUE STATUS: []

KEY PLAN

A15 N.T.S.

145 State Street, 9th Fl., Portland, Maine 04104
Tel: (207) 775-3846
Fax: (207) 775-0100
www.smri.com

REV.	DESCRIPTION	DATE

AS NOTED DATE: []
PROJECT MANAGER: [] SLB GRAPHIC SCALE: 0' 1'
JOB SUPERVISOR: [] TONCOS
DATE OF RECORD: [] DIT SHEET NO.: EP103A
SMF CODE: EP103A-0819 0819 PROJECT NO. []

KEYED NOTES:

1. SEE GRID FOR PROJECT GENERAL NOTES
2. SEE SHEET 0401 FOR LEGEND AND GENERAL NOTES.
3. MOUNT RECEIPTS 4" AFF TO CENTER OF DEVICE.
4. PROVIDE ELECTRICAL CONNECTION TO CANNY DRAIN AREA TRAPE PROVIDED BY PLUMBING CONTRACTOR. COORDINATE ALL WORK WITH PLUMBING CONTRACTOR.
5. PROVIDE FOUR COMPARTMENT CORD-IN-PLACE FLOORBOX WITH 1" EMPTY COUPLER WITH FULL STRING FOR TELECOMMUNICATIONS WIRING TO PROVIDE AN ACCESSIBLE CEILING FLOORBOX DEPENDENT ON FLOORING. PROVIDE TWO PORT RECEIPTS AND BULKHEADS FOR TELECOMMUNICATIONS DEVICES.
6. PROVIDE 1/2" CONNECTION TO MOTORIZED DOOR OPERATOR UNIT. PROVIDE ROOM IN FOR EQUIPMENT INSTALLATION.
7. PROVIDE AND INSTALL ALL NECESSARY ELECTRICAL CONNECTIONS AS INDICATED. COORDINATE W/ AND COMPUTER EQUIPMENT. WIRING SHALL BE 4" TO 4" MIN. #1600 FOR FUTURE CONNECTION FLEXIBILITY.