

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 10-1244	Issue Date:	CBL: 434 C005001
-----------------------	-------------	---------------------

Location of Construction: 331 Veranda St	Owner Name: Martin's Point Health Care Inc	Owner Address: 331 Veranda St	Phone:
Business Name: Martin's Point Health Care Inc	Contractor Name: Sprinkler System, Inc	Contractor Address: P.O. Box 1285 Lewiston	Phone 2077820104
Lessee/Buyer's Name	Phone:	Permit Type: Sprinkler Systems	Zone: R-F

Past Use: Commercial / Martin's Point Health Care Inc.	Proposed Use: Commercial / Martin's Point Health Care Inc.: Install Sprinkler System.	Permit Fee: \$340.00	Cost of Work: \$32,000.00	CEO District: 4
Proposed Project Description: Install Sprinkler System.		FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied <i>*See Conditions</i>	INSPECTION: Use Group: Type:	
		Signature: <i>(KG)</i>	Signature:	
PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)				
Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied				
Signature: Date:				

Permit Taken By: gg	Date Applied For: 10/05/2010	Zoning Approval		
------------------------	---------------------------------	------------------------	--	--

<ol style="list-style-type: none"> This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules. Building permits do not include plumbing, septic or electrical work. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.. 	Special Zone or Reviews <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/> Date: <i>10/8/10</i>	Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date:	Historic Preservation <input type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied <i>OLD Hospital Bldg's ALandmark Bldg</i> Date:
---	--	---	--

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE

MAIL PERMIT TO:

SPRINKLER SYSTEMS INC
PO BOX 1205
LEWISTON, ME 04240



Water-Based Fire Suppression System Permit

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

Installation address: 331 Veranda Street CBL: 434 C005

Exact location: (within structure) Entire Building

Type of occupancy(s) (NFPA & ICC): Office and Automobile Parking

Building owner: Martin's Point Health Care

Managing Supervisor (RMS): Clayton Saucier License No: 442

Supervisor phone: 782-0104 E-mail: Clayton@SprinklerSystemsInc.com

Installing contractor: Sprinkler Systems, Inc. License No: 093

Contractor phone: 782-0104 E-mail: _____

The suppression work to be done will be: New: Renovation: Addition to existing system:

This is an amendment to an existing permit: Yes: NO: Permit no: _____

NFPA Standard this system is designed to: 13 Edition: 2007

*Non-NFPA systems are not approved for use within the City of Portland.

Download a new copy of this document from www.portlandmaine.gov/fire for every submittal. Attach all working documents and complete approved submittals as may be required by the State Fire Marshal's Office on electronic PDF's in addition to full sized plans.

Contractor shall verify location and type of all FDCs shall be approved in writing by the Fire Prevention Bureau.

COST OF WORK: 32,000
PERMIT FEE: 340.00
(\$10 PER \$1,000 + \$30 FOR THE FIRST \$1,000)

Submit all information to the Building Inspections Department, 389 Congress Street, Room 315, Portland, Maine 04101.

Prior to acceptance of any fire protection system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided.

All installation(s) must comply with NFPA and the Fire Department Technical Standard(s).

Applicant signature: *Michael Lahey* Date: 10/9/10

Sprinkler Systems, Inc.

P.O. Box 1285

Lewiston, Maine 04243-1285

Ph. (207) 782-0104 Fax (207) 783-4865

Fire Protection Professionals Since 1973

October 4, 2010

Pizzagalli Construction
131 Presumpscot Street
Portland, ME 04103


Re: Martin's Point

Gentlemen:

This letter is to certify that the sprinkler system in the aforementioned location is active and is designed and installed in accordance with NFPA #13 and all other state and local codes.

If there are any questions or concerns please do not hesitate to call.

Very truly yours,
Sprinkler Systems, Inc.



Michael Lahey
General Manager

Sprinkler Systems, Inc.

Contractor's Material & Test Certificate for Aboveground Pipe

Procedure

Upon completion of work, inspection and tests shall be made by the contractor's representative and witnessed by an owner's representative. All defects shall be corrected and system left in service before contractor's personnel finally leave the job.

A certificate shall be filled out and signed by both representatives. Copies shall be prepared for approving authorities, owners, and contractor. It is understood the owner's representative signature in no way prejudices any claim against contractor for faulty material, poor workmanship, or failure to comply with approving authority's requirements or local ordinances.

Property Name **Martin's Point Health Care - Medical Office Building** Date **6/24/10**

Property Address **331 Veranda Drive, Portland, Maine**

Plans
 Accepted by approving authorities (Names) **Maine State Fire Marshals Office**
 Address **52 State House Station Augusta, Maine 04333-0052**
 Installation conforms to accepted plans Yes No
 Equipment used is approved, if no, explain deviations Yes No

Instructions
 Has person in charge of fire equipment been instructed as to location of control valve and care and maintenance of this new equipment? Yes No
 If no, explain:
 Have copies of the following been left on the premises?
 1. System components instructions Yes No
 2. Care and maintenance instructions Yes No
 3. NFPA 25 Yes No

Location of System
 Supplies Area: **Level 1 - Parking / Level 2 - Parking**

Sprinklers	Make	Model	Year of Mfg.	Orifice Size	Quantity	Temp Rating
	Globe	GL5615	2010	1/2"	334	200°F.
	Globe	GL5635	2010	1/2"	2	200°F.
	Globe	GL5626	2010	1/2"	2	200°F.

Pipe and Fittings
 Type of pipe **As Per N.F.P.A.-13** Type of fittings **As Per N.F.P.A.-13**

Alarm Valve or Flow Indicator
NA
 Alarm Device
 Maximum time to operate through te. connection
 Type Make Model Min Sec

Dry Pipe Operating Test
 Dry Valve QOD
 Make Model Serial # Make Model Serial #
 Time to trip through test connection Water Pressure Air Pressure Trip Point Air Pressure Time Water Reached Test Outlet Alarm Operated Properly
 With QOD MIN SEC PSI PSI PSI MIN SEC YES NO
 W/O QOD MIN SEC PSI PSI PSI MIN SEC YES NO

If no explain:

Deluge & Preaction Valve NA	Operation: <i>Circle One</i> Pneumatic Electric Hydraulic		Piping Supervised Yes No		Detectin Media Supervised Yes No		
	Does valve operate from the manual trip, remote, or both control stations?					Yes	No
	Is there an accessible facility in each circuit for testing? If no, explain.					Yes	No
	Make	Model	Does each circuit operate supervision loss alarm?		Does each circuit operate valve release?		Maximum time to operate release
			Yes	No	Yes	No	Min ____ Sec ____
Pressure Reducing Valve NA	Location & Floor	Make & Model	Setting	Static Pressure <i>Inlet</i> (psi) <i>Outlet</i> (psi)		Residual Pressure <i>Inlet</i> (psi) <i>Outlet</i> (psi)	Flow Rate Flow (gpm)
Test Description	<p>HYDROSTATIC: Hydrostatic tests shall be made at not less than 200 psi (13.6 bars for 2 hours or 50 psi (3.4 bars) above static pressure in excess of 150 psi (10.2 bars) for 2 hours. Differential dry-pipe valve clappers shall be left open during the test to prevent damage. All aboveground piping leakage shall be stopped.</p> <p>PNEUMATIC: Establish 40 psi (2.7 bars) air pressure and drop, which will not exceed 1 1/2 psi (.01 bars) in 24 hours. Test pressure tanks at normal water level and air pressure and measure air pressure drop, which shall not exceed 1 1/2 psi (.01 bars) in 24 hours.</p>						
Tests	All piping hydrostatically tested at <u>200</u> psi (____ bars) for <u>2</u> hours					If no, state reason:	
	Dry piping pneumatically tested (<i>check one</i>) NA <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/>						
	Equipment operates properly (<i>check one</i>) Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>						
Do you certify as the sprinkler contractor that additives and corrosive chemicals, sodium silicate or derivatives or sodium silicate, brine, or other corrosive chemicals were not used for testing systems or stopping leaks?					Check one: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
Drain Test: Reading of gauge located near water supply test connection: _____ psi (____ bars)					Residual pressure with valve in test connection open wide: _____ psi (____ bars)		
Hydraulic Data Nameplate <input type="checkbox"/>	Nameplate provided: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		If no, explain:				
Remarks	Date left in service with all control valves open:						
Signatures	Sprinkler Contractor: Sprinkler Systems, Inc. P.O. Box 1285 Lewiston, Maine 04243-1285 Phone: 207-782-0104 Fax: 207-783-4865						
	Property Owner Signature		Title		Date		
	<i>Victor Dumcan</i>		PCC Intern		6/24/10		
Sprinkler Contractor Signature		Title		Date			
<i>[Signature]</i>		FORMAN		6/24/10			

Additional Explanations and Notes:

09032

Sprinkler Systems, Inc.

Contractor's Material & Test Certificate for Aboveground Pipe

Procedure
 Upon completion of work, inspection and tests shall be made by the contractor's representative and witnessed by an owner's representative. All defects shall be corrected and system left in service before contractor's personnel finally leave the job.

A certificate shall be filled out and signed by both representatives. Copies shall be prepared for approving authorities, owners, and contractor. It is understood the owner's representative signature in no way prejudices any claim against contractor for faulty material, poor workmanship, or failure to comply with approving authority's requirements or local ordinances.

Property Name **Date** 6/8/10
 Martin's Point Health Care - Medical Office Building

Property Address
 331 Veranda Drive, Portland, Maine

Plans
 Accepted by approving authorities (Names) Maine State Fire Marshals Office
 Address 52 State House Station Augusta, Maine 04333-0052
 Installation conforms to accepted plans Yes No
 Equipment used is approved, if no, explain deviations Yes No

Instructions
 Has person in charge of fire equipment been instructed as to location of control valve and care and maintenance of this new equipment? Yes No
 If no, explain:

Have copies of the following been left on the premises?
 1. System components instructions Yes No
 2. Care and maintenance instructions Yes No
 3. NFPA 25 Yes No

Location of System
 Supplies Buildings: 3rd Level Medical Office - West Side

Sprinklers	Make	Model	Year of Mfg.	Orifice Size	Quantity	Temp Rating
	Globe	GL5601	2010	1/2"	214	155 DEG.
Globe	GL5606	2010	1/2"	32	155 DEG.	
Globe	GL5615	2010	1/2"	2	200 DEG.	
Globe	GL5626	2010	1/2"	6	200 DEG.	

Pipe and Fittings
 Type of pipe: As Per N.F.P.A.-13 Type of fittings: As Per N.F.P.A.-13

Alarm Valve or Flow Indicator	Alarm Device			Maximum time to operate through test connection	
	Type	Make	Model	Min	Sec
	Flow Switch	Potter	VSR-F		

Dry Pipe Operating Test	Dry Valve			QOD		
	Make	Model	Serial #	Make	Model	Serial #
	Time to trip through test connection	Water Pressure	Air Pressure	Trip Point Air Pressure	Time Water Reached Test Outlet	Alarm Operated Properly
	With QOD	MIN SEC	PSI	PSI	PSI	MIN SEC
W/O QOD	MIN SEC	PSI	PSI	PSI	MIN SEC	
If no, explain:						

NA

Deluge & Preaction Valve NA	Operation: <i>Circle One:</i> Pneumatic Electric Hydraulic		Piping Supervised Yes No		Detecting Media Supervised Yes No			
	Does valve operate from the manual trip, remote, or both control stations?					Yes	No	
	Is there an accessible facility in each circuit for testing? If no, explain.					Yes	No	
	Make	Model	Does each circuit operate supervision loss alarm?		Does each circuit operate valve release?		Maximum time to operate release	
			Yes	No	Yes	No	Min ____ Sec ____	
Pressure Reducing Valve NA	Location & Floor	Make & Model	Setting	Static Pressure Inlet (psi) Outlet (psi)		Residual Pressure Inlet (psi) Outlet (psi)		Flow Rate Flow (gpm)
Test Description	<p>HYDROSTATIC: Hydrostatic tests shall be made at not less than 200 psi (13.6 bars for 2 hours or 50 psi (3.4 bars) above static pressure in excess of 150 psi (10.2 bars) for 2 hours. Differential dry-pipe valve clappers shall be left open during the test to prevent damage. All aboveground piping leakage shall be stopped.</p> <p>PNEUMATIC: Establish 40 psi (2.7 bars) air pressure and drop, which will not exceed 1 1/2 psi (.01 bars) in 24 hours. Test pressure tanks at normal water level and air pressure and measure air pressure drop, which shall not exceed 1 1/2 psi (.01 bars) in 24 hours.</p>							
Tests	All piping hydrostatically tested at 200 psi (____ bars) for 2 hours					If no, state reason:		
	Dry piping pneumatically tested (check one) NA <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/>							
	Equipment operates properly (check one) Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>							
	Do you certify as the sprinkler contractor that additives and corrosive chemicals, sodium silicate or derivatives or sodium silicate, brine, or other corrosive chemicals were not used for testing systems or stopping leaks?					Check one: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
	Drain Test: Reading of gauge located near water supply test connection: _____ psi (____ bars)					Residual pressure with valve in test connection open wide: _____ psi (____ bars)		
Hydraulic Data Nameplate <input type="checkbox"/>	Nameplate provided: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		If no, explain:					
Remarks	Date left in service with all control valves open:							
Signatures	Sprinkler Contractor: Sprinkler Systems, Inc. P.O. Box 1285 Lewiston, Maine 04243-1285 Phone: 207-782-0104 Fax: 207-783-4865							
	Property Owner Signature		Title		Date			
	Nick Duncan		PCC Intern		6/8/10			
Sprinkler Contractor Signature		Title		Date				
[Signature]		FORMAN		6/8/10				

Additional Explanations and Notes:

Sprinkler Systems, Inc.

Contractor's Material & Test Certificate for Aboveground Pipe

Procedure

Upon completion of work, inspection and tests shall be made by the contractor's representative and witnessed by an owner's representative. All defects shall be corrected and system left in service before contractor's personnel finally leave the job.

A certificate shall be filled out and signed by both representatives. Copies shall be prepared for approving authorities, owners, and contractor. It is understood the owner's representative signature in no way prejudices any claim against contractor for faulty material, poor workmanship, or failure to comply with approving authority's requirements or local ordinances.

Property Name

Martin's Point Health Care – Medical Office Building

Date 7/8/10

Property Address

331 Veranda Drive, Portland, Maine

Plans

Accepted by approving authorities (Names) Maine State Fire Marshals Office

Address 52 State House Station Augusta, Maine 04333-0052

Installation conforms to accepted plans

Yes No

Equipment used is approved, if no, explain deviations

Yes No

Instructions

Has person in charge of fire equipment been instructed as to location of control valve and care and maintenance of this new equipment?

Yes No

If no, explain:

Have copies of the following been left on the premises?

1. System components instructions
2. Care and maintenance instructions
3. NFPA 25

Yes No

Yes No

Yes No

Location of System

Supplies Buildings: 4th Level Mechanical

Sprinklers

Make	Model	Year of Mfg.	Orifice Size	Quantity	Temp Rating
Globe	GL5615	2010	1/2"	16	155 DEG.

Pipe and Fittings

Type of pipe

As Per N.F.P.A.-13

Type of fittings

As Per N.F.P.A.-13

Alarm Valve or Flow Indicator

Alarm Device

Maximum time to operate through test connection

Type	Make	Model	Min	Sec
Flow Switch	Potter	VSR-F		

Dry Pipe Operating Test

NA

Dry Valve				QOD		
Make	Model	Serial #	Make	Model	Serial #	
Time to trip through test connection	Water Pressure	Air Pressure	Trip Point Air Pressure	Time Water Reached Test Outlet	Alarm Operated Properly	
With QOD	MIN SEC	PSI	PSI	PSI	MIN SEC	
W/O QOD	MIN SEC	PSI	PSI	MIN SEC	YES NO	
					YES NO	

If no, explain:

Deluge & Preaction Valve NA	Operation: <i>Circle One:</i> Pneumatic Electric Hydraulic		Piping Supervised Yes No		Detecting Media Supervised		Yes No				
	Does valve operate from the manual trip, remote, or both control stations?							Yes	No		
	Is there an accessible facility in each circuit for testing? If no, explain.							Yes	No		
	Make	Model	Does each circuit operate supervision loss alarm?		Does each circuit operate valve release?		Maximum time to operate release				
			Yes	No	Yes	No	Min	Sec			
Pressure Reducing Valve NA	Location & Floor		Make & Model		Setting	Static Pressure Inlet (psi) Outlet (psi)		Residual Pressure Inlet (psi) Outlet (psi)		Flow Rate Flow (gpm)	
Test Description	<p>HYDROSTATIC: Hydrostatic tests shall be made at not less than 200 psi (13.6 bars for 2 hours or 50 psi (3.4 bars) above static pressure in excess of 150 psi (10.2 bars) for 2 hours. Differential dry-pipe valve clappers shall be left open during the test to prevent damage. All aboveground piping leakage shall be stopped.</p> <p>PNEUMATIC: Establish 40 psi (2.7 bars) air pressure and drop, which will not exceed 1 1/2 psi (.01 bars) in 24 hours. Test pressure tanks at normal water level and air pressure and measure air pressure drop, which shall not exceed 1 1/2 psi (.01 bars) in 24 hours.</p>										
Tests	All piping hydrostatically tested at <u>200</u> psi (<u> </u> bars) for <u>2</u> hours							If no, state reason:			
	Dry piping pneumatically tested (check one) NA <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/>										
	Equipment operates properly (check one) Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>										
Do you certify as the sprinkler contractor that additives and corrosive chemicals, sodium silicate or derivatives or sodium silicate, brine, or other corrosive chemicals were not used for testing systems or stopping leaks?							Check one: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>				
Drain Test: Reading of gauge located near water supply test connection: <u> </u> psi (<u> </u> bars)							Residual pressure with valve in test connection open wide: <u> </u> psi (<u> </u> bars)				
Hydraulic Data Nameplate <input type="checkbox"/>	Nameplate provided: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>				If no, explain:						
Remarks	Date left in service with all control valves open:										
Signatures	Sprinkler Contractor: Sprinkler Systems, Inc. P.O. Box 1285 Lewiston, Maine 04243-1285 Phone: 207-782-0104 Fax: 207-783-4865										
	Property Owner Signature					Title			Date		
	<i>John A. Bell</i>					SP Engineer			7/8/10		
Sprinkler Contractor Signature					Title			Date			
<i>[Signature]</i>					FORMAN						

Additional Explanations and Notes:

Sprinkler Systems, Inc.

P.O. Box 1285

Lewiston, ME 04243-1285

TO: Building Inspections Dept.
389 Congress Street
Portland, Maine 04101

Letter of Transmittal

DATE	4 October 2010	JOB #	09032
ATTENTION:			
RE: Martin's Point Health Care Medical Office Building			

WE ARE SENDING YOU:

- Attached Under separate cover via _____ the following items:
- Shop drawings Prints Plans Samples Specifications Wavier or Liens
- Copy of letter Change order Signed Contracts _____

COPIES	DATE	NO.	DESCRIPTION
2			Shop Drawings – Fire Sprinklers FP-1, FP-2, FP-3 & FP-4 and Calculations
2			Reduced Scale Drawings FP-1 to FP-4 – 11x17
2			SFMO Permit
2			PWD Water Flow Map
1			Permit Application
1			Check

THESE ARE TRANSMITTED as checked below:

- For your approval Approved as submitted Resubmit _____ copies for approval
- For your use Approved as noted Submit _____ copies for distribution

REMARKS:

SIGNED: Alan Small



State of Maine
Department of Public Safety



Fire Sprinkler System Permit

8864

Martin's Point Healthcare MOB

Located at: 331 Veranda Street
In the Town of: Portland
Occupancy/Use: Medical Office Building
Type of System: NFPA 13

Permission is hereby given to:

Sprinkler Systems, Inc.
PO Box 1285
Lewiston, ME 042431285
Contractor License # 93

according to plans submittal filed with the Licensing and Inspections Unit and are now approved. This application form/plans are filed under log # 2091440, and no departure from application form/plans shall be made without prior approval in writing. This permit is issued under the provisions of Title 32, Chapter 20, Section 12004-I. Nothing herein shall excuse the holder of this permit for failure to comply with local ordinances, zoning laws, or other pertinent legal restrictions. Each permit issued shall be displayed/available at the site of construction.

This permit was issued on 11/14/2009 for a fee paid of \$1,144.00
This permit will expire at midnight on Thursday, May 13, 2010

Anne H. Jordan
Commissioner

Fire Department Connection Location/Type per Local Fire Department

Within 30 days of the completion of a new fire sprinkler system or an addition to an existing fire sprinkler system, a fire sprinkler system contractor shall provide to the Licensing and Inspections Unit a copy of this permit signed and dated by the certified responsible managing supervisor representing that the fire sprinkler system has been installed according to specifications of the approved plan to the best of the supervisor's knowledge, information, and belief. This requirement is part of the sprinkler law, and neglect of this duty is grounds to not renew the contractor's license to do work in the State of Maine. All sprinkler licenses expire June 30th every year.

Job completed, tested and verified on date of _____

RMS for this job: Kannegieser J. Marc

RMS Signature: _____

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK CITY OF PORTLAND

Please Read Application And Notes, If Any, Attached

BUILDING INSPECTION PERMIT

Permit Number: 101244

This is to certify that Martin's Point Health Care Inc. Sprinkler System, Inc. has permission to Install Sprinkler System

AT 331 Veranda St

CPI 434-0005001

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of buildings and structures, and of the application on file in this department.

Apply to Public Works for street line and grade if nature of work requires such information.

Notification of inspection must be given and written permission procured before this building or part thereof is lathed or otherwise closed-in. 24 HOUR NOTICES REQUIRED.

A certificate of occupancy must be procured by owner before this building or part thereof is occupied.

OTHER REQUIRED APPROVALS

Fire Dept. CAPT. [Signature]

Health Dept. _____

Appeal Board _____

Other _____

Department Name

Director - Building & Inspection Services

PENALTY FOR REMOVING THIS CARD



CITY OF PORTLAND, MAINE
Department of Building Inspections

Original Receipt

Oct 5 2010

Received from Spunkh Systems

Location of Work 331 Vermont St.

Cost of Construction \$ _____ Building Fee: _____

Permit Fee \$ _____ Site Fee: _____

Certificate of Occupancy Fee: _____

Total: 340.00

Building (I1) _____ Plumbing (I5) _____ Electrical (I2) _____ Site Plan (U2) _____

Other Spinkler

CBL: 434 C005

Check #: 252910 Total Collected \$ 340.00

**No work is to be started until permit issued.
Please keep original receipt for your records.**

Taken by: [Signature]

WHITE - Applicant's Copy
YELLOW - Office Copy
PINK - Permit Copy



PORTLAND WATER DISTRICT
 225 Douglass Street
 Portland, ME 04104

Drawn By: DPW
 Date: 7/12/2009


Scale: As Noted

331 Veranda Street
 Portland

Disclaimer: This map is suitable for preliminary study and analysis and is based on PWD record information. PWD is not liable for any damages whatsoever resulting from inaccurate data or from errors made in the location and marking of its infrastructure.

Prepared for:
 Sprinkler Systems, Inc
 Sheet No. 1 of 1

1 inch = 100 feet




Flow Hydrant
 POD-HYD001798
 WS# 005923
 Veranda St 500' NE of Oregon St
 Date: 8-1-2006
 Static: 89 psi
 Pito: 80 psi
 Flow: 1500 gpm

Main material and
 installation date
 change

Site

Test Hydrant
 POD-HYD01668
 WS# 003369
 Veranda St 300' NE of Oregon St
 Date: 8-1-2006
 Static: 100 psi
 Residual: 88 psi



... Fire Protection by Computer Design

Sprinkler Systems Inc.
2-4 Avon Street
P O Box 1285
Lewiston, Maine 04240
207-782-0104

Job Name : MARTIN'S POINT HEALTH CARE AREA 1
Building : NEW
Location : US ROUTE 1 PORTLAND, MAINE
System : 1 WET
Contract : 09032
Data File : MIPtA1a.WXF

Fittings Used Summary

Sprinkler Systems Inc.
MARTIN'S POINT HEALTH CARE AREA 1

Fitting Legend Abbrev. Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B Generic Butterfly Valve	0	0	0	0	0	0	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E 90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zac Ames 2000SS	Fitting generates a Fixed Loss Based on Flow																			
Zf Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61

Units Summary

- Diameter Units Inches
- Length Units Feet
- Flow Units US Gallons per Minute
- Pressure Units Pounds per Square Inch

Final Calculations - Hazen-Williams

Sprinkler Systems Inc.
MARTIN'S POINT HEALTH CARE AREA 1

Page 4
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
TYP to ARM	16.80 16.8	1.049 120 0.0943	1E 2.0 1T 5.0 1Eq 17.0	1.500 24.000 25.500	9.000 0.0 2.404			K Factor = 5.60 Vel = 6.24	
	0.0 16.80					11.404		K Factor = 4.97	
ARM1 to 10	26.18 26.18	1.049 120 0.2142	1E 2.0 1T 5.0 0.0	3.500 7.000 10.500	21.857 0.0 2.249			K Factor = 5.60 Vel = 9.72	
	0.0 26.18					24.106		K Factor = 5.33	
9 to 10	24.21 24.21	1.442 120 0.0393	0.0 0.0 0.0	10.750 0.0 10.750	23.683 0.0 0.423			K Factor @ node ARM Vel = 4.76	
10 to 11	26.18 50.39	1.442 120 0.1527	0.0 0.0 0.0	8.500 0.0 8.500	24.106 0.0 1.298			Vel = 9.90	
11 to 12	25.08 75.47	1.442 120 0.3223	0.0 0.0 0.0	12.000 0.0 12.000	25.404 0.0 3.868			K Factor @ node ARM Vel = 14.83	
12 to 13	26.91 102.38	1.442 120 0.5668	1T 7.432 0.0 0.0	42.500 7.432 49.932	29.272 0.0 28.301			K Factor @ node ARM Vel = 20.11	
	0.0 102.38					57.573		K Factor = 13.49	
2 to 3	17.44 17.44	1.049 120 0.1010	1E 2.0 1T 5.0 0.0	4.000 7.000 11.000	9.703 0.0 1.111			K Factor = 5.60 Vel = 6.47	
	0.0 17.44					10.814		K Factor = 5.30	
1 to 3	17.12 17.12	1.049 120 0.0976	1E 2.0 1T 5.0 0.0	8.000 7.000 15.000	9.350 0.0 1.464			K Factor = 5.60 Vel = 6.36	
3 to 4	17.45 34.57	1.442 120 0.0761	0.0 0.0 0.0	7.750 0.0 7.750	10.814 0.0 0.590			Vel = 6.79	
4 to 5	16.80 51.37	1.442 120 0.1582	0.0 0.0 0.0	9.250 0.0 9.250	11.404 0.0 1.463			K Factor @ node ARM Vel = 10.09	
5 to 6	17.84 69.21	1.442 120 0.2747	0.0 0.0 0.0	8.500 0.0 8.500	12.867 0.0 2.335			K Factor @ node ARM Vel = 13.60	

Final Calculations - Standard

Sprinkler Systems Inc.
MARTIN'S POINT HEALTH CARE AREA 1

Page 6
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
BASE	0.0	8.27	2E 53.91	600.000	80.106				
to		140	1G 5.99	139.268	5.197				
HOSE	213.31	0.0003	2F 26.955	739.268	0.248				Vel = 1.27
			1T 52.413						
HOSE	100.00	12.34	0.0	145.000	85.551				Qa = 100.0
to		140	0.0	0.0	0.0				
TEST	313.31	0.0001	0.0	145.000	0.015				Vel = 0.84
	0.0								
	313.31				85.566				K Factor = 33.87

Hydraulic Design Information Sheet

Name - MARTIN'S POINT HEALTH CARE WET SYS. AREA 2 Date - 7/22/09
Location - US ROUTE 1 PORTLAND, MAINE
Building - NEW Contractor - SPRINKLER SYSTEMS INC. System No. - 1 WET
Calculated By - CDS Contract No. - 09032
Construction: () Combustible (X) Non-Combustible Drawing No. - 4 OF 4
Occupancy - MEDICAL OFFICES Ceiling Height - VARIES

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
Y () NFPA 231 () NFPA 231C () Figure Curve
S Other

T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 945	System Type	Sprinkler/Nozzle
	Density	- .10	(X) Wet	Make VIKING
D	Area Per Sprinkler	- 168	() Dry	Model VK302
E	Elevation at Highest Outlet	- 110.500	() Deluge	Size 1/2" X 1/2"
S	Hose Allowance - Inside	- 0	() Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance	- 0	() Other	Temp.Rat.155 DEG.
G	Hose Allowance - Outside	- 100		

Note

Calculation Flow Required - 214.71 Press Required - 61.285 AT BASE
Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 08/01/06	Rated Cap.-	Cap. -
T	Time of Test - AM	@ Press -	Elev.-
E	Static Press - 100	Elev. -	
R	Residual Press - 88		Well
S	Flow - 1500		Proof Flow
U	Elevation - 68.0'		

P Location - ON SITE

L Source of Information - OWNER AND WATER DISTRICT
Y

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row		() Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling
A Longitudinal Transverse
G

E Horizontal Barriers Provided:

Final Calculations - Hazen-Williams

Sprinkler Systems Inc.
MARTIN'S POINT HEALTH CARE AREA 2

Page 10
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	***** Notes *****
TYP to ARM	16.80 16.8	1.049 120 0.0943	1E 2.0 1T 5.0 1Eq 17.0	1.500 24.000 25.500	9.000 0.0 2.404		K Factor = 5.60 Vel = 6.24
	0.0 16.80					11.404	K Factor = 4.97
14 to 15	26.15 26.15	1.442 120 0.0454	0.0 0.0 0.0	10.750 0.0 10.750	27.635 0.0 0.488		K Factor @ node ARM Vel = 5.14
15 to 16	26.39 52.54	1.442 120 0.1649	1T 7.432 0.0 0.0	58.500 7.432 65.932	28.123 0.0 10.875		K Factor @ node ARM Vel = 10.32
16 to 27	0.0 52.54	4.26 120 0.0008	0.0 0.0 0.0	10.500 0.0 10.500	38.998 0.0 0.008		Vel = 1.18
	0.0 52.54					39.006	K Factor = 8.41
17 to 18	24.17 24.17	1.442 120 0.0392	0.0 0.0 0.0	7.500 0.0 7.500	23.602 0.0 0.294		K Factor @ node ARM Vel = 4.75
18 to 19	24.32 48.49	1.442 120 0.1422	0.0 0.0 0.0	13.000 0.0 13.000	23.896 0.0 1.849		K Factor @ node ARM Vel = 9.53
19 to 26	25.24 73.73	1.442 120 0.3088	0.0 0.0 0.0	3.750 0.0 3.750	25.745 0.0 1.158		K Factor @ node ARM Vel = 14.48
	0.0 73.73					26.903	K Factor = 14.21
20 to 21	16.80 16.8	1.442 120 0.0200	0.0 0.0 0.0	3.500 0.0 3.500	11.404 0.0 0.070		K Factor @ node ARM Vel = 3.30
21 to 22	16.85 33.65	1.442 120 0.0722	0.0 0.0 0.0	4.250 0.0 4.250	11.474 0.0 0.307		K Factor @ node ARM Vel = 6.61
22 to 23	17.08 50.73	1.442 120 0.1546	0.0 0.0 0.0	8.000 0.0 8.000	11.781 0.0 1.237		K Factor @ node ARM Vel = 9.97
23 to 24	17.95 68.68	1.442 120 0.2707	0.0 0.0 0.0	10.250 0.0 10.250	13.018 0.0 2.775		K Factor @ node ARM Vel = 13.49
24 to 25	19.77 88.45	1.442 120 0.4324	1T 7.432 0.0 0.0	2.500 7.432 9.932	15.793 0.0 4.295		K Factor @ node ARM Vel = 17.38

Final Calculations - Standard

Sprinkler Systems Inc.
MARTIN'S POINT HEALTH CARE AREA 2

Page 12
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Fng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
-----------------------	--------------	----------------------	---------------------------	------------------------	----------------	----------------	-------	-------	-------

Hydraulic Design Information Sheet

Name - MARTIN'S POINT HEALTH CARE WET SYS. AREA 3 Date - 7/22/09
Location - US ROUTE 1 PORTLAND, MAINE
Building - NEW
Contractor - SPRINKLER SYSTEMS INC. System No. - 1 WET
Calculated By - CDS Contract No. - 09032
Construction: () Combustible (X) Non-Combustible Drawing No. - 4 OF 4
Occupancy - MEDICAL OFFICES Ceiling Height - VARIES

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
Y () NFPA 231 () NFPA 231C () Figure Curve
S Other

T Specific Ruling Made By Date
E

M Area of Sprinkler Operation - 945 System Type Sprinkler/Nozzle
Density - .10 (X) Wet Make VIKING
D Area Per Sprinkler - 168 () Dry Model VK302
E Elevation at Highest Outlet - 110.500 () Deluge Size 1/2" X 1/2"
S Hose Allowance - Inside - 0 () Preaction K-Factor 5.6
I Rack Sprinkler Allowance - 0 () Other Temp.Rat.155 DEG.
G Hose Allowance - Outside - 100
N

Note

Calculation Flow Required - 207.62 Press Required - 82.092 AT BASE
Summary C-Factor Used: 120 Overhead 140 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 08/01/06 Cap. -
T Time of Test - AM Rated Cap. - Elev.-
E Static Press - 100 @ Press -
R Residual Press - 88 Elev. - Well
S Flow - 1500 Proof Flow
U Elevation - 68.0'

P Location - ON SITE

L Source of Information - OWNER AND WATER DISTRICT
Y

C Commodity Class Location
O Storage Ht. Area Aisle W.
M Storage Method: Solid Piled % Palletized % Rack
M
S R () Single Row () Conven. Pallet () Auto. Storage () Encap.
T A () Double Row () Slave Pallet () Solid Shelf () Non
O C () Mult. Row () Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling
A Longitudinal Transverse
G

E Horizontal Barriers Provided:

Final Calculations - Hazen-Williams

Sprinkler Systems Inc.
MARTIN'S POINT HEALTH CARE AREA 3

Page 16
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftnng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
TYP to ARM	16.80 16.8 0.0 16.80	1.049 120 0.0943	1E 2.0 1T 5.0 1Eq 17.0	1.500 24.000 25.500	9.000 0.0 2.404			K Factor = 5.60 Vel = 6.24	
ARM1 to 110	18.91 18.91 0.0 18.91	1.049 120 0.1174	1E 2.0 1T 5.0 0.0	4.000 7.000 11.000	11.403 0.0 1.291			K Factor = 4.97 K Factor = 5.60 Vel = 7.02	
ARM2 to 111	20.19 20.19 0.0 20.19	1.049 120 0.1324	1E 2.0 1T 5.0 0.0	4.250 7.000 11.250	12.993 0.0 1.489			K Factor = 5.31 K Factor = 5.60 Vel = 7.50	
ARM3 to 101	17.27 17.27 0.0 17.27	1.049 120 0.0992	1E 2.0 1T 5.0 0.0	6.500 7.000 13.500	9.512 0.0 1.339			K Factor = 5.31 K Factor = 5.60 Vel = 6.41	
108 to 109	17.21 17.21 0.0210	1.442 120 0.0210	0.0 0.0 0.0	8.000 0.0 8.000	11.969 0.0 0.168			K Factor = 5.24 K Factor @ node ARM Vel = 3.38	
109 to 110	17.33 34.54 0.0760	1.442 120 0.0760	0.0 0.0 0.0	7.330 0.0 7.330	12.137 0.0 0.557			K Factor @ node ARM Vel = 6.79	
110 to 111	18.91 53.45 0.1703	1.442 120 0.1703	0.0 0.0 0.0	10.500 0.0 10.500	12.694 0.0 1.788			Vel = 10.50	
111 to 112	20.19 73.64 0.3080	1.442 120 0.3080	0.0 0.0 0.0	7.000 0.0 7.000	14.482 0.0 2.156			Vel = 14.47	
112 to 112A	20.29 93.93 0.4833	1.442 120 0.4833	0.0 0.0 0.0	82.000 0.0 82.000	16.638 0.0 39.629			K Factor @ node ARM Vel = 18.45	
112A to 113	0.0 93.93 0.4833	1.442 120 0.4833	1T 7.432 0.0 0.0	1.000 7.432 8.432	56.267 0.0 4.075			Vel = 18.45	
HSW1 to 102	17.17 17.17 0.0981	1.049 120 0.0981	1E 2.0 1T 5.0 0.0	2.500 7.000 9.500	9.406 0.650 0.932			K Factor = 12.09 K Factor = 5.60 Vel = 6.37	

Final Calculations - Standard

Sprinkler Systems Inc.
MARTIN'S POINT HEALTH CARE AREA 3

Page 18
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Fng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
31 to 32	0.0 207.62	4.26 120 0.0107	2E 26.334 0.0 0.0	14.250 26.334 40.584	70.363 0.0 0.435				
32 to TWR	0.0 207.62	4.26 120 0.0107	2E 26.334 0.0 0.0	13.000 26.334 39.334	70.798 5.197 0.422		Vel = 4.67		
TWR to 3000	0.0 207.62	4.26 120 0.0107	1Zf 10.0 1T 26.334 1B 15.8	8.000 52.134 60.134	76.417 2.599 0.645		Vel = 4.67		
3000 to BKFL	0.0 207.62	4.026 120 0.0141	2E 20.0 0.0 0.0	5.000 20.000 25.000	79.661 -0.866 0.353		Vel = 5.23		
BKFL to BASE	0.0 207.62	4.026 120 0.0141	1T 20.0 1Zac 0.0 0.0	1.000 20.000 21.000	79.148 2.648 0.296		* Fixed loss = 2.648 Vel = 5.23		
BASE to HOSE	0.0 207.62	8.27 140 0.0003	2E 53.91 1G 5.99 2F 26.955 1T 52.413	600.000 139.268 739.268	82.092 5.197 0.236		Vel = 1.24		
HOSE to TEST	100.00 307.62	12.34 140 0.0001	0.0 0.0 0.0	145.000 0.0 145.000	87.525 0.0 0.014		Qa = 100.0 Vel = 0.83		
	0.0 307.62					87.539	K Factor = 32.88		

Hydraulic Design Information Sheet

Name - MARTIN'S POINT HEALTH CARE WET SYS. AREA 4 Date - 7/22/09
Location - US ROUTE 1 PORTLAND, MAINE
Building - NEW System No. - 1 WET
Contractor - SPRINKLER SYSTEMS INC. Contract No. - 09032
Calculated By - CDS Drawing No. - 4 OF 4
Construction: () Combustible (X) Non-Combustible Ceiling Height - VARIES
Occupancy - MECHANICAL ROOM

S (X) NFPA 13 () Lt. Haz. Ord.Haz.Gp. (X) 1 () 2 () 3 () Ex.Haz.
Y () NFPA 231 () NFPA 231C () Figure Curve
S Other

T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- ENTIRE	System Type	Sprinkler/Nozzle
	Density	- .15	(X) Wet	Make VIKING
D	Area Per Sprinkler	- 130	() Dry	Model VK300
E	Elevation at Highest Outlet	- 122.25	() Deluge	Size 1/2" X 1/2"
S	Hose Allowance - Inside	- 0	() Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance	- 0	() Other	Temp.Rat.200 DEG.
G	Hose Allowance - Outside	- 250		

Note

Calculation Flow Required - 248.91 Press Required - 52.311 AT BASE
Summary C-Factor Used: 120 Overhead 140 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 08/01/06 Cap. -
T Time of Test - AM Rated Cap.- Elev.-
E Static Press - 100 @ Press -
R Residual Press - 88 Elev. - Well
Flow - 1500 Proof Flow
S Elevation - 68.0'

U Location - ON SITE

P Source of Information - OWNER AND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	% Palletized	% Rack
	() Single Row () Conven. Pallet () Auto. Storage () Encap.		
S	() Double Row () Slave Pallet () Solid Shelf () Non		
T	() Mult. Row () Open Shelf		

R K Flue Spacing Clearance:Storage to Ceiling
A Longitudinal Transverse

G Horizontal Barriers Provided:

Final Calculations - Hazen-Williams

Sprinkler Systems Inc.
MARTIN'S POINT HEALTH CARE AREA 4

Page 22
Date


Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
209 to 210	19.86	1.442 120	0.0	12.250	12.572			K Factor = 5.60	
210 to 211	19.86	0.0273	0.0	12.250	0.334			Vel = 3.90	
211 to 211A	20.11	1.442 120	0.0	12.250	12.906			K Factor = 5.60	
211A to 212	39.97	0.0994	0.0	12.250	1.218			Vel = 7.85	
212 to 213	21.05	1.442 120	0.0	12.250	14.124			K Factor = 5.60	
213 to 212	61.02	0.2176	0.0	12.250	2.666			Vel = 11.99	
212 to 213	22.95	1.442 120	1T	7.432	5.750	16.790		K Factor = 5.60	
213 to 212	83.97	0.3927	0.0	13.182	5.176			Vel = 16.50	
212 to 213	0.0	2.157 120	1T	12.307	1.750	21.966			
213 to 212	83.97	0.0553	0.0	14.057	0.777			Vel = 7.37	
212 to 213	0.0								
213 to 212	83.97				22.635			K Factor = 17.65	
205 to 206	19.59	1.442 120	0.0	12.000	12.238			K Factor = 5.60	
206 to 207	19.59	0.0267	0.0	12.000	0.320			Vel = 3.85	
207 to 207A	19.85	1.442 120	0.0	12.250	12.558			K Factor = 5.60	
207A to 208	39.44	0.0970	0.0	12.250	1.188			Vel = 7.75	
208 to 207A	20.76	1.442 120	0.0	12.250	13.746			K Factor = 5.60	
207A to 208	60.2	0.2122	0.0	12.250	2.600			Vel = 11.83	
208 to 207A	22.64	1.442 120	1T	7.432	5.750	16.346		K Factor = 5.60	
207A to 208	82.84	0.3829	0.0	13.182	5.048			Vel = 16.27	
208 to 207A	0.0								
207A to 208	82.84				21.286			K Factor = 17.96	
201 to 202	19.50	1.442 120	0.0	14.000	12.125			K Factor = 5.60	
202 to 203	19.5	0.0264	0.0	14.000	0.369			Vel = 3.83	
203 to 203A	19.79	1.442 120	0.0	12.250	12.494			K Factor = 5.60	
203A to 204	39.29	0.0964	0.0	12.250	1.181			Vel = 7.72	
204 to 203A	20.71	1.442 120	0.0	9.000	13.675			K Factor = 5.60	
203A to 204	60.0	0.2109	0.0	9.000	1.898			Vel = 11.79	
204 to 203A	22.10	1.442 120	1T	7.432	6.500	15.573		K Factor = 5.60	
203A to 204	82.1	0.3768	0.0	13.932	5.249			Vel = 16.13	


Water Supply Curve (C)

Sprinkler Systems Inc.
 MARTIN'S POINT HEALTH CARE AREA 4

City Water Supply:
 C1 - Static Pressure : 100
 C2 - Residual Pressure: 88
 C2 - Residual Flow : 1500

Demand:
 D1 - Elevation : 23.604
 D2 - System Flow : 248.907
 D2 - System Pressure : 57.894
 Hose (Adj City) : 250
 Hose (Demand) : 498.907
 D3 - System Demand : 40.540
 Safety Margin





... Fire Protection by Computer Design

Sprinkler Systems Inc.
2-4 Avon Street
P O Box 1285
Lewiston, Maine 04240
207-782-0104

Job Name : MARTIN'S POINT HEALTH CARE SECOND LEVEL PARKING AREA 1
Building : NEW
Location : US ROUTE 1 PORTLAND, MAINE
System : 2 DRY
Contract : 09032
Data File : MIPtD2A1R.WXF

Sprinkler Systems Inc.
 MARTIN'S POINT HEALTH CARE SECOND LEVEL PARKING AREA 1


Fitting Legend Abbrev. Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B Generic Butterfly Valve	0	0	0	0	0	0	7	10	0	12	9	10	12	19	21	0	0	0	0	0
D Generic Dry Pipe Valve	0	0	0	0	0	0	9.5	17	0	28	0	47	0	0	0	0	0	0	0	0
E 90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zac Ames 2000SS	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

- Diameter Units Inches
- Length Units Feet
- Flow Units US Gallons per Minute
- Pressure Units Pounds per Square Inch

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Fng's Total	Pt Pe Pf	Pt Pv Pn	***** Notes *****
TYP to DROP	19.50 19.5	1.049 100 0.1740	1T 3.568 0.0 0.0	1.000 3.568 4.568	12.125 0.0 0.795		K Factor = 5.60 Vel = 7.24
	0.0 19.50					12.920	K Factor = 5.43
317 to 318	32.76 32.76	1.682 100 0.0456	2E 7.065 0.0 0.0	9.000 7.066 16.066	36.474 0.0 0.733		K Factor @ node DROP Vel = 4.73
318 to 319	33.10 65.86	1.682 100 0.1658	2T 14.131 1E 3.533 0.0	12.250 17.664 29.914	37.207 0.217 4.961		K Factor @ node DROP Vel = 9.51
	0.0 65.86					42.385	K Factor = 10.12
315 to 316	34.16 34.16	1.682 100 0.0492	2T 14.131 0.0 0.0	13.250 14.131 27.381	39.661 0.0 1.348		K Factor @ node DROP Vel = 4.93
	0.0 34.16					41.009	K Factor = 5.33
309 to 310	19.68 19.68	1.682 100 0.0178	0.0 0.0 0.0	8.250 0.0 8.250	13.165 0.0 0.147		K Factor @ node DROP Vel = 2.84
310 to 311	19.80 39.48	1.682 100 0.0644	0.0 0.0 0.0	8.250 0.0 8.250	13.312 0.0 0.531		K Factor @ node DROP Vel = 5.70
311 to 312	20.18 59.66	1.682 100 0.1382	0.0 0.0 0.0	8.250 0.0 8.250	13.843 0.0 1.140		K Factor @ node DROP Vel = 8.61
312 to 313	21.00 80.66	1.682 100 0.2413	0.0 0.0 0.0	8.250 0.0 8.250	14.983 0.0 1.991		K Factor @ node DROP Vel = 11.65
313 to 314	22.35 103.01	1.682 100 0.3795	0.0 0.0 0.0	8.250 0.0 8.250	16.974 0.0 3.131		K Factor @ node DROP Vel = 14.87
314 to ZZ	24.33 127.34	1.682 100 0.5617	1E 3.533 1T 7.065 0.0	9.000 10.599 19.599	20.105 0.0 11.009		K Factor @ node DROP Vel = 18.39
	0.0 127.34					31.114	K Factor = 22.83
301 to 302	19.50 19.5	1.682 100 0.0175	0.0 0.0 0.0	8.250 0.0 8.250	12.920 0.0 0.144		K Factor @ node DROP Vel = 2.82

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes *****
TDV2 to 2000	0.0 387.6	4.026 120 0.0448	1D 28.0 1B 12.0 1T 20.0	2.000 60.000 62.000	63.308 1.732 2.779			
2000 to 3000	0.0 387.6	4.26 120 0.0340	0.0 0.0 0.0	3.000 0.0 3.000	67.819 0.0 0.102		Vel = 9.77	
3000 to BKFL	0.0 387.6	4.026 120 0.0448	2E 20.0 0.0 0.0	5.000 20.000 25.000	67.921 -0.866 1.120		Vel = 8.72	
BKFL to BASE	0.0 387.6	4.026 120 0.0448	1T 20.0 1Zac 0.0 0.0	1.000 20.000 21.000	68.175 3.728 0.941		Vel = 9.77	* Fixed loss = 3.728
BASE to HOSE	0.0 387.6	8.27 140 0.0010	2E 53.91 1G 5.99 2F 26.955 1T 52.413	600.000 139.268 739.268	72.844 5.197 0.748		Vel = 9.77	
HOSE to TEST	250.00 637.6	12.34 140 0.0004	0.0 0.0 0.0	145.000 0.0 145.000	78.789 0.0 0.053		Qa = 250 Vel = 2.32	
	0.0 637.60							Vel = 1.71
					78.842			K Factor = 71.81



... Fire Protection by Computer Design

Sprinkler Systems Inc.
2-4 Avon Street
P O Box 1285
Lewiston, Maine 04240
207-782-0104

Job Name : MARTIN'S POINT HEALTH CARE FIRST LEVEL PARKING AREA 1
Building : NEW
Location : US ROUTE 1 PORTLAND, MAINE
System : 1 DRY
Contract : 09032
Data File : MIPtD1A1.WXF

Fittings Used Summary

Sprinkler Systems Inc.

MARTIN'S POINT HEALTH CARE FIRST LEVEL PARKING AREA 1

Fitting Legend Abbrev. Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B Generic Butterfly Valve	0	0	0	0	0	0	7	10	0	12	9	10	12	19	21	0	0	0	0	0
D Generic Dry Pipe Valve	0	0	0	0	0	0	9.5	17	0	28	0	47	0	0	0	0	0	0	0	0
E 90° Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F 45° Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T 90° Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zac Ames 2000SS	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units
Length Units
Flow Units
Pressure Units

Inches
Feet
US Gallons per Minute
Pounds per Square Inch

Final Calculations - Hazen-Williams

Sprinkler Systems Inc.

MARTIN'S POINT HEALTH CARE FIRST LEVEL PARKING AREA 1

Page 4
Date


Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftn'g's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
219 to 220	30.21	1.682 100	2T 14.131 1E 3.533	8.000 17.664	29.110 0.0			K Factor = 5.60	
	0.0		0.0	25.664	1.007			Vel = 4.36	
	30.21				30.117				
213 to 214	19.75	1.682 100	0.0	13.000	12.443			K Factor = 5.50	
	19.75	0.0179	0.0	0.0	0.0			K Factor = 5.60	
			0.0	13.000	0.233			Vel = 2.85	
214 to 215	19.94	1.682 100	0.0	13.000	12.676			K Factor = 5.60	
	39.69	0.0650	0.0	0.0	0.0			Vel = 5.73	
	20.59	1.682 100	0.0	13.000	13.521			K Factor = 5.60	
	60.28	0.1408	0.0	0.0	0.0			Vel = 8.70	
	21.94	1.682 100	0.0	13.000	15.352			K Factor = 5.60	
	82.22	0.2501	0.0	0.0	0.0			Vel = 11.87	
	24.16	1.682 100	2T 14.131 1E 3.533	8.000 17.664	18.603 0.0			K Factor = 5.60	
	106.38	0.4027	0.0	25.664	10.336			Vel = 15.36	
	0.0								
	106.38				28.939			K Factor = 19.78	
207 to 208	19.56	1.682 100	0.0	13.000	12.194			K Factor = 5.60	
	19.56	0.0175	0.0	0.0	0.0			Vel = 2.82	
			0.0	13.000	0.228				
208 to 209	19.73	1.682 100	0.0	13.000	12.422			K Factor = 5.60	
	39.29	0.0638	0.0	0.0	0.0			Vel = 5.67	
	20.39	1.682 100	0.0	13.000	13.252			K Factor = 5.60	
	59.68	0.1382	0.0	0.0	0.0			Vel = 8.62	
	21.72	1.682 100	0.0	13.000	15.049			K Factor = 5.60	
	81.4	0.2455	0.0	0.0	0.0			Vel = 11.75	
	23.92	1.682 100	2T 14.131 1E 3.533	8.000 17.664	18.240 0.0			K Factor = 5.60	
	105.32	0.3954	0.0	25.664	10.147			Vel = 15.21	
	0.0								
	105.32				28.387			K Factor = 19.77	
201 to 202	19.50	1.682 100	0.0	13.000	12.125			K Factor = 5.60	
	19.5	0.0175	0.0	0.0	0.0			Vel = 2.82	
			0.0	13.000	0.227				

Final Calculations - Standard

Sprinkler Systems Inc.
 MARTIN'S POINT HEALTH CARE FIRST LEVEL PARKING AREA 1


Page 6
 Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
BKFL to BASE	0.0 346.94	4.026 120 0.0365	1T 20.0 1Zac 0.0 0.0	1.000 20.000 21.000	70.002 3.482 0.767			* Fixed loss = 3.482 Vel = 8.74	
BASE to HOSE	0.0 346.94	8.27 140 0.0008	2E 53.91 1G 5.99 2F 26.955 1T 52.413	600.000 139.268 739.268	74.251 5.197 0.610			Vel = 2.07	
HOSE to TEST	250.00 596.94	12.34 140 0.0003	0.0 0.0 0.0	145.000 0.0 145.000	80.058 0.0 0.046			Qa = 250 Vel = 1.60	
	0.0 596.94							80.104 K Factor = 66.70	




MINIMUM PITCH FOR ALL MAINS IS 1/8" PER 10'-0"
 AND 1/4" PER 10'-0" FOR ALL BRANCHES.
 ALL DEVICES ARE TO BE INSTALLED FROM THE
 APPROXIMATE POSITION OF THE THIRD FLOOR - SEE
 BUILDING SECTION ON P. 14 FOR FLOOR FINISHES.

1st LEVEL - PARKING - WEST




- Type of Hazard **DRY / LIGHT** & Reflector Distance
- Pipe Type Used **1/2" AL. BK. C.** Sprinkler Area **24X46 30 FT.**
- Type of Construction **NON-CONSTRUCTIBLE**
- Maximum Spacing Allowed **LIGHTS 22.50 FT. HD & DR-130 30 FT. HD.**
- PIPE SIZING METHOD PIPE SCHEDULE
 HYDRAULICALLY CALCULATED
- ALL HANGERS AND LOCATIONS TO BE IN ACCORDANCE
 WITH NFPA PAMPHLET NO. 13
- NON DEGREE TEMPERATURE SPRINKLER HEADS TO BE
 INSTALLED IN ACCORDANCE WITH NFPA PAMPHLET
 NO. 12




SYMBOL	DESCRIPTION
○	AL BRKO RD
○	AL BK
○	AL SHD
○	AL PRKO RD
○	BR
○	SHD
○	DR SHD
○	1/2" SHD


ABBREVIATIONS	CONTRACT RESPONSIBILITIES			
B	Bottom of Beam	ITEM	FFC	CON
D	Bottom of Deck	STRUCY COM		
DB	Bottom of Pipe	MECH		
DB	Beam Depth	MECH		
DB	Right and Left	MECH		
DB	Not in Contact	MECH		
DB	Clearance	MECH		
DB	Prepared Bar Joints	MECH		
DB	Steel Member	MECH		
DB	Support Bar Joints	MECH		
DB	Top of Beam	MECH		
DB	Top of Pipe	MECH		
DB	Top of Deck	MECH		
DB	Utility Openings	MECH		
DB	Utility	MECH		
DB	Utility Openings	MECH		
DB	Utility	MECH		
DB	Utility	MECH		
DB	Utility	MECH		



M.O.B. TEL/DATA



M.O.B. IT/PHONE




SECOND LEVEL - TEL/DATA

PART PLANS OF FM-200 SYSTEMS

SCALE: 1/4"=1'-0"

GENERAL NOTES:

- SCOPE OF WORK: THE FIRST AND SECOND LEVELS ARE PRIMARILY UNHEATED PARKING PROTECTED WITH 2 DEDICATED DRY PIPE SYSTEMS. THE THIRD LEVEL MEDICAL OFFICES AND THE FOURTH LEVEL MECHANICAL PENTHOUSE ARE PROTECTED USING A SINGLE DRY VALVE. ALSO 3 FM-200 SYSTEMS ARE PROVIDED TO PROTECT DATA CLOSETS, ONE ON THE SECOND LEVEL AND 2 ON THE THIRD LEVEL.
- THE BUILDING OWNER SHALL BE RESPONSIBLE FOR PROVIDING ADEQUATE HEAT FOR ALL AREAS IN THE BUILDING PROTECTED BY WET SPINKLER SYSTEMS AND FOR ALL WATER FILLED SUPPLY PIPES.
- ALL NEW PIPING SHALL BE HYDROSTATICALLY TESTED AT NOT LESS THAN 200 PSI FOR 2 HOURS OR AT 50 PSI IN EXCESS OF THE MAXIMUM PRESSURE, WHEN THE MAXIMUM PRESSURE TO BE MAINTAINED IS IN EXCESS OF 150 PSI (PER NFPA 13).
- WHETHER OR NOT INDICATED ON DRAWINGS, THE FOLLOWING ITEMS SHALL BE PROVIDED:
 - SPARK HEAD CASING WITH WRENCH OUT P.A. ID
 - PROVISIONS FOR FLUSHING AND DRAINING ALL PIPING
 - INSPECTOR'S TEST CONNECTION FOR EACH SYSTEM
- ALL 1" PIPING SHALL BE SCHEDULE 40 BLACK STEEL WITH MALLEABLE IRON FITTINGS.
- ALL PIPING 1 1/2" AND LARGER SHALL BE SCHEDULE 15 BLACK STEEL WITH GROOVED COUPLERS AND "VICTALARK FRELCO" FITTINGS OR EQUAL.
- ALL SPINKLER HEADS IN SALT CEILINGS SHALL BE LOCATED IN AN AESTHETIC, SYMMETRICAL PATTERN WHENEVER POSSIBLE WITH THE HEADS CENTERED WITHIN THE TILE.
- CENTERLINE OF PIPE ABOVE FINISH FLOOR IS INDICATED AS (P-0") OR BELOW BACK AS (B-0").
- HYDRAULIC DATA REFERENCE POINTS ARE INDICATED AS (R-0") OR (R-1").
- ALL HANGERS SHALL BE SIZED AND LOCATED IN ACCORDANCE WITH NFPA 13.
- ALL PIPING SHALL BE FITTED IN ACCORDANCE WITH NFPA 13 REQUIREMENTS.
- ALL MECHANICAL TRADES MUST COORDINATE THEIR WORK WITH THE SPINKLER WORK SHOWN ON THESE PLANS.
- THE SCOPE OF WORK UNDER THIS CONTRACT IS LIMITED TO THE WORK SHOWN ON THESE DOCUMENTS.



SITE PLAN

SCALE: 1"=100'-0"

HYDRAULIC DATA NAMEPLATE

This Building is protected by a hydraulically designed Automatic Sprinkler System

Location AREA-4

No. of Sprinkler 12


Basin of design

- Density 0.15 gpm/sq ft
- Design area of discharge ENTIRE

System Demand

- Water flow Rate 248.91 gpm
- Residual Pressure 52.311 psi

GROSS AREA SQ.FT. 1,300




BUILDING SECTION A-A

SCALE: 3/32"=1'-0"

NORTH



- Type of Hazard ORD. / LIGHT & DETECTOR BURNING
- Pipe Type Used EPDM BK
- Type of Construction NON-COMBUSTIBLE
- Minimum Spacing Allowed LIGHTS 20 FT AND 8 OR 12 IN SQ FT/100
- PIPE SIZING METHOD PIPE SCHEDULE HYDRAULICALLY CALCULATED
- ALL HANGERS AND LOCATIONS TO BE IN ACCORDANCE WITH NFPA 13 HANDBOOK MD 13
- NOON DEGREE TEMPERATURE SPINKLER HEADS TO BE INSTALLED IN ACCORDANCE WITH NFPA 13 HANDBOOK MD 13



AS SHOWN

1	ALL IRON ROD
2	3/8"
3	1/2"
4	3/4"
5	1"
6	1 1/2"
7	2"
8	2 1/2"
9	3"
10	3 1/2"
11	4"
12	4 1/2"
13	5"
14	5 1/2"
15	6"
16	6 1/2"
17	7"
18	7 1/2"
19	8"
20	8 1/2"
21	9"
22	9 1/2"
23	10"
24	10 1/2"
25	11"
26	11 1/2"
27	12"
28	12 1/2"
29	13"
30	13 1/2"
31	14"
32	14 1/2"
33	15"
34	15 1/2"
35	16"
36	16 1/2"
37	17"
38	17 1/2"
39	18"
40	18 1/2"
41	19"
42	19 1/2"
43	20"
44	20 1/2"
45	21"
46	21 1/2"
47	22"
48	22 1/2"
49	23"
50	23 1/2"
51	24"
52	24 1/2"
53	25"
54	25 1/2"
55	26"
56	26 1/2"
57	27"
58	27 1/2"
59	28"
60	28 1/2"
61	29"
62	29 1/2"
63	30"
64	30 1/2"
65	31"
66	31 1/2"
67	32"
68	32 1/2"
69	33"
70	33 1/2"
71	34"
72	34 1/2"
73	35"
74	35 1/2"
75	36"
76	36 1/2"
77	37"
78	37 1/2"
79	38"
80	38 1/2"
81	39"
82	39 1/2"
83	40"
84	40 1/2"
85	41"
86	41 1/2"
87	42"
88	42 1/2"
89	43"
90	43 1/2"
91	44"
92	44 1/2"
93	45"
94	45 1/2"
95	46"
96	46 1/2"
97	47"
98	47 1/2"
99	48"
100	48 1/2"
101	49"
102	49 1/2"
103	50"
104	50 1/2"
105	51"
106	51 1/2"
107	52"
108	52 1/2"
109	53"
110	53 1/2"
111	54"
112	54 1/2"
113	55"
114	55 1/2"
115	56"
116	56 1/2"
117	57"
118	57 1/2"
119	58"
120	58 1/2"
121	59"
122	59 1/2"
123	60"
124	60 1/2"
125	61"
126	61 1/2"
127	62"
128	62 1/2"
129	63"
130	63 1/2"
131	64"
132	64 1/2"
133	65"
134	65 1/2"
135	66"
136	66 1/2"
137	67"
138	67 1/2"
139	68"
140	68 1/2"
141	69"
142	69 1/2"
143	70"
144	70 1/2"
145	71"
146	71 1/2"
147	72"
148	72 1/2"
149	73"
150	73 1/2"
151	74"
152	74 1/2"
153	75"
154	75 1/2"
155	76"
156	76 1/2"
157	77"
158	77 1/2"
159	78"
160	78 1/2"
161	79"
162	79 1/2"
163	80"
164	80 1/2"
165	81"
166	81 1/2"
167	82"
168	82 1/2"
169	83"
170	83 1/2"
171	84"
172	84 1/2"
173	85"
174	85 1/2"
175	86"
176	86 1/2"
177	87"
178	87 1/2"
179	88"
180	88 1/2"
181	89"
182	89 1/2"
183	90"
184	90 1/2"
185	91"
186	91 1/2"
187	92"
188	92 1/2"
189	93"
190	93 1/2"
191	94"
192	94 1/2"
193	95"
194	95 1/2"
195	96"
196	96 1/2"
197	97"
198	97 1/2"
199	98"
200	98 1/2"
201	99"
202	99 1/2"
203	100"
204	100 1/2"
205	101"
206	101 1/2"
207	102"
208	102 1/2"
209	103"
210	103 1/2"
211	104"
212	104 1/2"
213	105"
214	105 1/2"
215	106"
216	106 1/2"
217	107"
218	107 1/2"
219	108"
220	108 1/2"
221	109"
222	109 1/2"
223	110"
224	110 1/2"
225	111"
226	111 1/2"
227	112"
228	112 1/2"
229	113"
230	113 1/2"
231	114"
232	114 1/2"
233	115"
234	115 1/2"
235	116"
236	116 1/2"
237	117"
238	117 1/2"
239	118"
240	118 1/2"
241	119"
242	119 1/2"
243	120"
244	120 1/2"
245	121"
246	121 1/2"
247	122"
248	122 1/2"
249	123"
250	123 1/2"
251	124"
252	124 1/2"
253	125"
254	125 1/2"
255	126"
256	126 1/2"
257	127"
258	127 1/2"
259	128"
260	128 1/2"
261	129"
262	129 1/2"
263	130"
264	130 1/2"
265	131"
266	131 1/2"
267	132"
268	132 1/2"
269	133"
270	133 1/2"
271	134"
272	134 1/2"
273	135"
274	135 1/2"
275	136"
276	136 1/2"
277	137"
278	137 1/2"
279	138"
280	138 1/2"
281	139"
282	139 1/2"
283	140"
284	140 1/2"
285	141"
286	141 1/2"
287	142"
288	142 1/2"
289	143"
290	143 1/2"
291	144"
292	144 1/2"
293	145"
294	145 1/2"
295	146"
296	146 1/2"
297	147"
298	147 1/2"
299	148"
300	148 1/2"
301	149"
302	149 1/2"
303	150"
304	150 1/2"
305	151"
306	151 1/2"
307	152"
308	152 1/2"
309	153"
310	153 1/2"
311	154"
312	154 1/2"
313	155"
314	155 1/2"
315	156"
316	156 1/2"
317	157"
318	157 1/2"
319	158"
320	158 1/2"
321	159"
322	159 1/2"
323	160"
324	160 1/2"
325	161"
326	161 1/2"
327	162"
328	162 1/2"
329	163"
330	163 1/2"
331	164"
332	164 1/2"
333	165"
334	165 1/2"
335	166"
336	166 1/2"
337	167"
338	167 1/2"
339	168"
340	168 1/2"
341	169"
342	169 1/2"
343	170"
344	170 1/2"
345	171"
346	171 1/2"
347	172"
348	172 1/2"
349	173"
350	173 1/2"
351	174"
352	174 1/2"
353	175"
354	175 1/2"
355	176"
356	176 1/2"
357	177"
358	177 1/2"
359	178"
360	178 1/2"
361	179"
362	179 1/2"
363	180"
364	180 1/2"
365	181"
366	181 1/2"
367	182"
368	182 1/2"
369	183"
370	183 1/2"
371	184"
372	184 1/2"
373	185"
374	185 1/2"
375	186"
376	186 1/2"
377	187"
378	187 1/2"
379	188"
380	188 1/2"
381	189"
382	189 1/2"
383	190"
384	190 1/2"
385	191"
386	191 1/2"
38	