

City of Portland, Maine - Building or Use Permit Application
 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

| | | |
|-----------------------|-------------|---------------------|
| Permit No: 09-0684 | Issue Date: | CBL: 435 A001001 |
|-----------------------|-------------|---------------------|


| | | | |
|---|--|---|------------------------|
| Location of Construction: 97 ALLEN AVE | Owner Name: NORTHERN NEW ENGLAND CO | Owner Address: 7TH DAY ADVENTIST INC | Phone: 207-650-0611 |
| Business Name: | Contractor Name: Jims Plumbing & Heating Inc. | Contractor Address: 98 Lamb Rd Westbrook | Phone: 2078548068 |
| Lessee/Buyer's Name | Phone: | Permit Type: HVAC | Zone: R-5 <i>SP</i> |

| | | | | | |
|--|---|-------------------------|------------------------------|--------------------|----------------------|
| Past Use: Commercial/Church Institutional | Proposed Use: Institutional/Church Commercial/Church - Install Alpine/Burnham Direct Vent Gas Fired Stainless Steel Boiler | Permit Fee: \$200.00 | Cost of Work: \$18,000.00 | CEO District: 4 | Zone: R-3 in rear |
|--|---|-------------------------|------------------------------|--------------------|----------------------|

| | | |
|--|---|--|
| Proposed Project Description: Install Alpine/Burnham Direct Vent Gas Fired Stainless Steel Boiler | FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied * See Conditions | INSPECTION: Use Group: A Type: HVAC DNC 2003 Signature: JMB 7/14/09 |
| PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) | | |
| Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied | | |
| Signature: _____ Date: _____ | | |

| | | |
|-------------------------|---------------------------------|------------------------|
| Permit Taken By: lmd | Date Applied For: 06/30/2009 | Zoning Approval |
|-------------------------|---------------------------------|------------------------|

| | | | |
|--|---|---|---|
| 1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules. 2. Building permits do not include plumbing, septic or electrical work. 3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.. | Special Zone or Reviews <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MIM <input type="checkbox"/> Date: <i>ok</i> 7/2/09 | Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date: _____ | Historic Preservation <input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date: <i>S</i> |
|--|---|---|---|



CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

| | | | |
|---|---------|------|-------|
| SIGNATURE OF APPLICANT | ADDRESS | DATE | PHONE |
| RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE | | DATE | PHONE |

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

| | | |
|------------------------------|--|----------------------------|
| Permit No: 09-0684 | Date Applied For: 06/30/2009 | CBL: 435 A001001 |
|------------------------------|--|----------------------------|

| | | | |
|--|---|--|---------------------------------|
| Location of Construction: 97 ALLEN AVE | Owner Name: NORTHERN NEW ENGLAND CO | Owner Address: 7TH DAY ADVENTIST INC | Phone: 207-650-0611 |
| Business Name: | Contractor Name: Jims Plumbing & Heating Inc. | Contractor Address: 98 Lamb Rd Westbrook | Phone: (207) 854-8068 |
| Lessee/Buyer's Name | Phone: | Permit Type: HVAC | |

| | |
|---|--|
| Proposed Use: Institutional/Church - Install Alpine/BurnhamDirect Vent Gas Fired Stainless Steel Boiler | Proposed Project Description: Install Alpine/BurnhamDirect Vent Gas Fired Stainless Steel Boiler |
|---|--|

| | | | |
|---|---|--------------------------------------|---|
| Dept: Zoning | Status: Approved | Reviewer: Marge Schmuckal | Approval Date: 07/02/2009 |
| Note: | | | Ok to Issue: <input checked="" type="checkbox"/> |
| Dept: Building | Status: Approved with Conditions | Reviewer: Jeanine Bourke | Approval Date: 07/14/2009 |
| Note: | | | Ok to Issue: <input checked="" type="checkbox"/> |
| 1) The appliance shall be installed in accordance with the UL listing, IMC 2003 and NFPA 211. | | | |
| 2) The installation must comply with the State of Maine Gas Regulations. | | | |
| Dept: Fire | Status: Approved with Conditions | Reviewer: Capt Keith Gautreau | Approval Date: 07/08/2009 |
| Note: | | | Ok to Issue: <input checked="" type="checkbox"/> |
| 1) The boiler room must be 1 hour rated or have sprinkler protection. (1 head above the boiler) | | | |
| 2) Install shall comply with all manufacture's specifications. | | | |