RISER DIAGRAM
SCALE: N.T.S.

RISER NOTES:

1. RISER IS A DIAGRAMMATICAL REPRESENTATION OF THE SYSTEM ARCHITECTURE IN BUILDING CROSS SECTION. IT IS NOT INTENDED TO REPRESENT ACTUAL WIRE RUNS, PANEL CONFIGURATIONS OR PENETRATIONS. REFER TO FLOOR PLANS AND PANEL DETAILS FOR CIRCUIT ROUTING AND CONFIGURATION INFORMATION.
2. ALL WIRING SHALL COMPLY WITH APPLICABLE ELECTRICAL CODES. REFER TO 'APPLICABLE CODES & STANDARDS' ON SHEET FA-000 FOR SPECIFIC CODE REFERENCES.

KEYED NOTES:

1. 120VAC PRIMARY POWER SOURCE SHALL BE A MECHANICALLY PROTECTED BRANCH CIRCUIT. THE CIRCUIT DISCONNECTING MEANS SHALL HAVE A RED MARKING, AND BE IDENTIFIED AS "FIRE ALARM CIRCUIT"
2. NEW SMOKE DETECTOR'S TO BE ADDED TO NEAREST EXISTING INITIATING CIRCUIT. FIELD TO VERIFY.

tyco SimplexGrinnell
Safer. Smarter. Tyco.™
DISTRICT - 147
30 THOMAS DRIVE
WESTBROOK, ME 04092
SERVICE: 207-842-6440
PHONE: 207-842-6440
FAX: 207-842-6439

NORTHFIELD GREEN BUILDINGS 147/149/151

NORTHFIELD GREEN
149 ALLEN AVENUE
PORTLAND, ME 04103-3734

ISSUE LOG				
MARK	DATE	CAD	CHK	DESCRIPTION

Revisions shown with ⚠ symbol

DRAWN BY:	PRANESH/TT
CHECKED BY:	TT
ISSUE DATE:	2/2/18
JOB #:	147428511
PROJECT #:	147604471601

JCI © 2018

SYSTEM:
FIRE ALARM SYSTEM

SHEET:
RISER DIAGRAM

FA-201

IMPORTANT NOTICE TO USER: By accepting or using this drawing and/or the information contained herein, the user agrees and acknowledges that this drawing may be subject to restrictions and limitations as to its use and distribution, and that any use or alteration or alteration of the information contained herein shall be at the sole risk of the user. This information may not be sold or transferred to any third party, used on other projects or additions to this project for which it was prepared, or used for completion of this project by any third party. Johnson Controls disclaims all liability for the use or misuse of altered files by the user or any subsequent third party and will hold harmless and indemnify, and hold Johnson Controls harmless from any and all claims for loss, damage or injury arising directly or indirectly therefrom.

FILE PATH: C:\Users\tmotter\Box Sync\Greater NY-New England Design Team Pass Folder\147-604471601 Northfield Green 2018 Replacements\Submittals\FIRE\FA-201.dwg
LAST SAVED BY: TTROTTER
LAST PRINTED: 2/12/2018 10:55:40 AM
24" x 36" - Arch D Size