

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT

This is to certify that

LYNCH CARSON G

Located at

1308 WASHINGTON AVE

PERMIT ID: 2016-00182

ISSUE DATE: 02/04/2016

CBL: 437 A055001

has permission to **AMENDMENT NO. 1 to Building Permit #2014-02631, relocate the basement stairs to the mudroom, remove chimney and add pass thru wall opening**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

*Approved Property Use - Zoning*  
single-family

*Building Inspections*

*Fire Department*

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703 (ONLY)  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status or Schedule an Inspection On-Line at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

## **REQUIRED INSPECTIONS:**

Framing Only

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

|   |                                      |  |  |   |
|---|--------------------------------------|--|--|---|
| <b>City of Portland, Maine - Building or Use Permit</b>   |                                      | <b>Permit No:</b><br>2016-00182  | <b>Date Applied For:</b><br>01/27/2016 | <b>CBL:</b><br>437 A055001                              |
| 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716   |                                      |  |  |   |
| <b>Proposed Use:</b><br>Same: Single-Family Home  |                                      | <b>Proposed Project Description:</b><br>AMENDMENT NO. 1 to Building Permit #2014-02631, relocate the basement stairs to the mudroom, remove chimney and add pass thru wall opening |  |   |
| <b>Dept:</b> Zoning   | <b>Status:</b> Approved w/Conditions | <b>Reviewer:</b> Christina Stacey  | <b>Approval Date:</b> 02/01/2016       |   |
| <b>Note:</b>  |                                      |  |  | <b>Ok to Issue:</b> <input checked="" type="checkbox"/> |
| <b>Conditions:</b>  |                                      |  |  |   |
| 1) .All conditions from previous permits for this project are still in effect with the issuance of this permit. |                                      |  |  |   |