

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



**This is to certify that**

EIDE MATTHEW P & NATALIE G EIDE JTS

**Located at**

32 SARA LN

**PERMIT ID:** 2013-01145

**ISSUE DATE:** 07/29/2013

**CBL:** 437 D084001

has permission to **Change of Use to Home Occupation for up to six (6) children plus two (2) children after school**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.	A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.
---	--

*/s/ Chris Pirone*

*/s/ Jeanie Bourke*

**Fire Official**

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

***Approved Property Use - Zoning***

Single Family Dwelling with a home occupation for upto six children plus two children after school

***Building Inspections***

**Use Group:** One      **Type:**  
Dwelling  
Single Family with Home Day Care  
ENTIRE  
MUBEC/IRC 2009

***Fire Department***

**BUILDING PERMIT INSPECTION PROCEDURES**  
Please call 874-8703 (ONLY)  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

**REQUIRED INSPECTIONS:**

Certificate of Occupancy/Final

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

<b>City of Portland, Maine - Building or Use Permit</b>		<b>Permit No:</b> 2013-01145	<b>Date Applied For:</b> 06/05/2013	<b>CBL:</b> 437 D084001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
<b>Proposed Use:</b> Single Family w/Home Occupation	<b>Proposed Project Description:</b> Change of Use to Home Occupation for up to six (6) children plus two (2) children after school			
<b>Dept:</b> Zoning <b>Status:</b> Approved w/Conditions <b>Reviewer:</b> Marge Schmuckal <b>Approval Date:</b> 06/07/2013				
<b>Note:</b>				<b>Ok to Issue:</b> <input checked="" type="checkbox"/>
<b>Conditions:</b>				
1) This property shall remain a single family dwelling with a Home Occupation for Daycare for upto six (6) children plus two (2) children after school with the issuance of this permit and subsequent issuance of a Certificaste of Occupancy. Any change of use shall require a separate permit application for review and approval. Any increase in the number of children SHALL require a separate permit, ZBA action, and approvals.				
2) Separate permits shall be required for any new signage. Under the Home Occupation guidelines				
<b>Dept:</b> Building <b>Status:</b> Approved w/Conditions <b>Reviewer:</b> Jeanie Bourke <b>Approval Date:</b> 07/23/2013				
<b>Note:</b>				<b>Ok to Issue:</b> <input checked="" type="checkbox"/>
<b>Conditions:</b>				
1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
2) This permit is approved for compliance with the City of Portland zoning ordinance for home occupation, and the State of Maine adoption of MUBEC, as revised. This designates the State Fire Marshal and DHHS to regulate compliance of this structure for the proposed Family Child Care Provider. <a href="http://www.maine.gov/dps/fmo/documents/ChildCareFacility.pdf">http://www.maine.gov/dps/fmo/documents/ChildCareFacility.pdf</a>				
3) This is a Change of Use ONLY permit. It does NOT authorize any construction activities.				
4) Permit approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
<b>Dept:</b> Fire <b>Status:</b> Approved w/Conditions <b>Reviewer:</b> Chris Pirone <b>Approval Date:</b> 07/26/2013				
<b>Note:</b>				<b>Ok to Issue:</b> <input checked="" type="checkbox"/>
<b>Conditions:</b>				
1) Single-station photoelectric smoke alarms are required. They shall be powered by the building's electrical service with battery backup and shall be interconnected. Smoke alarms shall be installed in the following locations:				
(1) All sleeping rooms				
(2) Outside each separate sleeping area, in the immediate vicinity of the sleeping rooms				
(3) On each level of the dwelling unit, including basements.				
Single-station Carbon Monoxide (CO) alarms are required. They shall be powered by the building's electrical service with battery backup and shall be interconnected. CO alarms shall be installed in the following locations:				
(1) Outside each separate dwelling unit sleeping area in the immediate vicinity of the bedrooms				
(2) On every occupiable level of the dwelling unit, including basements, excluding attics and crawl spaces				
2) Shall Comply with 2009 NFPA 101 Chapter 16 New Day-Care Occupancies				
Pay special attention to:				
16.6 Day Care Homes				
16.6.2.4. Number of Means of Escape				
16.6.3.1 Protection of Vertical Openings				
16.6.3.2 Protection from Hazards				
3) All construction shall comply with City Code Chapter 10.				