

ELECTRICAL PERMIT

City of Portland, Me.

Single

Area #2



[Handwritten initials]

To the Chief Electrical Inspector, Portland Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the City of Portland Electrical Ordinance, National Electrical Code and the following specifications:

Date 5/5/00
 Permit # _____
 CBL# 439-D-023

SITE LOCATION: 45 Chesley Ave Portland ME

OWNER Roland Gagne TENANT _____

						TOTAL EACH FEE		
OUTLETS	Receptacles	<u>5</u>	Switches		Smoke Detectors		.20	<u>1.00</u>
FIXTURES	incandescent		fluorescent		Strips		.20	
SERVICES	Overhead	<u>1</u>	Underground		TTL AMPS <u>100</u>	<800	15.00	<u>15.00</u>
	Overhead		Underground			>800	25.00	
Temporary Service	Overhead		Underground		TTL AMPS		25.00	
METERS	(number of)						1.00	
MOTORS	(number of)						2.00	
RESID/COM	Electric units						1.00	
HEATING	oil/gas units		Interior		Exterior		5.00	
APPLIANCES	Ranges		Cook Tops		Wall Ovens		2.00	
	Insta-Hot		Water heaters		Fans		2.00	
	Dryers		Disposals		Dishwasher		2.00	
	Compactors		Spa		Washing Machine		2.00	
	Others (denote)						2.00	
MISC. (number of)	Air Cond/win						3.00	
	Air Cond/cent				Pools		10.00	
	HVAC		EMS		Thermostat		5.00	
	Signs						10.00	
	Alarms/res						5.00	
	Alarms/com						15.00	
	Heavy Duty(CRKT)						2.00	
	Circus/Carnv						25.00	
	Alterations						5.00	
	Fire Repairs						15.00	
	E Lights						1.00	
	E Generators						20.00	
PANELS	Service		Remote		Main		4.00	
TRANSFORMER	0-25 Kva						5.00	
	25-200 Kva						8.00	
	Over 200 Kva						10.00	
						TOTAL AMOUNT DUE		<u>35.00</u>
						MINIMUM FEE/COMMERCIAL	35.00	
						MINIMUM FEE	25.00	

INSPECTION: Will be ready _____ or will call

CONTRACTORS NAME Rick Binette MASTER LIC. # MS60008261
 ADDRESS PO 1277 Biddeford ME LIMITED LIC. # _____
 TELEPHONE 207-282-7490

SIGNATURE OF CONTRACTOR Roland N. Gagne Jr

ELECTRICAL INSTALLATIONS

Permit Number _____

Location _____

Owner _____

Date of Permit _____

Final Inspection _____

By Inspector _____

INSPECTION: Service 5/12/00 by V. Caddelell
Service called in 5/17/00
Closing-in _____ by _____

PROGRESS INSPECTIONS: _____ / _____ / _____
_____ / _____ / _____
_____ / _____ / _____
_____ / _____ / _____
_____ / _____ / _____
_____ / _____ / _____

DATE:	REMARKS:
5/16	MET RICK B. @ SITE HE COUNDN'T FINISH INST.
	WHILE THERE - HE NEEDS 1/2" M. ADPTR FOR GR. COND.
	PROTECTOR PIPE. WENT BACK @ 1 PM TO JUSA BUT
	DAVE CADDELL HAD ALREADY O.K.'D.

Washington Ave Post Connected