

Sprinkler Systems Inspection Co.

A Division of Sprinkler Systems, Inc.

P.O. Box 1285


Lewiston, ME 04243-1285

Ph: 207-782-0104 Fax: 783-4865

www.sprinklersystemsinc.com

BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE RECORD

| General Information | | | | |
|--|--|---|------------------------------------|---|
| Address: 54 Commercial Street 54 Commercial Street | | | | |
| Portland, ME | | | | |
| Location of Assembly | | | Date of Installation | Incoming Line Pressure |
| Utility Room | | | n/a | |
| Manufacturer: Watts | | Model: 909QT | SN: 639121 | |
| Size: 1 Inch | | Assembly Type: RPBA (Reduced Pressure Backflow Assembly) | | |
| Test & Repairs Information | | | | |
| | Check Valve #1 | Check Valve #2 | Differential Pressure Relief Valve | Pressure Vacuum Breaker |
| Initial Test | - Pressure drop across first check valve: 8.4 psi | Closed Tight - Pressure drop across second check valve: psi | opened @ 3 psi | air inlet open @ psi Check valve held @ psi |
| Repairs | | | | |
| Final Test | - Pressure drop across first check valve: psi | - Pressure drop across check valve: psi | opened @ psi | |
| Condition of #2 Control Valve: | | | | |
| Remarks: Assembly Passed | | | | |
| Test Kit | | | | |
| Mfr: | Model: | SN: | Calib. date: | |

| Approvals | | |
|---|-------------------|--|
| I have completed the above test and hereby certify that this backflow device performed satisfactorily and meets all federal, State and local codes and regulations as required. | | |
| Name of Certified Technician: Tom Zielinski, Inspector #711 | Technician Phone: | Technician Certification #: ABPA 20-172 |
| Name of Witness to Test: | Witness Phone: | Inspection Date: 1/29/2016 |
| Certified Technician Signature: Tom Zielinski, Inspector #711 | | Customer Signature: |
|  | | |