

- C CLOCK
- CL LARGE CLOCK
- S SPEAKER - CEILING MOUNTED (PROVIDED BY OWNER)
- SW SPEAKER - WALL MOUNTED (PROVIDED BY OWNER)
- IE INTERCOM
- V VOLUME CONTROL

- 20A, 125V, 2P, 3W, NEMA 5-20R
- 20A, 125V, 2P, 3W, NEMA L5-20R (TWISTLOCK)
- 20A, 250V, 2P, 3W, NEMA 6-30R
- 30A, 250V, 2P, 3W, NEMA 6-30R
- 50A RANGE RECEPTACLE-250V, 2P, 3W, NEMA 14-60R, (3)R#+ (1)R10 TO 40A, 2P CIRCUIT BREAKER

NOTE:
PROVIDE MATCHING CORD AND PLUG FOR SINGLE RECEPTACLES

NOTE
SYMBOLS AND ABBREVIATIONS SHOWN ON THIS SHEET ARE FOR REFERENCE ONLY AND DO NOT INDICATE THEIR INCORPORATION INTO THE DESIGN

1. BRANCH CIRCUIT WIRING NOT SHOWN. THE INTENT OF THESE DRAWINGS IS TO SHOW THE GENERAL ARRANGEMENT OF CIRCUITRY AND LAYOUT & LOCATIONS OF EQUIPMENT. IT IS NOT THE INTENT OF THESE DRAWINGS TO SHOW EVERY WIRE, DEVICE, BOX, FITTING OR APPURTENANCE NEEDED FOR A COMPLETE INSTALLATION NOR IS IT THE INTENT TO SHOW THE LAYOUT OF BRANCH CIRCUIT WIRING.
2. DISCONNECT, REMOVE, RELOCATE, AND RECONNECT ELECTRICAL CONDUIT, WIRING, DEVICES, BOXES, FIXTURES, EQUIPMENT, ETC. AS INDICATED AND AS REQUIRED TO FACILITATE THE WORK OF DIVISION 28 AND OTHER DIVISIONS. THESE DRAWINGS ARE NOT INTENDED TO INDICATE ALL ITEMS TO BE REMOVED.
3. DO NOT SCALE THE DRAWINGS. REFER TO ARCHITECTURAL DRAWINGS AND EXISTING CONDITIONS FOR EXACT DIMENSIONS.
4. THE LOCATION OF EQUIPMENT, OUTLETS, ETC. AS GIVEN ON THE DRAWINGS, IS APPROXIMATE. IT SHALL BE UNDERSTOOD THAT THESE LOCATIONS ARE SUBJECT TO MODIFICATION AS MAY BE FOUND NECESSARY OR DESIRABLE AT THE TIME OF INSTALLATION IN ORDER TO MEET PROJECT REQUIREMENTS. SUCH CHANGES SHALL BE MADE WITHOUT EXTRA CHARGE.
5. ALL ELECTRICAL DEVICES, WHEN INSTALLED, SHALL BE PROTECTED FROM DAMAGE DURING CONSTRUCTION. COVER PLATES SHALL BE INSTALLED AFTER FINISH MATERIALS HAVE BEEN APPLIED.
6. COORDINATE ALL WORK WITH OTHER DIVISIONS AND THE OWNER.
7. VERIFY EXACT POWER REQUIREMENTS OF EQUIPMENT PRIOR TO ROUGH IN.
8. LINE VOLTAGE POWER WIRING FOR EQUIPMENT & CONTROL SHALL BE PERFORMED BY DIVISION 26. ALL CONTROL WIRING OPERATING AT LESS THAN 120 VOLTS FOR MECHANICAL EQUIPMENT SHALL BE BY DIVISION 23.
9. NO WIRING THAT BECOMES UNUSED AS PART OF THIS PROJECT SHALL BE ABANDONED IN PLACE.

1. INSTALLATION OF EXIT SIGN SHALL BE COORDINATED WITH INSTALLATION OF GLASS CURTAIN WALL. COORDINATE WITH CURTAIN WALL INSTALLER FOR ROUTING OF BRANCH CIRCUIT CONDUCTORS.
2. PROVIDE POWER CONNECTION FOR AUTOMATIC DOOR OPERATOR HARDWARE. COORDINATE WITH CURTAIN WALL AND DOOR HARDWARE PROVIDER FOR ROUTING OF BRANCH CIRCUIT CONDUCTORS.
3. PROVIDE FIRE ALARM RECORDS STORAGE CABINET PER CITY OF PORTLAND FIRE ALARM REQUIREMENTS.
4. PROVIDE RACEWAYS AND BOXES AS NEEDED FOR CONTROL AND SAFETY DEVICES OF OVERHEAD DOOR SYSTEM. COORDINATE WITH OVERHEAD DOOR INSTALLER FOR EXACT REQUIREMENTS. ALL CONTROL AND SAFETY DEVICES AND CABLING SHALL BE PROVIDED BY OVERHEAD DOOR INSTALLER.
5. PROVIDE CONNECTION OF FACTORY SUPPLIED LIGHT FIXTURE IN SHOWER. DIVISION 26 SHALL PROVIDE LOCAL TIMER SWITCH FOR CONTROL OF LUMINAIRE. CONNECT TO UN-SWITCHED PORTION OF EXISTING LOCAL LIGHTING CIRCUIT.
6. CONNECT EXISTING RELOCATED UNIT HEATER. UTILIZE EXISTING BRANCH CIRCUIT. EXTEND BRANCH CIRCUIT CONDUCTORS AS NEEDED TO FACILITATE INSTALLATION. CONNECT ALL CONTROL DEVICES TO RETURN UNIT HEATER TO FULL OPERATION. REFER TO DEMO KEYED NOTE 6.
7. PROVIDE ADDITIONAL HARDWARE AND LUMINAIRE PARTS AS NEEDED TO EXTEND LUMINAIRE HOUSING TO END OF CEILING.
8. COORDINATE INSTALLATION OF FIRE ALARM CABLING WITH CURTAIN WALL INSTALLER. CABLING SHALL BE CONCEALED INSIDE HOLLOW SPACES OF CURTAIN WALL ASSEMBLY WHEREVER POSSIBLE.
9. COORDINATE WITH OWNER AND VERIFY MOUNTING HEIGHT OF POWER AND DATA OUTLETS FOR FLAT SCREEN MONITOR PRIOR TO ROUGH-IN.
10. COLUMN MOUNTED RECEPTACLES SHALL BE FED FROM ABOVE. INSTALL SURFACE MOUNTED GALVANIZED RIGID STEEL CONDUIT AND BOXES CENTERED ON WEB OF STRUCTURAL STEEL COLUMN. CREATE CONDUIT RADIUS AS SMALL AS POSSIBLE FOR TRANSITION FROM CEILING SPACE TO STEEL COLUMN.
11. EXIT SIGN SHALL BE MOUNTED ON FACE OF STEEL GIRT. CONCEAL WIRING IN HOLLOW SPACES OF STRUCTURAL STEEL WHEREVER POSSIBLE.
12. TYPICAL CEILING SPEAKERS TO BE FURNISHED AND WIRED BY OWNER. SHOWN IS FOR REFERENCE ONLY.

G1 CLOCKS AND SPEAKERS
NO SCALE

G3 SINGLE RECEPTACLES
NO SCALE

G7 GENERAL NOTES (APPLY TO ALL DRAWINGS)
NO SCALE

- NURSE CALL PATIENT STATION. PROVIDE BOXES AND EMPTY CONDUITS FOR USE BY OWNER'S NURSE CALL VENDOR. COORDINATE WITH OWNER.
- NURSE CALL DOME LIGHT. PROVIDE EMPTY BOXES AND CONDUITS FOR USE BY OWNER'S NURSE CALL VENDOR. COORDINATE WITH OWNER.
- NURSE CALL ANNUNCIATOR PANEL.

- ◇ DUPLEX RECEPTACLE - 20A, 125V, 2P, 3W, NEMA 5-20R
 - ⊕ DOUBLE DUPLEX RECEPTACLE
 - ⊕ DUPLEX RECEPTACLE, HATCH INDICATES CONNECTION TO CRITICAL BRANCH, TYPICAL
 - ⊕ GFCI DUPLEX RECEPTACLE
 - ⊕ GFCI DOUBLE DUPLEX RECEPTACLE
 - ⊕ GFCI RECEPTACLE WITH WEATHERPROOF COVER
 - ⊕ GFCI RECEPTACLE IN WP ENCLOSURE ON ROOF
 - ⊕ MULTI-OUTLET STRIP, PROVIDE OUTLETS 24" OC UNO, MOUNT 48" AFF UNO
- NOTES:
1. MOUNT RECEPTACLES WITH CENTERLINE 18" AFF UNO
2. MOUNT EXTERIOR RECEPTACLES WITH CENTERLINE 24" AFG UNO

- F◇ DUPLEX RECEPTACLE, 20A, 125V, 2P, 3W, NEMA 5-20R, MOUNT IN FLUSH FLOOR BOX
- F⊕ DOUBLE DUPLEX RECEPTACLE, 20A, 125V, 2P, 3W, NEMA 5-20R, MOUNT IN FLUSH FLOOR BOX
- F⊔ JUNCTION BOX, MOUNT IN FLUSH FLOOR BOX
- F⊖ EMPTY FLUSH FLOOR BOX
- F◇ DUPLEX RECEPTACLE, PEDESTAL MOUNTED
- F⊔ SINGLE RECEPTACLE, PEDESTAL MOUNTED
- F⊖ JUNCTION BOX, PEDESTAL MOUNTED
- C◇ DUPLEX RECEPTACLE, FLUSH MOUNTED IN CEILING
- C⊕ DOUBLE DUPLEX RECEPTACLE, FLUSH MOUNTED IN CEILING
- C⊖ DUPLEX GFCI RECEPTACLE, FLUSH MOUNTED IN CEILING
- C⊕ DOUBLE DUPLEX GFCI RECEPTACLE, FLUSH MOUNTED IN CEILING
- C⊔ DATA OUTLET, FLUSH MOUNTED IN CEILING, SEE SCHEDULE FOR TYPE
- C⊔ JUNCTION BOX, FLUSH MOUNTED IN CEILING
- ⊕ OVERHEAD RECEPTACLE DROP, DUPLEX
- ⊕ OVERHEAD RECEPTACLE DROP, DOUBLE DUPLEX
- ⊕ OVERHEAD RECEPTACLE DROP, GFCI

G9 KEYED NOTES (APPLY TO ALL DRAWINGS)
NO SCALE

1. EXISTING FIRE ALARM PANEL TO BE REMOVED. EXISTING FIRE ALARM SYSTEM SHALL BE COMPLETELY REPLACE WITH NEW DIGITAL ADDRESSABLE SYSTEM WITH VOICE EVACUATION CAPABILITY.
2. COMPLETELY REMOVE ALL EXISTING ELECTRICAL EQUIPMENT IN THIS ROOM INCLUDING BUT NOT LIMITED TO: LIGHTING, LIGHTING CONTROLS, POWER EQUIPMENT, FIRE ALARM EQUIPMENT AND DEVICES, TELEPHONE DEVICES, LOCAL AREA NETWORK DEVICES AND PUBLIC ADDRESS EQUIPMENT. REMOVE BACK TO ACTIVE SOURCE OR NEXT ACTIVE DEVICE SCHEDULED TO REMAIN EXISTING SPRINKLER COMPRESSOR PUMP SHALL REMAIN.
3. REMOVE EXISTING ELECTRICAL SWITCHGEAR, DISCONNECTS, PANELBOARDS, TRANSFORMERS AND CONTROL EQUIPMENT. EXISTING ELECTRICAL SUBFEEDS TO EQUIPMENT OUTSIDE OF THIS ROOM SHALL REMAIN. PREP FOR RE-ROUTING TO NEW ELECTRICAL ROOM. COORDINATE ALL SHUTDOWNS WITH OWNER AND ARCHITECT.
4. EXISTING FIXTURE TO BE SAVED FOR RELOCATION TO NEW ELECTRICAL/MECHANICAL ROOM 136. REFER TO LIGHTING PLAN FOR LOCATION.
5. EXISTING EXTERIOR LIGHTING CONTROLS AND OVERRIDE SWITCHES SHALL BE SAVED AND RELOCATED TO NEW ELECTRICAL ROOM 136. MODIFY AND EXTEND ALL EXISTING CIRCUITRY AS NEEDED TO RESTORE LIGHTING SYSTEM TO FULL FUNCTION. COORDINATE ALL SHUT DOWNS WITH OWNER AND ARCHITECT.
6. DISCONNECT ELECTRICAL FEED TO EXISTING UNIT HEATER, RETAIN BRANCH CIRCUIT FOR RECONNECTION OF UNIT HEATER IN NEW LOCATION. REFER TO KEYED NOTE 6.
7. ALL CEILING MOUNTED LIGHTING AND DEVICES IN THIS AREA TO BE REMOVED, STORED AND REINSTALLED AS REQUIRED TO ACCOMMODATE NEW SECONDARY ELECTRIC FEEDER ROUTING.

F5 NURSE CALL
NO SCALE

- TBD TO BE DETERMINED
- AFB ABOVE FINISHED FLOOR
- AFG ABOVE FINISHED GRADE
- BAS BUILDING AUTOMATION SYSTEM
- BKBD BACKBOARD
- CATV CABLE TV
- CB CIRCUIT BREAKER
- FWE FURNISHED WITH EQUIPMENT
- P/O PART OF
- MT MOUNT
- NEC NATIONAL ELECTRICAL CODE
- NF NON-FUSED
- TEL TELEPHONE
- UNO UNLESS NOTED OTHERWISE
- UF UNDER FLOOR
- WP WEATHERPROOF
- WG WIREGUARD
- XFMR TRANSFORMER
- CH COUNTER HEIGHT - REFER TO ARCHITECTURAL INTERIOR ELEVATION PLANS
- (E) EXISTING ITEM TO REMAIN
- (R) REMOVE ITEM AND DISPOSE OF PROPERLY
- (ER) RELOCATED ITEM AT NEW LOCATION
- (RL) REMOVE AND RELOCATE

E3 RECEPTACLES
NO SCALE

- F1 LIGHT FIXTURE, RECESSED TROFFER, TYPICAL
- ⊕ INDICATES LIGHT FIXTURE TYPE ON LUMINAIRE SCHEDULE
- ⊕ LOWER CASE LETTER INDICATES SWITCHING, TYPICAL
- ⊕ NUMBER INDICATES CIRCUITING, TYPICAL
- ⊕ RECESSED DOWNLIGHT
- ⊕ RECESSED WALL WASHER DOWNLIGHT
- ⊕ WALL MOUNTED LIGHT FIXTURE
- ⊕ CEILING SURFACE MOUNTED LIGHT FIXTURE
- ⊕ PENDANT MOUNTED LIGHT FIXTURE
- ⊕ LINEAR LIGHT FIXTURE, CEILING SURFACE MOUNTED
- ⊕ LINEAR LIGHT FIXTURE, PENDANT MOUNTED
- ⊕ LINEAR LIGHT FIXTURE, WALL MOUNTED
- ⊕ REMOTE BALLAST, ALLOW 9" IN ALL DIRECTIONS BETWEEN BALLASTS
- ⊕ FIRE ALARM CONTROL PANEL, MOUNT WITH TOP OF PANEL NOT MORE THAN 72" AFF
- ⊕ FIRE ALARM ANNUNCIATOR, MOUNT WITH TOP OF PANEL NOT MORE THAN 72" AFF
- ⊕ SMOKE DETECTOR
- ⊕ SMOKE DETECTOR, "E" INDICATES CONNECTION FOR ELEVATOR RECALL
- ⊕ SINGLE STATION SMOKE DETECTOR WITH AUDIBLE INDICATING APPLIANCE, MOUNT 80" AFF TO BOTTOM OR 6" BELOW CEILING WHICHEVER IS LOWER
- ⊕ SINGLE STATION SMOKE DETECTOR WITH AUDIBLE/VISUAL INDICATING APPLIANCE, MOUNT 80" AFF TO BOTTOM OR 6" BELOW CEILING WHICHEVER IS LOWER
- ⊕ HEAT DETECTOR
- ⊕ DUCT SMOKE DETECTOR
- ⊕ REMOTE TEST/INDICATOR FOR DUCT SMOKES, MOUNT ON CEILING BENEATH UNIT, OR WALL MOUNT WHERE INDICATED ON PLANS
- ⊕ MANUAL PULL STATION, MOUNT 48" AFF
- ⊕ SPEAKER/VISUAL INDICATING APPLIANCE, CANDELA AS NOTED ON PLANS, MOUNT 80" AFF TO BOTTOM OR 6" BELOW CEILING WHICHEVER IS LOWER
- ⊕ HORN/VISUAL INDICATING APPLIANCE, CANDELA AS NOTED ON PLANS, MOUNT 80" AFF TO BOTTOM OR 6" BELOW CEILING WHICHEVER IS LOWER
- ⊕ VISUAL INDICATING APPLIANCE, CANDELA AS NOTED ON PLANS, MOUNT 80" AFF TO BOTTOM OR 6" BELOW CEILING WHICHEVER IS LOWER
- ⊕ VISUAL INDICATING APPLIANCE, 15 CANDELA, 120V, CONNECT TO OPERATE UPON ACTIVATION OF ROOM SMOKE DETECTOR
- ⊕ MINI HORN
- ⊕ AUDIO/VISUAL INDICATING APPLIANCE WITH PULL STATION DIRECTLY BELOW
- ⊕ MAGNETIC DOOR HOLD OPEN DEVICE
- ⊕ TRANSFORMER
- ⊕ SPRINKLER SYSTEM WATER FLOW SWITCH, PROVIDED UNDER DIVISION 23, WIRED UNDER DIVISION 26
- ⊕ SPRINKLER SYSTEM TAMPER SWITCH, PROVIDED UNDER DIVISION 23, WIRED UNDER DIVISION 26
- ⊕ SPRINKLER SYSTEM CHECK VALVE PRESSURE SWITCH, FURNISHED AND INSTALLED UNDER DIVISION 23, WIRED UNDER DIVISION 26
- ⊕ SPRINKLER SYSTEM EXCESS PRESSURE PUMP, FURNISHED AND INSTALLED UNDER DIVISION 23, WIRED UNDER DIVISION 26
- ⊕ KNOX BOX, MOUNT 60" AFF - PROVIDE IN ACCORDANCE WITH LOCAL FIRE DEPARTMENT REQUIREMENTS
- ⊕ SMOKE DAMPER
- ⊕ FIRE ALARM ADDRESSABLE INPUT MODULE
- ⊕ FIRE ALARM MONITOR MODULE
- ⊕ PANELBOARD - SURFACE MOUNTED
- ⊕ PANELBOARD - FLUSH MOUNTED
- ⊕ FUSED DISCONNECT SWITCH
- ⊕ NON-FUSED DISCONNECT SWITCH
- ⊕ MOTOR STARTER - NUMBER INDICATES NEMA SIZE
- ⊕ COMBINATION MOTOR STARTER/FUSED DISCONNECT
- ⊕ MOTOR - # INDICATES HORSEPOWER RATING, OHD = OVERHEAD DOOR
- ⊕ MOTOR RATED 20A TOGGLE SWITCH, PROVIDE NUMBER OF POLES AS NEEDED
- ⊕ METER AND CABINET
- ⊕ JUNCTION BOX - SIZE PER NEC
- ⊕ TRANSFORMER - NUMBER INDICATES DESIGNATION
- ⊕ VARIABLE FREQUENCY DRIVE
- ⊕ TRANSIENT VOLTAGE SURGE SUPPRESSOR
- ⊕ EMERGENCY SHUTOFF SWITCH - WALL MOUNTED 48" TO CENTERLINE - PROVIDE TAMPER-PROOF COVER
- ⊕ CONDUIT TURNING UP
- ⊕ CONDUIT TURNING DOWN
- ⊕ WIRING UNDERGROUND OR UNDERSLAB
- ⊕ LOW VOLTAGE WIRING
- ⊕ HOMERUN
- ⊕ SINGLE-PHASE HOMERUN OR MULTIPLE HOMERUN UTILIZING THE SAME CONDUIT
- ⊕ 3-PHASE HOMERUN OR MULTIPLE HOMERUN UTILIZING THE SAME CONDUIT
- ⊕ L-20A, 1P INDICATES 20A, 1P LOCKING CIRCUIT BREAKER
- ⊕ FLEXIBLE CONNECTION
- ⊕ GROUNDING SYSTEM
- ⊕ POWER POLE
- ⊕ PUSHBUTTON
- ⊕ PUSHBUTTON - HANDICAPPED DOOR OPERATOR
- ⊕ HANDICAPPED DOOR OPERATING MECHANISM
- ⊕ CONTROL PACKAGE - FURNISHED WITH EQUIPMENT
- ⊕ CABLE TRAY
- ⊕ GROUNDING BUS - PROVIDE WITH #4 COPPER TO MAIN GROUNDING ELECTRODE.
- ⊕ BATHROOM EXHAUST FAN- PROVIDED BY DIV. 26, FL= FAN/LIGHT COMBO

E7 FLOOR AND CEILING DEVICES
NO SCALE

D9 DEMO KEYED NOTES (APPLY TO ALL DRAWINGS)
NO SCALE

- CENTERLINE 48" AFF, UNO -
- ⊕ LIGHT SWITCH, 20A, 125V/277V, LETTER INDICATES SWITCHING
- ⊕ THREE-WAY LIGHT SWITCH
- ⊕ FOUR-WAY LIGHT SWITCH
- ⊕ TWO-POLE SWITCH
- ⊕ KEY OPERATED SWITCH
- ⊕ MOTOR RATED SWITCH
- ⊕ SINGLE POLE SWITCH WITH RED PILOT LIGHT - RED LIGHT SHALL GLOW WHEN CIRCUIT IS ENERGIZED
- ⊕ MULTI-GANGED SWITCHES, GANG UNDER ONE PLATE, LETTER INDICATES SWITCHING
- ⊕ OCCUPANCY SENSOR SWITCH, WALL MOUNTED
- ⊕ 2-BUTTON OCCUPANCY SENSOR SWITCH
- ⊕ OCCUPANCY SENSOR, CEILING MOUNTED
- ⊕ OCCUPANCY SENSOR, WALL MOUNTED
- ⊕ INCANDESCENT DIMMER SWITCH
- ⊕ FLUORESCENT DIMMER SWITCH
- ⊕ HANDICAP SWITCHES FOR HOOD LIGHT AND FAN
- ⊕ TIMER SWITCH, 60 MINUTES
- ⊕ LOW VOLTAGE LIGHT SWITCH
- ⊕ LIGHTING TIME CLOCK
- ⊕ LIGHTING CONTACTOR
- ⊕ LIGHTING CONTROL PANEL
- ⊕ PHOTOCELL

C1 ABBREVIATIONS
NO SCALE

C3 LUMINAIRES
NO SCALE

- ⊕ TELEPHONE WALL OUTLET, 44" AFF UNO. PROVIDE (1) HORIZONTAL CABLE PER LOCATION
- ⊕ TELEPHONE OUTLET, 18" AFF UNO. PROVIDE (1) HORIZONTAL CABLE PER LOCATION
- ⊕ TEL/DATA OUTLET, 18" AFF UNO. PROVIDE (2) HORIZONTAL CABLES PER LOCATION
- ⊕ DATA OUTLET, 18" AFF UNO. PROVIDE (1) HORIZONTAL CABLE PER LOCATION
- ⊕ WIRELESS ACCESS POINT CEILING MOUNTED. PROVIDE (1) HORIZONTAL CABLE PER LOCATION
- ⊕ WIRELESS ACCESS POINT WALL MOUNTED. PROVIDE (1) HORIZONTAL CABLE PER LOCATION
- 1. PROVIDE BOXES, RACKS, ETC. WHERE INDICATED OR NEEDED
- 2. IN AREAS WITHOUT CEILINGS, CONDUIT PROVIDED TO NEAREST ACCESSIBLE CORRIDOR CEILING - 1" CONDUIT TO SINGLE GANG BOXES, 1-1/4" CONDUIT TO DOUBLE GANG BOXES.

- ⊕ HATCHING INDICATES FIXTURE WITH EMERGENCY BATTERY BALLAST.
- ⊕ EMER BATTERY UNIT WITH INTEGRAL HEADS, MT 7-6" AFF BP# INDICATES BATTERY UNIT DESIGNATION CONNECT TO UNSWITCHED PORTION OF LOCAL LIGHTING CIRCUIT
- ⊕ EXIT SIGN, SELF-POWERED, WALL MOUNTED, SHADING INDICATES FACE(S), MOUNT AT 7-6" AFF OR OVER DOOR, CONNECT TO UNSWITCHED PORTION OF LOCAL LIGHTING CIRCUIT

A5 FIRE ALARM SYSTEM
NO SCALE

A7 POWER DISTRIBUTION
NO SCALE

A9 LIGHT SWITCHES
NO SCALE

A1 TECHNOLOGY
NO SCALE

A3 EMERGENCY LUMINAIRES
NO SCALE

Allied Engineering
Structural Mechanical Electrical Commissioning


160 Veranda Street
Portland, Maine 04103
T: 207.221.2260
F: 207.221.2266
Web: www.allied-eng.com

Allied Project No: 12008
Cad File: 12008E.dwg
Checked By: CAF

SSA

Scott Simons Architects
75 York Street, Portland, Maine 04101
www.simonsarchitects.com
207.772.4656

PROJECT NAME:
CASCO BAY FERRY TERMINAL
RENOVATIONS & ADDITIONS
56 COMMERCIAL STREET
PORTLAND, MAINE 04101

SEAL:


THIS DRAWING IS THE PROPERTY OF SCOTT SIMONS ARCHITECTS (SSA) AND IS NOT TO BE COPIED OR REPRODUCED IN PART OR WHOLE.
2012 © SCOTT SIMONS ARCHITECTS, LLC

REVISION:	DATE
1	DATE
2	DATE
3	DATE
4	DATE
5	DATE
6	DATE

DATE OF ISSUE: MAY 14, 2013
PROJECT NUMBER: 2011-0270
STATUS: ISSUED FOR BIDDING

**ELECTRICAL
LEGEND, NOTES &
ABBREVIATIONS**

E-000
2008 © Scott Simons Architects LLC

N:\Projects\2013\12008 - Casco Bay Ferry Terminal\01 Drawing Files\12008E.dwg May 13, 2013 - 3:00pm